



US Army Corps
of Engineers
Construction Engineering
Research Laboratories

AD-A277 734



USACERL Technical Report FE-94/02
December 1993
Coal Conversion Strategies for the Army,
Installation Technical Assistance

DTIC

S F D
APR 03 1994

(2)

Coal Conversion at Picatinny Arsenal and Forts Campbell, Bragg, and Gordon: A Feasibility Study

by
Mike C.J. Lin
Lee Thurber
Thomas Durbin
Ronald Tarvin

2728 94-10249

Public Law 99-190 requires the Department of Defense to increase the use of coal at its facilities in the United States. This study investigated the feasibility of converting oil- and gas-fired heating plants to coal firing at four Army installations: Fort Bragg, NC; Fort Campbell, KY; Fort Gordon, GA; and Picatinny Arsenal, NJ. Information on the energy systems at the selected sites was gathered by site visit and survey, and project life cycle cost (LCC) was computationally estimated.

The study concluded that, for the four installations, there would be a lower life-cycle cost (LCC) in maintaining the status quo than in building new plants. However, where new plant construction is planned, the larger the plants, the better its potential for cost-effectively using coal as a plant fuel. The use of coal at a new plant at Fort Bragg was found to be more cost effective than gas or oil, and may result in significant cost savings. For the other three installations studied, significant price increases in alternate fuels would be required before coal would become economically feasible (31 to 73 percent for gas, and 50 to 84 percent for #6 fuel oil).

DTIC QUALITY INSPECTED 3

Approved for public release; distribution is unlimited.

94-4-4-161

The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official endorsement or approval of the use of such commercial products. The findings of this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

DESTROY THIS REPORT WHEN IT IS NO LONGER NEEDED

DO NOT RETURN IT TO THE ORIGINATOR

USER EVALUATION OF REPORT

REFERENCE: USACERL Technical Report FE-94/02, *Coal Conversion at Picatinny Arsenal and Forts Campbell, Bragg, and Gordon: A Feasibility Study*

Please take a few minutes to answer the questions below, tear out this sheet, and return it to USACERL. As user of this report, your customer comments will provide USACERL with information essential for improving future reports.

1. Does this report satisfy a need? (Comment on purpose, related project, or other area of interest for which report will be used.)

2. How, specifically, is the report being used? (Information source, design data or procedure, management procedure, source of ideas, etc.)

3. Has the information in this report led to any quantitative savings as far as manhours/contract dollars saved, operating costs avoided, efficiencies achieved, etc.? If so, please elaborate.

4. What is your evaluation of this report in the following areas?

a. Presentation: _____

b. Completeness: _____

c. Easy to Understand: _____

d. Easy to Implement: _____

e. Adequate Reference Material: _____

f. Relates to Area of Interest: _____

g. Did the report meet your expectations? _____

h. Does the report raise unanswered questions? _____

i. General Comments. (Indicate what you think should be changed to make this report and future reports of this type more responsive to your needs, more usable, improve readability, etc.)

5. If you would like to be contacted by the personnel who prepared this report to raise specific questions or discuss the topic, please fill in the following information.

Name: _____

Telephone Number: _____

Organization Address: _____

6. Please mail the completed form to:

Department of the Army
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES
ATTN: CECER-IMT
P.O. Box 9005
Champaign, IL 61826-9005

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
<p>Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.</p>				
1. AGENCY USE ONLY (Leave Blank)	2. REPORT DATE December 1993	3. REPORT TYPE AND DATES COVERED Final		
4. TITLE AND SUBTITLE Coal Conversion at Picatinny Arsenal and Forts Campbell, Bragg, and Gordon: A Feasibility Study		5. FUNDING NUMBERS Reimbursable Order No. R-ARMY-TACOM		
6. AUTHOR(S) Mike C.J. Lin, Lee Thurber, Thomas Durbin, and Ronald Tarvin				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army Construction Engineering Research Laboratories (USACERL) P.O. Box 9005 Champaign, IL 61826-9005		8. PERFORMING ORGANIZATION REPORT NUMBER TR FE-94/02		
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) U.S. Army Center for Public Works (USACPW) ATTN: CECPW-FU-M Bldg 358 Fort Belvoir, VA 22060-5516		10. SPONSORING/MONITORING AGENCY REPORT NUMBER		
11. SUPPLEMENTARY NOTES Copies are available from the National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161.				
12a. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution is unlimited.			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) <p>Public Law 99-190 requires the Department of Defense to increase the use of coal at its facilities in the United States. This study investigated the feasibility of converting oil- and gas-fired heating plants to coal firing at four Army installations: Fort Bragg, NC; Fort Campbell, KY; Fort Gordon, GA; and Picatinny Arsenal, NJ. Information on the energy systems at the selected sites was gathered by site visit and survey, and project life cycle cost (LCC) was computationally estimated.</p> <p>The study concluded that, for the four installations, there would be a lower life-cycle cost (LCC) in maintaining the status quo than in building new plants. However, where new plant construction is planned, the larger the plants, the better its potential for cost-effectively using coal as a plant fuel. The use of coal at a new plant at Fort Bragg was found to be more cost effective than gas or oil, and may result in significant cost savings. For the other three installations studied, significant price increases in alternate fuels would be required before coal would become economically feasible (31 to 73 percent for gas, and 50 to 84 percent for #6 fuel oil).</p>				
14. SUBJECT TERMS Ft. Bragg, NC Ft. Campbell, KY Ft. Gordon, GA		Army coal conversion program coal-fixed technologies cost-effectiveness		15. NUMBER OF PAGES 272
				16. PRICE CODE
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIFICATION OF ABSTRACT Unclassified	20. LIMITATION OF ABSTRACT SAR	

FOREWORD

This study was conducted for the U.S. Army Center for Public Works (USACPW), Fort Belvoir, VA, under a reimbursable Work Unit R-ARMY-TACOM, "Coal Conversion Strategies for the Army, Installation Technical Assistance." The USACPW technical monitor was James F. Donnelly, CECPW-FU-M.

The research was performed by the Energy and Utility Systems Division (FE), of the Infrastructure Laboratory (FL), of the U.S. Army Construction Engineering Research Laboratories (USACERL). Dr. Mike C.J. Lin was the USACERL principal investigator. Dr. David M. Joncich is Chief, USACERL-FE, and Dr. Michael J. O'Connor is Chief, USACERL-FL. The USACERL technical editor was William J. Wolfe, Information Management Office.

Special acknowledgement is given to the following persons at Fort Campbell, Fort Bragg, Fort Gordon, and Picatinny Arsenal, for their assistance in providing the needed information: at Fort Campbell, Dewayne Smith, Patty Teyhen, Judy Husdon, Dick Huser, Bill Joiner, Mike Chilton, Donald Terrell, Kay Gregory, Jack Thompson, Les Yarbrough; Fort Bragg: Steve Smith, Mike Laurenceau, Glen Prillaman, Jimmy Thomas, Linwood Hill, Gene Gaskins, Jimmie Jude, Marvin Parker, Charles Nevers, Richard Smith, Bill Repsher, Dewy Suggs, Leroy Walker; at Fort Gordon, Curt Oglesby, Jerry Delaughter, Pat Arthur, Carlton Shuford, Jack Hayes, Ben Goins; at Picatinny Arsenal, Vernon Shankle, Vinni Kapoor.

LTC David J. Rehbein is Commander of USACERL and Dr. L.R. Shaffer is Director.

CONTENTS

	Page
SF 298	1
FOREWORD	2
1 INTRODUCTION	5
Background	
Objective	
Approach	
Scope	
2 COAL CONVERSION FEASIBILITY STUDY	7
DOD Coal Use and the Potential Conversion Sites	
Review of Air Force Coal Conversion Work	
Screening and Cost Estimation Tools	
Final Selection of Four Installations	
Results of Detailed Feasibility Study	
3 CONCLUSIONS AND RECOMMENDATIONS	23
METRIC CONVERSION TABLE	23
REFERENCES	24
APPENDIX A: Tables	A1
APPENDIX B: Figures	B1
APPENDIX C: 1989 Installation Energy Consumption Report	C1
APPENDIX D: CHPECON Input	D1
APPENDIX E: CHPECON Screening Model Report	E1
APPENDIX F: CHPECON Costing Model Report (Long Form)	F1
APPENDIX G: CHPECON Costing Model Report (Short Form)	G1
DISTRIBUTION	

Accession For	
NTIS	<input checked="" type="checkbox"/>
CRA&I	<input type="checkbox"/>
DTIC	<input type="checkbox"/>
TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution /	
Availability Codes	
Dist	Avail and/or Special
A-1	

COAL CONVERSION AT PICATINNY ARSENAL AND FORTS CAMPBELL, BRAGG, AND GORDON: A FEASIBILITY STUDY

1 INTRODUCTION

Background

The fiscal year 1986 (FY86) Defense Appropriations Act (PL 99-190) Section 8110 directed the Department of Defense (DOD) to establish a program to increase the use of coal at facilities in the United States to a target of 1.6 million short tons per year,* over the 1985 coal consumption level, by 1994. The FY87 Appropriations Act (PL-500) Section 9099, continued this direction to implement the coal use program, and stipulated that such action should use the most life-cycle cost-effective fuel system. The language further stated that 300,000 tons of this amount should be anthracite coal. Subsequent Acts (FY88 PL 100, Section 8113, and FY89 PL 100-463, Section 8126) retained the direction toward the FY94 target for increased coal consumption, but added that the Department of Defense must comply with the life-cycle cost effectiveness criteria requirements of 10 USC 2690. House Report HR-101-345, accompanying the FY90 Defense Appropriations Act, stated that, "As a related issue, the conferees agree with Senate report language which directs the Department to continue, without modification, its efforts to increase domestic consumption of coal as outlined in the Department's letter signed by the Assistant Secretary of Defense for Acquisition and Logistics, dated August 30, 1985." To help the Army comply with these requirements, the U.S. Army Engineering and Housing Support Center (USAEHSC) requested that the U.S. Army Construction Engineering Research Laboratories (USACERL) provide technical studies and support for the Army's coal conversion program.

In general, coal is cheaper than gas or oil on a per-Btu basis, but coal-fired plants require considerably more capital and have higher operation and maintenance (O&M) costs due to coal/ash handling equipment and air pollution control devices not required with other fuels. A series of screening and life-cycle cost-estimating models have been developed to determine when and where specific coal combustion technologies could be implemented. Those specific plants that can be cost-effectively converted to coal (most likely the larger heat plants) must be identified. The first step in identifying and ranking potential sites for coal conversion is to collect information from installation heating plants and to conduct computer analyses with screening and costing models.

Objective

The objective of this study was to determine the technical feasibility and cost-effectiveness of converting selected central heat plants to coal-firing capability at four Army installations.

Approach

A literature search was done to locate other coal conversion studies, and an Air Force coal conversion study was reviewed. Criteria for selecting four installations for a detailed study were

* A metric conversion table is included on p 23.

formulated, and Army installations were evaluated and scored accordingly. Based on the scores obtained from the evaluation, final selections were made. The selected installations were visited, and detailed plant data was collected. Plants were evaluated for possible coal conversion using the CHPECON and Status Quo software programs. The results of the evaluations were compiled and recommendations were made.

Scope

This work investigated the feasibility of coal conversion for four selected Army installations at a given point in time. Specific conclusions, recommendations, and cost estimates were based on assumptions (e.g., future base energy requirements, fuel price, and price escalation factors) that will likely change with time and advances in technology. However, the methodology and procedures used in this study can be extended to other federal facilities for similar studies.

2 COAL CONVERSION FEASIBILITY STUDY

DOD Coal Use and the Potential Conversion Sites

Table 1* lists the total DOD coal consumption during the past 7 years, including coal consumption in the Army, Air Force and Navy. To meet the Congressional directive, the DOD has to more than double its coal usage. The increase in coal use at the DOD, however, has not been significant since 1985. In 1991, the DOD consumed 3.4 percent more coal than it did in 1985. The Army consumed the largest amount of coal of the three services with about a 9 percent increase in coal consumption in 1991—the majority of which was used in facilities at the Army Materiel Command. However, the Navy's consumption increased only 3.2 percent, while Air Force consumption actually fell by 3.7 percent.

A survey conducted at the DOD identified the potential coal conversion sites. Table 2 lists the name and the potential increase in coal use for each sites (Salthouse 1987). The listing shows the Navy to have the highest potential for increased domestic coal consumption.

Review of Air Force Coal Conversion Work

The Air Force had contracted Oak Ridge National Laboratory (ORNL) for a coal conversion study.** The results indicated that coal firing was not economical for smaller industrial and commercial heating plants or plants with low load factors. A minimum value for annual fuel use was identified as a cut-off point (260 BBtu/year or 30 MBtu/hr average). Any plant using less fuel was dropped from consideration in the study. Heating plants known to have no boilers larger than 10 MBtu/hr were also eliminated. Only gas/oil-fired heating plants with an aggregate boiler capacity of 50 MBtu/hr or greater were considered. Twenty seven plants were found in 24 Air Force bases that met the capacity and fuel usage criteria. (The ORNL study listed only 18 coal burning plants in the Air Force.) There were three types of possible projects:

1. Those that use coal firing to meet base steam load, and gas/oil during high demand period
2. Those that use coal firing for all steam generation, but include a gas/oil backup burner
3. Those that cogenerate electricity and steam.

The first ORNL study (Wilkinson 1989) focused on category 1, using a commercial software package (Framework II)*** to develop a costing program that used algorithms based on recent cost studies, vendor information, and applicable reported costs of actual coal utilization projects. The program assumed conversion or replacement of one to three existing boilers with the same capacities. Sulphur dioxide (SO₂) and nitrogen oxide (NO_x) emission regulation standards are assumed to be met by using low sulfur coal with good combustion control. A baghouse was assumed for particulate control. Economic evaluations were performed for the 27 heating plants and the results were presented. Micronized coal firing was found to be the most economic system. The ORNL report cautioned that more in-depth study would be needed to confirm this technology as the current best choice. The break-even gas/oil prices for all the plants ranged between 2.63 and 5.69 \$/MBtu. Ten heating plants showed cost savings (from 14.4 percent to 0.6 percent) using micronized coal technology.

* All tables are included in Appendix A to this report; all figures are included in Appendix B.

** The ORNL study produced four reports, cited fully in the reference section of this report (p 24): Griffin, et al. 1989; Holcomb and Griffin 1990; Thomas and Young 1989; and Wilkinson 1989.

*** Framework II is a registered trademark of Ashton Tate, 20101-T Hamilton, Torrance, CA 90413, tel. 213/292-1374.

This coincides with other Air Force studies that found these plants to be among the 12 sites recommended for further study, even before ORI/Guernsey performed the economic analysis (ORI, Inc. and C.H. Guernsey 1988). ORI/Guernsey selected seven Air Force Bases for detailed coal conversion study: Elmendorf, the U.S. Air Force Academy, Hill, Kelly, Robins, Arnold, and Plattsburgh. All seven of these AFBs were sites of heating plants selected by ORNL. The ORNL study concluded that conversion of 18 heating plants to coal would be required to meet Air Force's target of 600,000 tons additional annual coal consumption. This study also concluded that, to be cost effective, larger cogeneration projects must be considered.

A recent ORNL study (Holcomb and Griffin 1990) used approaches adopted by USACERL, and followed the life-cycle costing method and evaluation procedures set forth in the Federal Energy Management Program Rules. Both coal refit technologies and replacement boilers were considered. The study considered the following refit technologies: micronized coal-firing units; slagging pulverized coal burners; modular fluidized bed combustor (FBC) add-on units; stoker firing units; coal/water slurry, and coal/oil slurry units; and low-Btu gasifiers. Replacement boilers include packaged shell stokers, packaged shell FBCs, field-erected stokers, field-erected FBCs, pulverized coal boilers, and circulating FBCs. Results showed that, with micronized coal technology, it was economical to refit 15 heating plants at 15 Air Force bases. The benefit/cost ratio (the life-cycle cost [LCC] for continued gas/oil firing to the LCC for the coal utilization project) ranged between 1.262 and 1.039. After careful examination, 16 plants at 16 bases (Elmendorf, AK; Tinker, OK; Hill, UT; Robins, GA; Plattsburgh, NY; McGuire, NJ; USAF Academy, CO; Hanscom, MA; Arnold, TN; Grand Forks, ND; Andrews, MD; Kelly, TX; Minot, ND; Scott, IL; Dover, DE; and Pease, NH) were selected for possible coal conversion. If the coal projects were implemented in the 16 selected sites, an additional 334,800 tons/year coal consumption in Air Force would be achieved. The ORNL study concluded that cogeneration, plant expansion, and other types of projects must be explored as ways to expand coal use.

In October 1990, ORNL published cogeneration economic analysis results for seven Air Force bases (Hill, McGuire, Plattsburgh, Kelly, Griffiss, Grissom, and Wright-Patterson). The report recommended that feasibility studies of coal-fired cogeneration plants should be initiated for the three leading candidate bases: Hill, McGuire, and Plattsburgh. The benefit/cost ratios ranged between 1.25 and 2.82 based on the 10 percent Air Force financing method. It would consume additional 340,000 tons of coal per year.

ORNL recently assessed energy plant options for McGuire Air Force Base. Four options were considered: (1) to renovate the existing gas-fired boiler, (2) to build a new baseload (50 MBtu/hr) coal-fired heating boiler, (3) to build a coal-fired cogeneration steam plant (2x10 MWe*), and (4) to build a gas turbine cogeneration plant (3x6 MWe). Results indicated that a coal-fired heating boiler was economical, but a coal-fired cogeneration plant was not. A gas turbine cogeneration plant showed a small economic benefit (benefit/cost ratio about 1.08). A similar assessment at Andrews Air Force base showed that use of a new coal-fired heating boiler would be economical (benefit/cost ratio 1.45). Renovation and conversion to gas showed a small benefit (benefit/cost ratio 1.07). Neither a coal-fired cogeneration plant nor a gas turbine cogeneration plant were economical.

Other results from the several reports on the ORNL study were somewhat internally inconsistent, and more examination will be required to resolve the discrepancies between the several reports generated from the study. For example, one study on micronized coal retrofit (Thomas and Young 1989) assumed an unrealistically low price for a high quality fuel (1.5 \$/MBtu for coal with 0.1 percent ash and 0.25 percent sulfur).

* MWe = MegaWatts of electrical generating capacity.

ORI Inc./C.H. Guernsey and Co. also conducted a study (1988) for the Air Force to evaluate the potential for applying conventional coal technology at 34 Air Force Bases. The study considered conversion or reconversion of existing boilers capable of burning coal, and the replacement or addition of new coal-fired boilers. The study also analyzed the 34 bases and identified candidates ranked by their potential for development of coal-fired facilities. An economic evaluation model was developed and applied to the candidate bases.

Each base considered was evaluated for its potential to develop four alternative types of coal-fired central heating plants, by: (1) reconverting to coal, (2) adding a coal boiler, (3) constructing a new coal boiler at a new site on-base, or (4) constructing a new coal boiler at a new site off-base. Also considered was the potential to develop three alternative coal-fired cogeneration plants: (1) a cogeneration unit at existing CHP, (2) a cogeneration unit at a new site on-base, and (3) a cogeneration unit at a new site off-base. A matrix was developed to screen the bases using the following categories: (1) coal availability, (2) coal-firing suitability, (3) cogeneration potential, and (4) environmental acceptability. The total possible points for each category was 100.

Points were assigned in the evaluation matrix as follows:

A. Coal availability to base:

1. Rail - Long Haul (20 points)
2. Rail - Short Haul (40 points)
3. Truck (40 points)

B. Coal capability of existing heating plant:

1. Boilers suitable for coal (Yes/No)
2. Plant expansion space (20 points)
3. Site for coal storage (20 points)
4. Site for cooling tower (10 points)
5. Rail access (10 points)
6. Truck access (10 points)
7. Coal-handling equipment (10 points)
8. Coal preparation equipment (10 points)
9. Ash-handling equipment (10-points)
10. Ash disposal (10 points)
11. Existing coal capability vs. load (10 points)
12. Water supply (10 points)
13. Access to central heating system (30 points)
14. Steam/hot water load characteristics (10 points)
15. Access to electric utility (10 points)

C. Cogeneration potential:

1. Electric utility acceptance (50 points)
2. Facility electric load (50 points)

D. Environmental

1. Air field operations (10 points)
2. EPA air quality compliance (30 points)
3. Wastewater discharge (20 points)
4. Noise (20 points)
5. Aesthetics (20 points)

Seven candidate bases were selected for economic analysis based on the matrix ranking: Elmendorf, USAF Academy, Hill, Kelly, Robins, Arnold, and Plattsburgh. Site visits were conducted and final matrix evaluations were made. Four of the candidate bases (Elmendorf, Robin, Arnold, and Plattsburgh) were ranked highly. The lowest total facility charges for conventional coal-fired installations at highly ranked candidate bases with 600,000 tons per year of coal consumption were:

<u>Base</u>	<u>Alternative</u>	<u>Coal Usage</u> (Tons/year)
Plattsburgh AFB	Co-gen, 17 MW	102,200
Elmendorf AFB	Co-gen, 22.5 MW	165,865
Arnold AFB	Co-gen, 75 MW	341,200
	Total	609,765

The ORNL and ORI/C.H. Guernsey study gave preliminary results only, and indicated that further engineering study may be warranted to confirm the economics.

Screening and Cost Estimation Tools

Army Installation Inventory Program

The first step to identify the potential Army sites for coal conversion is to collect the energy consumption data for each installation. The data can be obtained from the Defense Energy Information System (DEIS). This system was established to obtain energy consumption, inventory, and cost data from the services. The Department of the Army (DA) requires all Army installations to submit data to the Army DEIS Data Entry System (ADDS). Energy consumption is reported twice each month. The report is used at all levels of government for energy conservation evaluation and energy-related budgetary, procurement, and operational planning and decisionmaking. Appendix C lists the 1989 ADDS energy consumption report for the 226 Army installations in order of decreasing energy usage. Only installations located in the continental United States were considered for coal conversion. Table 3 lists 45 installations with average energy consumption of greater than 38 MBTU/hr in order of decreasing energy usage. For many installations, detailed heating plant data are not available. The initial focus of this study was to select four installations from the list for detailed feasibility studies.

Data on the selected installations was available through USACERL's Army Facility Energy Systems Inventory Program (INV) database, which was begun and has been updated since 1990. This inventory program is designed to hold energy and utility systems information for Army installations. This data can be used for reports about individual installations, to extract information about a large number of installations, or to supply data to other computer programs for further analysis. In the summer of 1990, a survey was distributed to installations in all the Army major commands (MACOMs) requesting detailed information about each installation, its heating plants, and its boilers. General information about each installation includes:

1. Building and land inventory
2. Climate and location information
3. Types of energy available, costs, and annual usage
4. Master planning information for the next 10 years
5. Information about emission standards.

The database resides on an IBM-compatible personal computer (PC). On starting the program, the user selects an installation from the list of 142. Through a series of pull-down menus and screens, the

user can view data on all aspects of the installation's energy systems. A report section enables the user to print out data on individual installations.

One important function of this database is to allow rapid access of energy and utility information for all the listed installations. The inventory programs have prewritten reports that enable the user to extract data by boiler manufacturer, size, fuel, age, and type of construction. The data itself is stored in dBase® format, a common personal computer database file format widely known and accessible via custom programs written by any programmer familiar with dBase software. Another important use of this data is to supply information for evaluating heating plant options.

CHPECON Program

The Central Heating Plant Economics Evaluation Program (CHPECON) is a USACERL-developed computer program that provides the ability to perform evaluations of the life cycle costs of heating plants with Plant Maximum Continuous Ratings (PMCR) between 50 and 600 MBtu/hr comprised of individual boilers ranging from 20 to 200 MBtu/hr. Heating plant fuel choice includes coal, gas, and/or oil.

The first step in performing an economic evaluation with CHPECON is to provide answers to the screening models. The screening model allows the user to determine the suitability of an installation for a boiler plant of a particular technology. The evaluation can be performed for one of the following configurations:

- new plant
- new plant with cogeneration (of electricity)
- new plant with third party (outside ownership) cogeneration
- new plant with consolidation of existing plants
- retrofit of a heavy oil plant with a different technology.

The screening model data requirements include choice of military installation being studied, average monthly heating load, boiler technology, and fuel type. The boiler technology choices include:

- dump grate spreader stoker with or without fly ash reinjection
- vibrating grate spreader stoker with or without fly ash reinjection
- reciprocating grate spreader stoker with or without fly ash reinjection
- travelling grate spreader stoker with or without fly ash reinjection
- travelling grate stoker
- chain grate stoker
- coal-oil slurry
- coal-water slurry
- bubbling bed
- circulating bed
- gas/oil fired boilers.

The screening model also includes general questions about the plant, used to calculate a feasibility score that reflects the probability that the proposed plant can be constructed and operated economically. Appendix D lists the information needed to run the CHPECON program using the screening and costing models. Appendix E contains an example screening model report.

The second step in completing an economic evaluation of a facility is to run the cost model option of CHPECON. The cost model calculates costs for a plant using the screening model data. Cost model inputs include fuel prices, the fiscal year of evaluation, current escalation and discount rates, and the

expected life of the plant. The cost model calculates the cost of boiler fuel including transportation, auxiliary energy, operation and maintenance, and repair and replacement over the life of the plant. The cost model report includes itemized plant component costs, capital investment costs, year-by-year operating costs, total life cycle costs, and levelized plant costs (in \$/MBtu and \$/1000 lb steam). Appendix F contains an example long-form cost model report. Appendix G contains the shorter cost model report that summarizes the plant costs from the long form.

CHPECON offers two special options to expedite the analysis of plant options, the multiple run analysis, and the sensitivity analysis. Multiple run analysis allows the user to run combined screening/costing models for all the appropriate coal-fired technologies, and provides a list of life-cycle costs for all the technologies in order of increasing cost. Sensitivity analysis automatically varies eleven parameters to show their effects on the plant costs. The eleven parameters are: (1) primary fuel initial cost, (2) primary fuel escalation rate, (3) auxiliary energy cost, (4) O&M labor cost, (5) O&M non-labor cost, (6) repair/replacement cost, (7) initial investment cost, (8) existing salvage value, (9) new salvage value, (10) discount rate, and (11) plant life.

CHPECON uses seven databases: (1) coal field information, (2) acceptable coal properties (for combustion technology options), (3) military installation information, (4) boiler stack emission regulations, (5) equipment emission factors, (6) construction productivity and wage data, and (7) operations labor staffing and wage data. These databases can be updated from within the CHPECON program by choosing the "update databases" option. The system utilities option allows the user to set screen colors, set printer margins, reindex files, rebuild a case list from present files, read in new LCCID (Life Cycle Cost in Design) cost information, or set the values for sensitivity analysis.*

Both the inventory program and the CHPECON program are currently being modified so that CHPECON can extract data directly from the inventory program. This will enable analysis of future energy supply alternatives according to the most up-to-date data available.

CHPECON Costing Validation

Boiler cost data was compiled from the CHPECON program, the equations in the CHPECON manual, and from *Population and Characteristics of Industrial/Commercial Boilers in the U.S.* (USEPA 1979). Table 4 presents boiler cost data and Table 5 presents CHPECON cost validation data.

The boiler costs reported by the EPA in 1979 were escalated from 1979 dollars to 1991 dollars by using economic indicators from *Chemical Engineering* and *Engineering News Record*. In Table 4, the plant cost indexes for 1979 and the third quarter of 1991 were used to calculate a multiplier of (360.9/238.7) to escalate the cost of capital and fixed costs in Table 5 from 1979 dollars to 1991 dollars. The multiplier used to escalate O&M costs in Table 5 was (4538.8/2661.5). The multipliers should provide an accuracy of ± 25 percent.

Individual boiler costs for various technologies and fuels from the USEPA study (1979) and CHPECON equations are compared in Table 4. Table 6 lists the items included in the boiler costs shown in Table 4. The values calculated with the CHPECON equations are reasonably accurate, though the CHPECON estimates rely on the plant maximum continuous rating (PMCR) and do not account for differences in fuel quality (which may create a need for additional equipment and pollution control).

* For more information on the Life Cycle Cost in Design program, see Linda K. Lawrie, *Development and Use of the Life Cycle Cost in Design Computer Program*, TR E-85/07/ADA162522 (U.S. Army Construction Engineering Research Laboratory [USACERL], November 1985).

The cost per MBtu was calculated from the USEPA data and compared to the cost per MBtu for a system with three or four boilers of comparable size given by the CHPECON program in Table 5. The costs per MBtu (calculated by the USEPA and CHPECON were close in the cases with gas/oil boilers, but for coal-fired boilers the value calculated from the USEPA data was much smaller than the CHPECON estimate. The discrepancy in the cost per MBtu found in the coal-fired boiler cases may be attributed to the overestimation of the cost of some subsystems (such as coal and ash handling) by CHPECON and the omission of the cost of the boiler house and air pollution control equipment and supplies in the USEPA data. Due to the frequently changing nature of market place and technologies, constant updating of costs is desirable.

Status Quo Evaluation

Before building a new plant or renovating an old plant, a status quo evaluation is needed to provide a baseline for justification of change. USACERL has developed the Status Quo evaluation program, designed to run on an IBM PC or compatible computer, which allows users to input plant data to calculate the status quo plant life cycle cost (Savoie 1992). The Status Quo database maintains an inventory of the individual parts in a central heating plant along with their installation years, costs (in a specified year), and lifespan. It also keeps a record of the typical annual costs for operating and maintenance. This data is used to calculate the projected cost of operating the central heating plant (CHP) in future years.

The Status Quo program begins with a main menu that allows the user to enter data about a particular installation, to maintain files containing default costs and life expectancy of parts, to browse the raw datafiles, and to run prepared reports.

Menus always feature a choice of possible actions. The user will need to enter data for each plant. This is done from a hand-written inventory of approximately 100 items, which comprise the components of a boiler plant, such as boilers, relief valves, and expansion tanks. The written list contains the basic specifications for each item, its installation year, and an estimate of general condition. This is entered into the computer using the "Add Data" option. Default data is supplied by USACERL with the program, including the cost and life expectancy of the component parts of the boiler plant. These items may be modified as new data becomes available.

SQLCCID Reports

The SQLCCID program is intended to help the user determine the life cycle cost of an existing central heating plant operating under status quo conditions. It runs LCCID to determine these costs based on input entered through prompt screens, and data contained in the Status Quo database.

The new plant costs calculated by CHPECON for Building 650 at Fort Campbell were compared to costs calculated by the Status Quo program. Table 7 lists the results of this comparison. To create a fair comparison, it is necessary to revise the status quo evaluation by equalizing the labor, energy, insurance, and other costs so that new plant costs are not penalized. For example, the new plant option required an operating staff of 11, while the status quo option only requires an operating staff of 7. In reality, new plants should need fewer operators due to increased automation. The revised 25-year life-cycle costs show that maintaining the status quo costs about \$3 million less than building a new plant firing the same gas fuel.

Installation Selection Criteria and Ranking Scores

To help choose the installations for a detailed study, criteria were selected and used to compare installations. A point was assigned to each installation for each met criterion according to information

collected in the inventory surveys. Table 8 shows the criteria and the points assigned. The points were summed to determine the composite score for each installation, and the installations with high scores were considered for final selection.

The installations being considered for the coal conversion study and the relevant information are shown in Table 9. The actual points and composite scores for the installations are shown in Table 10. These scores were taken into consideration when selecting the four installations for detailed coal conversion studies.

Final Selection of Four Installations

Four installations were chosen for detailed study: Fort Campbell, Fort Bragg, Fort Gordon, and Fort Carson. Factors taken into consideration are ranking scores, installation service function (FORSCOM, TRADOC, AMC, and others), geographic location (DOE regions), recent installation fuel contracts, etc. Site visits were made for the first three installations. Due to an unexpected strong objection by the Deputy Directorate of Engineering and Housing (DEH) at Fort Carson just before the scheduled visit, the trip to Fort Carson was cancelled. Since a lot of information was available on Picatinny Arsenal from previous USACERL's work, and also to include an AMC installation, Picatinny was chosen to replace Fort Carson. The following section gives the results of detailed coal conversion study.

Results of Detailed Feasibility Study

Fort Campbell

Fort Campbell is located in southwestern Kentucky in Trigg and Christian Counties and in north-central Tennessee in Stewart and Montgomery counties. The installation falls within the Clarksville-Hopkinsville Standard Metropolitan Statistical Area, (SMSA) and contains 105,347 acres. The cantonment area is located adjacent to U.S. Highway 41-A about 8 mi. north of Clarksville, TN and 17 mi. south of Hopkinsville, KY. Summers are characteristically hot and humid with mean high temperatures of 89 °F and low temperatures of 68 °F. Winters are characterized by damp, mild conditions with a mean high of 45 °F and an average minimum of 28 °F. The annual precipitation is approximately 47 in.

The major occupant of Fort Campbell is the 101st Airborne Division. Other tenant units at Fort Campbell include the U.S. Army Medical Department Activity, U.S. Army Communications Command Agency, Defense Property Disposal Office, Military Intelligence Group, and the U.S. Army Criminal Investigation Command. In addition, Campbell Army Airfield is the home of several U.S. Air Force tenant units.

The main cantonment is located on the east end of the installation on the Kentucky-Tennessee state line. The cantonment area has administration, community support, troop housing, and family housing areas. Campbell Army Airfield is located at the northeast corner of the installation. The remainder of the installation is used for training, ranges, drop zones, and landing zones. The facilities range from WWII temporary construction to recent permanent construction. The facilities serve a military population of about 22,000. In addition there are about 10,000 civilian dependents in family housing and about 5000 civilian employees at the installation. The total effective population is estimated to be about 34,000 persons. The Master Plan did not mention any major environmental problems or endangered species at Fort Campbell. However, there are minor problems with erosion caused by training activities, and with solid waste disposal areas.

The utilities at this time are well suited to serve the installation population. Fort Campbell has its own water system, which obtains good quality water from an underground artesian aquifer. The average daily consumption is between 5 and 6 million gallons per day (MGD) with peaks sometimes as high as 8 MGD. The water treatment plant has a capacity of about 9 MGD. The water storage capacity is 2.75 million gallons. The main water feeder lines are 8 to 20 in. in diameter. The sewerage system is provided by an extensive system that feeds a trickling filter treatment plant. The treatment plant effluent is discharged to Little West Fork Creek. There is apparently an infiltration problem with the collection system. The majority of the storm runoff from the cantonment area of Fort Campbell and the airfield is drained by storm sewers and open ditches into eight major drainage basins, which discharge into natural creeks. The drainage basins may limit development in some areas of the installation. In the training and range areas, the storm drainage is natural. Electrical power is supplied to Fort Campbell, except for the Lee Village housing area, by the Tennessee Valley Authority (TVA) at 67,000 volts to a main substation with a 80,000 KVA rating. The Lee Village housing area is served by the Pennyryle Rural Electric Cooperative. 12,500 volt overhead distribution lines serve the cantonment area and some ranges. Electrical loads are about 40 to 50 percent of existing capacity. The Clarksville Gas and Water Department supplies Fort Campbell with natural gas through a 10-in. high pressure line.

Fort Campbell has 5 central heating plants and 28 smaller plants. The five central heating plants are dual fueled (natural gas and fuel oil). The smaller plants operate on natural gas only. There is limited use of electricity and LP gas for heating. The thermal distribution system is mainly buried pipe. Solid waste is disposed in a sanitary landfill with an estimated life of 5 or more years.

Based on the collected information, heating plant conversion options were evaluated by running the CHPECON and the Status Quo programs. Status Quo results for the heating plants in Buildings 650, 3902, 7008, 7223, and 858 are shown in Tables 14b to 17b.

Table 11 listed the boiler fuel, capacity, year installed, and present condition (higher rating number means better condition) for each boiler in all six buildings. The heating plant in building 157 is being demolished, and therefore, no evaluation was made. Energy use data for the other five heating plants are shown in Table 12. Note that the boilers in building 7223 only operated in winter time. Annual costs for utilities, service, and supplies were estimated based on results obtained from boiler plant evaluation in Picatinny Arsenal with appropriate sizing factors. Labor costs were calculated based on total number of plant operating staff and the average pay for the designated grade levels. The total operating expense (per thousand pounds of steam) is also listed for each plant. The estimated average is 7.67 \$/thousand pounds of steam, which is about 5 percent higher than the value reported by the installation (7.25 \$/thousand pounds of steam). The boiler plant parts list and the results of life cycle cost analysis are presented in Tables 13a through 17a.

Results obtained from CHPECON runs on new plant option using gas, oil, or coal are shown in Tables 18 and 19 for the plants in buildings 7008 and 3902 respectively. The PMCR was set to be equal to the existing plant maximum capacity, and the fuel usage rate was set to be equal to one third of the PMCR. Only plants with capacity greater than 50 MBtu/hr can be evaluated by CHPECON program, and thus plants in building 650, 7223, and 858 were not included. The LCC ratios relative to gas fuel (set at 100) are listed in the last column of Tables 18 and 19. The tables show gas to be the least-cost plant fuel, followed by #2 oil, #6 oil, and coal. For the plant in building 7008, in terms of the LCC, a new coal-fired stoker is most costly (2.3 times of the cost of a gas-fired plant) followed by a fluidized bed combustor (FBC), a coal oil mixture (COM) fired plant, and a coal water slurries (CWS) fired plant. For the larger size plant in building 3902, a new FBC is most costly (1.92 times of the cost of a gas-fired plant), followed by stoker plant, COM plant, and CWS plant. A detailed cost sensitivity analysis for a gas/#2 oil-fired boiler plant with capacity sufficient to meet the steam demand for the whole installation is shown in Table 20. The fuel price and electricity cost are set according to the DOE region price. The parameters

used for sensitivity analysis include primary fuel initial cost, fuel price escalation rate, auxiliary energy cost, O&M labor cost, O&M nonlabor cost, repair/replacement cost, initial cost, salvage value, discount rate and plant life. Their effects on the plant LCC are plotted in Figures 1 through 6 in terms of percent change in the LCC versus percent change in parameter value. These sensitivity plots show that fuel price and its escalation rate, discount rate, and plant life have the most significant effect on the plant LCC.

The cost sensitivity analysis for a #6 oil-fired boiler plant and a coal-fired stoker plant are shown in Tables 21 and 22 respectively. The sensitivity plots are presented in Figures 7 through 18. For a coal-fired plant, the effect of fuel price change has less impact on the plant LCC while the effect of initial cost becomes important. The levelized costs of service expressed in terms of \$/thousand pounds of steam, versus fuel price for gas, #6 oil, and coal are shown in Figure 19. The costs at different fuel prices are calculated from the results obtained in sensitivity analysis. For Fort Campbell, a DOE region #2 coal with a price of 1.53 \$/MBtu was selected, and from Figure 19, the breakeven gas price is found to be 5.2 \$/MBtu, and the breakeven #6 oil price is 5.8 \$/MBtu. This means that if the coal price remains at 1.53 \$/MBtu, and the gas/oil price goes above the breakeven value, then conversion to coal would make economic sense. However, for this to happen, it would be necessary to double the current gas/oil price for this region, which may require a relatively long period of time to achieve. But due to the highly volatile and unpredictable nature of fuel pricing, frequent examination of switching opportunity may be warranted. As long as the installation steam demand remains at the present level, the analysis indicates that continued use of gas as plant fuel is the best choice for Fort Campbell.

Fort Bragg

Fort Bragg is located in south central North Carolina just northwest of Fayetteville, NC. Pope Air Force Base is located adjacent and north of the main cantonment area. Camp Mackall, a subinstallation of Fort Bragg is located about 40 mi. to the west. Simmons Army Air Field is just to the east of the main cantonment. The area to the southwest is urban, and the remainder of the surrounding area is largely rural. Fort Bragg occupies an area of about 137,000 acres in Hoke, Cumberland, Scotland, and Richmond counties. With the exception of the cantonment area and scattered open areas, most of the installation is wooded. Fort Bragg has a humid subtropical climate with long hot summers and mild winters. The average mean daily ranges from 43 °F in January to 80 °F in July. Rainfall at Fort Bragg is well distributed and averages 4.7 in. per month. Snow and sleet normally fall only once or twice a winter.

The major occupants of Fort Bragg are the XVIII Airborne Corps, the 82nd Airborne Division, and the Special Operations Command. Other major tenants include the 35th Signal Brigade, the 20th engineer brigade, the First Corps Support Command, the 16th Military Police Brigade, the Dragon Brigade, and the 525th Military Intelligence Brigade. There are also community support facilities and Directorate of Logistics facilities.

The main cantonment is located on the east end of the installation near Fayetteville, NC. The cantonment area has administration, community support, troop housing, and family housing. The remainder of the installation is used for training, ranges, drop zones, and landing zones. The Camp Mackell area is used mainly for training. Pope Air Base is located to the north of the main cantonment and Simmons Army Air Field to the east. The facilities range from WWII temporary construction to recent permanent construction. The facilities serve an average population of about 64,000 with nearly 3300 buildings that total over 20 million sq ft. Historical areas at Fort Bragg include two areas that were battle sites in the Revolutionary War, and several Civil War battle sites. The installation has several endangered species, the most important of which is the red-cockaded woodpecker. Protection of the endangered species has a significant effect on future development and present use of the installation.

The 1986 Master Plan for Fort Bragg does not review the utilities, except to state that there were no problems. The potable water supply for Fort Bragg is drawn from the Little River. There is also a connection to the Fayetteville City water system. The main cantonment water treatment plant has a capacity of 10 MGD. The sewage treatment system has a capacity of 8 MGD.

Following the same procedures used for the Fort Campbell study, heating plant information is presented in Table 23 for the plants in building 4-3124, C-1432, C-7549, D-3529, E-2823, and N-6002. The first three plants produce steam while the last three produce high temperature hot water. Table 24 lists the energy use data. The plant in building C-7549 is not in use and the plant in 4-3124 is being closed; therefore, they are not evaluated. For Fort Bragg, the estimated average production cost is \$8.20/MBtu, about 27 percent higher than that at Fort Campbell (\$6.44/MBtu), and mainly due to higher gas/oil prices paid at Fort Bragg. The boiler plant parts list and the results of a life-cycle cost analysis are presented in Tables 30 through 37 for the plants in building C-1432, D-3529, E-2823, and N-6002.

Results from CHPECON runs are shown in Tables 29, 30, and 31 for the plants in building C-1432, D-3529, and N-6002. The plant capacity at building E-2823 is less than 50 MBtu/hr and thus was not evaluated.

Table 29 shows that, for the plant in building C-1432, a new coal-fired FBC has the least LCC, followed by stoker, gas, CWS, #2 oil, COM, and #6 oil. The gas and oil prices used were supplied by the base. However, note that, after Operation Desert Storm, oil prices have substantially declined. In general, large plant capacity in addition to high gas/oil prices would favor coal conversion. In this case, an average monthly steam load of 100 MBtu/hr is required to make the coal conversion worthwhile. Retrofitting the boilers for coal-stoker, CWS, or micronized coal firing can potentially result in LCC savings range between approximately \$170,000,000 and \$240,000,000 (Table 29). A more detailed engineering analysis is needed to confirm the savings since some existing equipment may need to be replaced or repaired. The CHPECON retrofit model is being enhanced to account for the fact that the estimated values from the current models tend to give higher savings due to the optimistic assumptions made in using the existing equipment.

Table 39 gives the results for the plant in building D-3529. Because the PMCR is considerably less (130,000 lb/hr), coal is no longer the cheapest fuel. Gas is the least expensive fuel followed by CWS, FBC, Stoker, #2 oil, #6 oil, and COM. For the smallest plant in building N-6002 (Table 31), gas remains the least-cost fuel, followed by #2 oil, #6 oil, and coal. As plant load decreases, coal use becomes uneconomical due to high capital investment required for coal plants. Tables 32 and 33 show the results for plants in building 4-3124 and C-7549. Gas is the most inexpensive fuel for the two plants.

Table 34 gives a detailed cost sensitivity analysis for a gas/#2 oil-fired boiler plant with enough capacity to meet the heating demand of the whole installation. The DOE region price is used for costing. The effects of the 11 parameters on the plant LCC are plotted in Figures 20 through 25. Similar to the Fort Campbell plots, fuel price and its escalation rate, discount rate, and plant life are all significant parameters.

Tables 35 and 36 give the cost sensitivity analysis for a #6 oil-fired boiler plant and a coal-fired stoker plant. The sensitivity plots are shown in Figures 26 through 31 for #6 oil plant, and in Figures 32 through 37 for coal plant. Figure 38 shows the levelized costs of service versus fuel price for gas, #6 oil, and coal. At Fort Bragg, the DOE region coal price is \$1.72/MBtu. From Figure 38, the breakeven gas and #6 oil prices would be \$3.7/MBtu and \$4.1/MBtu respectively. The breakeven prices are about 37 to 57 percent higher than the current DOE region prices. This indicates that coal could become cost competitive when gas or oil price increased by 37 or 57 percent while coal price remained the same. The likelihood that this would occur certainly would be higher than the Fort Campbell case, in which a 100

percent gas/oil price increase would have been necessary for coal to become cost effective. Plant size is the major economic driving force in switching to coal since the Fort Bragg plant is twice the size of the Fort Campbell plant (379,000 lb/hr versus 188,000 lb/hr). Note that, at Fort Bragg, the gas billing rates are \$4.50/MBtu for interruptable gas and \$3.92/MBtu for uninterruptable gas. The FY92 #6 oil price paid by DOD facilities is \$4.41/MBtu. Therefore, based on present gas/oil price paid by Fort Bragg and the DOE region coal price, coal would be the least cost fuel when a new plant producing 379,000 lb/hr steam is to be built. However, maintaining the status quo remains cheaper than building new plants. Note that a study conducted by JRB Associates in 1982 showed that the 25-year LCC (in 1982 dollars) with the status quo was \$148,787,900 while the LCC for a new boiler plant with three coal stokers was \$131,078,000. The status quo evaluation done in this study (in 1992 dollars) resulted in a \$155,927,643 life-cycle cost, or about 5 percent higher than the value provided by JRB Associates. The LCC for new gas plants by CHPECON runs amounts to \$202,079,538, which is 30 percent higher than the status quo estimation. Based on these results, switching to coal is not recommended unless a new plant, large enough to meet the whole installation demand, is to be built. Another important issue is that complications and additional costs may be incurred in dealing with the endangered species issue (the red-cockaded woodpecker). This could significantly affect plant location and thermal distribution system design and installation.

Fort Gordon

Fort Gordon is located in the Central Savannah River Area (CSRA) of east-central Georgia, 9 mi. southwest of Augusta. The installation occupies portions of four counties (Jefferson, Richmond, Columbia, and McDuffie) with a total area of approximately 55,600 acres. The majority of the installation and the entire cantonment area lies within Richmond County, while the training areas are spread over all four counties. The climate consists of mainly warm, humid summers, and short, mild winters. The maximum recorded temperature was 109 °F. The average temperature in the winter is 50 °F. The average annual precipitation is in excess of 44 in., well distributed throughout the year. Snowfall is light and seldom remains on the ground.

The CSRA has a diverse economy based on education, defense, medical, and textile industries. The Augusta Metropolitan Statistical Area has an estimated population of about 400,000. The major occupant of Fort Gordon is the United States Army Signal Center and Headquarters of the Signal Corps. The mission of the U.S. Army Signal Center is to train military communicators in the installation, operation, and maintenance of communications-electronics equipment. The Signal Center is also responsible for development of Signal Doctrine and the corresponding organization, material, and test and evaluation requirements. A major tenant, the Dwight David Eisenhower Army Medical Center (DDEAMC) serves as the Regional Director for the Health Services Command.

The main cantonment is located on the east end of the installation. There are four main portions of the cantonment: (1) the Signal School and troop housing in the center, (2) family housing and community support areas to the southeast, (3) the DDEAMC to the northeast, and (4) the installation support areas in the west of the main cantonment. There are ranges and training areas in the center and west portions of the installation. The facilities range from WWII temporary construction to recent permanent construction. The facilities serve a military population of about 13,500 and a civilian population of about 6000. The total effective population is estimated to be about 16,000. There are no environmental considerations of major concern in the main cantonment area. There are minor problems with air quality, noise abatement, construction pollution, and wind and water erosion. Solid waste disposal may create future problems. Some of the environmental problems may change if the installation mission changes.

The utilities at this time are well suited to serve the installation population. Fort Gordon has its own water system supplied from Butler Reservoir. The water system consists of the water treatment plant with a 5.25 MGD capacity, storage facilities, and distribution and service lines. There is a problem with sludge handling from the water treatment plant. The wastewater system consists of the collection system and the wastewater treatment plant and is adequate for existing peak demands. The storm drainage system consists of pipes, and paved and channeled natural drainage ditches. The systems operate adequately for existing runoff. Electrical power is supplied to the Fort Gordon main substation by Georgia Power Company at 115 KV. Power is distributed to the installation by 12.47 KV transmission lines. There is a fuel-fired emergency motor generator to supply power to the DDEAMC. Current peak demand is about 75 percent of the rated substation capacity. The main cantonment is served by four central energy plants. The plants are dual-fueled (natural gas and fuel oil). The distribution system consists of high-temperature hot water and chilled water pipes in underground direct buried conduits, or accessible shallow concrete trenches. Future expansion of the DDEAMC may require expansion of plant "C," but otherwise the system is adequate to handle existing and proposed demands. Solid waste is disposed in a landfill with an operational life expectancy of 7 years. The current landfill complies with all federal, state, and local regulations, and is permitted and inspected quarterly by the state of Georgia.

Fort Gordon heating plant information is presented in Table 37 for the plants in building 25330, 2202, 25910, and 310. The four plants produce saturated steam by firing natural gas. The energy use data are presented in Table 38. For Fort Gordon, the estimated average production cost is \$9.15/MBtu, about 42 percent higher than that at Fort Campbell (\$6.44/MBtu), or 12 percent higher than at Fort Bragg (\$8.20/MBtu). This is mainly due to higher gas price paid at Fort Gordon. The boiler plant parts list and the results of life-cycle cost analysis are presented in Tables 39 through 42 for the plants in building 25330, 25910, 2202, and 310.

Results from CHPECON runs are shown in Tables 43, 44, and 45 for the plants in building 25330, 25910, and 2202. The plant capacity at building 310 was less than 50 MBtu/hr and thus was not evaluated.

Table 43 shows that, for the plant in building 25330, a new #6-oil fired plant has the least LCC, followed by #2 oil, gas, COM, CWS, stoker, and FBC. The gas and #2 oil prices used are supplied by the installation; #6 oil is not used in this installation, the DOE region price is used in cost estimation. For a new plant in building 25910, again, burning #6 oil resulted in lowest LCC, followed by #2 oil, COM, CWS, Stoker, FBC and gas (Table 57). It is interesting to note that gas is the most expensive fuel for this case. The LCC estimation results shown in Table 45 for plant in building 2202 are similar to those obtained for building 25330 in terms of fuel option.

A detailed cost sensitivity analysis for a gas/#2 oil-fired boiler plant with enough capacity to meet the heating demand of the whole installation is shown in Table 46. DOE region price is used for costing. The effects of the 11 parameters on the plant LCC are plotted in Figures 39 through 44. Similar to that observed in the previous two installations' plots, fuel price and its escalation rate, discount rate and plant life are significant parameters.

The cost sensitivity analysis for a #6 oil-fired boiler plant and a coal-fired stoker plant are shown in Tables 47 and 48. The sensitivity plots are presented in Figures 45 through 50 for #6 oil plant, and Figures 51 through 56 for coal plant. The levelized costs of service versus fuel price for gas, #6 oil, and coal are presented in Figure 57. At Fort Gordon, the DOE region coal price is \$1.72/MBtu. From Figure 57, the breakeven gas and #6 oil prices would be \$7.2/MBtu and \$8.1/MBtu respectively. The breakeven price is about three times that of the current DOE region price. This indicates that coal could be cost competitive when gas or oil price tripled if coal price remains at the same level. This would be an unlikely occurrence—certainly less likely than the Fort Campbell case, where a 100 percent gas/oil price

increase is necessary for coal to be cost effective. Plant size is again the major economic driving force in switching to coal—the Fort Gordon plant is only about half the size of the Fort Campbell plant (100,000 lb/hr versus 188,000 lb/hr) and one quarter of that for Fort Bragg. When compared, the results from the Status Quo evaluation and the CHPECON new plant runs show that maintaining the status quo remains cheaper than building a new plant. With plant size of 100,000 lb/hr or less, coal did not appear to be an attractive fuel.

Picatinny Arsenal

The U.S. Army Armament Research, Development, and Engineering Center (ARDEC), Picatinny Arsenal, is located in the north central part of New Jersey in Morris County about 4 mi. northwest of the town of Dover in the highlands of New Jersey. The surrounding area is suburban. The annual average temperature is 51 °F, and the maximum recorded temperature is 100 °F. The minimum recorded temperature is -20 °F. The average annual rainfall is 49 in., and the average annual snowfall is 44 in. Periods of extended extreme cold are rare, and abnormally high temperatures seldom last longer than a few days. The land area ranges in elevation from just under 700 to 1240 ft above mean sea level. The Arsenal is situated in an elongated valley tending northwest-southeast between Green Pond Mountain and Copperas Mountain on the northwest and an unnamed hill on the southeast.

In general, the areas that surround the Arsenal are suburban and summer vacation areas are located in the area's many small lakes and mountains. There are several small towns in the immediate vicinity of the Arsenal. The arsenal is within 50 mi. of several major cities and close to major transportation centers. Picatinny Arsenal covers approximately 6500 acres.

The major occupant of Picatinny Arsenal is the U.S. Army Research, Development, and Engineering Center. In addition, the headquarters of the U.S. Army Armament, Munitions and Chemical Command (AMCCOM) is located at Picatinny Arsenal. ARDEC is a subcommand of AMCCOM. AMCCOM is responsible for the life-cycle management of total research, development, engineering, product assurance, integrated logistic support, industrial preparedness, procurement, production, and material readiness for assigned systems or specific weapon systems or items. ARDEC is concerned with research, development, tests, and engineering of assigned military items and systems.

Picatinny Arsenal has three functional land areas. The south portion is roughly defined as the land between State Route 15 and the south shore of Lake Picatinny. The south portion has the main entrances, family housing, administration, research and development, industrial and maintenance engineering, inspection, supply, transportation, inert storage, and inert burning activities in the valley portion. Pilot lot operations involving explosives are performed along the slopes of the easterly hills in this area. The central portion includes the area from Lake Picatinny to Lake Denmark. The central portion has maintenance shops, explosives research and development laboratories, industrial and maintenance engineering, the power plant and testing activities. The north end has testing, inspection, and explosive storage facilities. The Arsenal has 308 acres of lakes and reservoirs, 322 acres of swamps, and 3908 acres of woods. There are about 1037 buildings and structures covering over 4 million sq ft. There are seven historical sites at the installation. The Arsenal has about 5500 civilian employees and 150 military personnel plus an unknown number of dependents in the family housing areas.

The Master Plan mentions several constraints on future development at Picatinny Arsenal. The Arsenal has various research, development, and manufacturing processes that produce a wide range of toxic and hazardous wastes. There are many known and unknown chemicals stored or buried at known and unknown sites at the Arsenal. Munitions research and testing is a primary task of ARDEC. The storage and Explosive Storage Quality Distances (ESQD) have a major effect on future development. Noise pollution can be a problem because of explosive blast noise. Because Picatinny Arsenal is within

the Northeast New Jersey-New York-Connecticut Interstate Region, control of air pollution is of major importance. The main power plant (Bldg 506) and the explosive burning ground are the major sources of air pollutants at the Arsenal. In addition, the Fish and Wildlife Program, the Forestry Program, the Agronomy and Land Management Program, and the historical sites present constraints on development.

The utilities have some trouble spots in the electrical power system and the thermal distribution system. The water system is supplied by deep wells and from surface water reservoirs. The total water demand is 170 million gal per year. A nonpotable water supply via Picatinny Lake provides water for industrial use and fire protection purposes. The sewerage system includes a collection network and a treatment plant. The treatment plant will be abandoned in the future with the installation of a pump station and pipings to the Rockaway Valley Authority sewer line. There are some individual septic tank systems. Storm water drainage at the Arsenal is furnished by a combination of natural and developed collection systems. The terrain provide natural storm drainage for most of the Arsenal. The system is adequate for the presently developed areas. Electrical power is supplied by Jersey Central Power and Light Company at 34.5 KV. The distribution system at the Arsenal operates at 2400 V. There are plans to change the distribution system to a 12.5 KV system. The electrical power system is inadequate at this time. (It is subject to frequent "Brown Outs.") There are limited emergency generation capabilities. The thermal distribution system has been the subject of recent detailed study by USACERL. It consists of a central power plant and aboveground high pressure steam distribution lines. There are several auxiliary steam plants serving limited areas of the Arsenal. Solid waste is collected by a private sanitation firm and disposed off the installation.

The Picatinny Arsenal heating plant information is presented in Table 62 for the plants in building 506, 99, and 3013. The plant in building 506 is located on the south side of Lake Picatinny and has three boilers for the production of superheated steam and electricity. The first boiler is a Riley Stoker packaged 50,000 lb/hr oil-fired unit installed in 1971. The other two boilers are Combustion Engineering units, originally designed for pulverized coal, but now firing #6 oil. Both units are rated at 160,000 lb/hr, with boiler outlet condition of 430 psig and 700 °F superheated steam. There are two steam turbine generators rated at 3 MW and 3.5 MW respectively. Since April 1988, no electric power has been generated due to the loss of the last operating turbine-generator. All the process and heating steam has been supplied through pressure reducing valves from the boiler main header.

The energy use data for building 506 plant are shown in Table 63. For Picatinny Arsenal, the estimated average production cost is \$5.02/MBtu, which is the lowest among the four installations studied. This is mainly due to the low #6 oil price paid at Picatinny Arsenal (\$3.01/MBtu). The boiler plant parts list and the results of life cycle cost analysis are presented in Tables 64 and 65 for the plant in building 506.

Tables 66 and 67 show results of the CHPECON runs for the plants in building 506 and 3013 respectively. The plant capacity at building 99 is less than 50 MBtu/hr and thus was not evaluated.

Table 66 shows that, for a new plant in building 506, a #6 oil-fired plant has the least LCC, followed by gas, #2 oil, COM, stoker, CWS, and FBC. The gas and coal prices used are from the DOE region price list. An average monthly steam load of 123 MBtu/hr is still not sufficient to justify conversion to coal at Picatinny Arsenal. This is different from what was found for Fort Bragg, where conversion to coal became potentially feasible at 100 MBtu/hr average load. Retrofit the boilers for coal-stoker, CWS, or micronized coal firing can potentially result in LCC savings that range between approximately \$62,426,000 and \$80,841,000 (Table 66). (A more detailed engineering analysis will be needed to confirm these savings since some existing equipment may need to be replaced or repaired.)

The results for the plant in building 3013 are shown in Table 53. Because of the low PMCR (50,000 lb/hr), coal is a rather expensive plant fuel. In this case, #6 oil is the least-cost fuel, followed by gas, #2 oil, COM, CWS, FBC, and Stoker. The LCC for a coal-fired plant is about twice that for a gas- or oil-fired plant.

A detailed cost sensitivity analysis for a gas/#2 oil-fired boiler plant with enough capacity to meet the heating demand of the whole installation is shown in Table 54. DOE region price is used for costing. The effects of the 11 parameters on the plant LCC are plotted in Figures 58 through 63. As observed in previous sensitivity plots, fuel price and its escalation rate, discount rate, and plant life are significant parameters.

Tables 55 and 56 show the cost sensitivity analysis for a #6 oil-fired boiler plant and a coal-fired stoker plant. The sensitivity plots are presented in Figures 64 through 69 for a #6 oil plant, and Figures 70 through 75 for a coal plant. Figure 76 shows the levelized costs of service versus fuel price for gas, #6 oil, and coal. At Picatinny Arsenal, the DOE region coal price is \$1.75/MBtu, and from Figure 76, the breakeven gas and #6 oil prices would be \$5.15/MBtu and \$5.18/MBtu respectively. The breakeven #6 oil price is about 50 percent higher than the price paid by the installation. The possibility for this to occur certainly would be higher than the Fort Campbell case, where 100 percent gas/oil price increase is necessary for coal to be cost effective. The plant size considered for Picatinny Arsenal (250,000 lb/hr) is between the Fort Bragg plant and the Fort Campbell plant (379,000 and 188,000 lb/hr).

The LCC obtained in the Status Quo evaluation (\$71,601,420) is about the same as that in the CHPECON result for a new #6 oil-fired plant (\$71,021,912). A new coal-fired plant will cost about 40 percent more than the #6 oil-fired plant. Therefore, maintaining the status quo while further investigating a retrofit with coal water slurry is recommended.

3 CONCLUSIONS AND RECOMMENDATIONS

This study concludes that:

1. For all the four installations studied, the LCC of maintaining the status quo is lower than that of building new plants. This coincides with large defense cutbacks that have followed the conclusion of the cold war, when new plant construction would also become less likely.

2. When a new plant is to be built, and when that plant will have a capacity large enough to meet the demand of the whole installation, the feasibility of using coal as fuel is proportional to plant size. The larger the plant, the more likely the feasibility of coal. At Fort Bragg, for example, using coal was found to be economically feasible, but at Fort Campbell, Fort Gordon, and Picatinny Arsenal, however, coal would become attractive only if there were a significant price increase in alternative fuels: a 31 to 73 percent increase for gas, or a 50 to 84 percent increase for oil.

3. This study has found that a retrofit of Fort Bragg building C-1432's heating plant to coal-firing may result in significant cost savings. However, before undertaking this project, a more detailed engineering study may be justified.

It is recommended that a later coal conversion study:

1. Revise the economic studies (Status Quo and CHPECON runs) using updated fuel information at the beginning of each fiscal year. This will ensure that opportunities to convert to more cost-effective technologies will not be overlooked.

2. Reconcile the life cycle costs obtained from the Status Quo evaluations and the CHPECON runs to validate the cost comparison. For example, total fuel and labor costs should be in close agreement so that no individual option is penalized.

3. Obtain feedback from the installations studied (double-check) to ensure the input data are correct and the evaluations are reasonable.

4. Select heating plants in Army installations with capacities greater than 300 MBtu/hr that at one time had fired coal, to further study the economic and engineering ramifications of reconversion to coal.

METRIC CONVERSION TABLE

1 in.	=	25.4 mm
1 ft	=	0.305 m
1 sq ft	=	0.093 m ²
1 mi	=	1.61 km
1 acre	=	0.4047 hectare
1 lb	=	0.453 kg
1 gal	=	3.78 l
°F	=	(°C × 1.8) + 32

CITED REFERENCES

- Griffin, F.P., J.F. Thomas, R.S. Holcomb, and J.M. Young, *Ranking of Air Force Heating Plants Relative to the Economic Benefit of Coal Utilization*, ORNL/TM-11100, Report prepared for the Air Force Engineering and Services Center (Oak Ridge National Laboratory, Oak Ridge, TN, November 1989).
- Holcomb, R.S., and F.P. Griffin, *Economic Analysis of Coal-Fired Cogeneration Plants for Air Force Bases*, ORNL/TM-11383, Report prepared for the Air Force Engineering and Services Center (Oak Ridge National Laboratory, Oak Ridge, TN, October 1990).
- ORI, Inc. and C.H. Guernsey & Co., *Air Force Coal Conversion Study*, Report prepared for HQAFESC/DEMB Tyndall Air Force Base [AFB] (Tyndall AFB, FL, January 1988).
- Salthouse, Robert, Memorandum, subject: *Coal Progress Report Update* (July 1987).
- Savoie, Martin J., *Development of the Central Energy Heating Plant Status Quo Program*, Draft Technical Report (TR) (U.S. Army Construction Engineering Research Laboratory [USACERL], June 1992).
- Thomas, J.F., F.P. Griffin, and J.M. Young, *Economic Benefit of Coal Utilization/Conversion at Air Force Bases: Screening Study*, ORNL/TM-11113, Report prepared for the Air Force Engineering and Services Center (Oak Ridge National Laboratory, Oak Ridge, TN, August 1989).
- Thomas, J.F., and J.M. Young, *Coal-Burning Technologies Applicable to Air Force Central Heating Plants*, ORNL/TM-11173, Report prepared for the Air Force Engineering and Services Center (Oak Ridge National Laboratory, Oak Ridge, TN, December 1989).
- Wilkinson, V.K., *Life Cycle Cost Analyses of U.S. Air Force Heating Plants*, ORNL/TM-11146, Oak Ridge National Laboratory Report prepared for the Air Force Engineering and Services Center (August 1989).

UNCITED REFERENCES

- Blazek, C.F., R. Biderman, J. Kinast, and J. Gutraj, *Coal-Fired Boiler Evaluation Program, Volume 1: Final Report; Volume 2: User's Manual; Volume 3: Military Base Weather Information Data Management Program, Volume 4: Coal Fired Properties Information Data Management Program; Volume 5: Emission Regulations Data Management Program; Volume 6: Program Listing*, Report prepared by Institute of Gas Technology for USACERL (July 1990).
- Bleak & Veatch Engineers-Architects for the U.S. Army Corps of Engineers, *Master Plan Report, 101st Airborne Division, Air Assault and Ft. Campbell* (U.S. Army Corps of Engineers, Louisville District, November 1987).
- GRW Engineers, Inc., *Fort Bragg Master Plan, Phase II* (Savannah District, U.S. Corps of Engineers, January 1986).
- Lev Zetlin Associates, *Future Development Master Plan for Picatinny Arsenal*, Report prepared for U.S. Army Corps of Engineers, New York District (1991).
- Nakata Planning Group, *Master Plan Report, Fort Gordon, Georgia* (Savannah District, U.S. Army Corps of Engineers, November 1991).
- Pope, Evans, and Robbins Inc., *Power Plant Betterment and Coal Conversion Study, Picatinny Arsenal, New Jersey*, Report prepared for U.S. Army Corps of Engineers, New York District (February 1980).
- Pope, Evans, and Robbins Inc., *Power Plant Coal Conversion Study, Direct Combustion, Liquefaction, Gasification*, Report prepared for U.S. Army Corps of Engineers, New York District (June 1980).
- Prillaman, G., *Update of Fort Bragg Master Plan*, Briefing at Fort Bragg, TX (February 1992).
- Savoie, Martin J., Jill E. Davidson, and Gary W. Schanke, *Energy Supply Alternatives for Picatinny Arsenal*, TR FE-92/04/ADA256863 (USACERL, September 1992).

Singer, R., and A. Collishaw, *Conversion of Army Heating Plants to Coal: Three Case Studies*, TR E-176/ADA113947 (USACERL, March 1982).

Stanley Consultants, Inc., *Evaluation Procedure for Gas/Oil Central Heating Plants: Volume I*, Report prepared for USACERL (February 1991).

Woody, A.W. *Construct Coal Fired Central Heating Plant*, FY 1986 Military Construction Project Data prepared by JRB Associates for Fort Bragg (October 1982).

APPENDIX A:

Tables

Table 1

DOD Coal Consumption (Short Tons)

Year	Army	Air Force	Navy	DOD Total
1985	704190	452242	162095	1336261
(% of DOD)	(52.69%)	(33.84%)	(12.13%)	(100%)
1986	733490	491122	168689	1409446
1987	734457	472086	163891	1384984
1988	802218	478092	178227	1471240
1989	768962	448945	222888	1453444
1990	867690	439512	178490	1498740
1991	766725	435563	167232	1381155
(% ↑ vs. 85)	(8.88%)	(-3.69%)	(3.17%)	(+3.36%)

Table 2**Potential Sites for Increased Coal Use
(Surveyed in 1987)**

Bases	Ton/Year
Army Bases	
Iowa AAP	30,000
Fort Drum	223,000
New CumberlandAD	15,000
USMA	20,000
Fort Bragg	30,000
Picatinny Arsenal	40,000
Bayonne MOT	24,000
Redstone Arsenal	44,000
Fort Dix	25,000
Fort Knox	20,000
Fort Eustis	13,000
Lake City AAP	25,000
Scranton AAP	9,000
Fort Lewis	25,000
Fort Belvoir	15,000
Fort Greely	30,000
MDW Washington DC	67,000
Army Total	655,000
Navy Bases	
PWC Norfolk	566,000
MCDEC Quantico	23,000
NSY Norfolk	180,000
SUBASE New London	93,000
NSY Puget Sound	70,000
NAEC Lakehurst	21,000
NAS Memphis	34,000
NETC Newport	36,000
PWC Great Lakes	100,000
NATC Patuxent River	21,000
NSY Philadelphia	157,000
MCRD Parris Island	30,000
Navy Total	1,331,000
Air Force Bases	
Malmstrom AFB	17,000
Griffiss AFB	25,000
Air Force Total	42,000
DOD Total	2,028,000

Table 3

CONUS Army Bases With Average Annual Energy Consumption > 38MBtu/hr
Period Covered: From Jan 89 Through Dec 89

Rank	Base	# OF CHPs >50MBtu/hr	MBTU/year	Ave. MBTU/hr	
1	4	Radford Army Ammo Plant***	2**	3,960,608	452
2	7	Fort Bragg	5	3,117,543	356
3	8	Fort Hood	0	2,873,759	328
4	9	Fort Knox	2	2,718,746	310
5	10	Fort Benning	7	2,717,107	310
6	12	Fort Lewis	0	2,515,574	287
7	13	Fort Campbell	2	2,425,919	277
8	15	Fort Riley	1	1,937,176	221
9*	16	Fort Ord	0	1,874,942	214
10*	17	Fort Dix	4	1,793,491	205
11*	18	Fort George Meade	1	1,719,846	196
12	19	Fort Carson	1	1,706,884	195
13	20	Fort Bliss	1	1,655,909	189
14	21	Fort Sill	1	1,649,784	188
15	22	Fort Leonard Wood	4	1,646,571	188
16	24	Fort Stewart	1	1,601,289	183
17	25	Fort Drum	1**	1,536,908	175
18	26	Fort Belvoir	1	1,351,474	154
19	27	Fort Jackson	3	1,342,532	153
20	29	West Point	1	1,289,720	147
21	30	Walter Reed Army Medical	NTE	1,254,489	143
22*	31	Fort Devens	0	1,240,232	142
23	32	Picatinny Arsenal	2	1,229,515	140
24	33	Fort Gordon	3	1,224,015	140
25	35	Fort Polk	0	1,177,156	134
26	36	Fort Sam Houston	0	1,090,090	124
27	38	Fort Rucker	0	952,015	109
28*	41	Fort McClellan	0	914,909	104
29	42	Fort Eustis	0	907,831	104
30	45	Fort Leavenworth	1	868,345	99
31	46	Red River Army Ammo Depot***	1**	867,540	99
32*	47	Fort Benjamin Harrison	1	842,345	96
33	48	Fort Huachuca	0	821,486	94
34	51	Lone Star Army Ammo Plant***	5	747,764	85
35	53	Fort Lee	0	725,970	83
36	54	Anniston Army Depot***	2**	700,806	80
37	60	Fort McCoy	0	646,369	74
38	62	Fort Dietrick	1	630,684	72
39	64	Tooele Army Depot***	1	601,416	69
40	66	Fitzsimons Army Medical C	NTER	569,836	65
41	72	Fort McPherson	0	484,372	55
42	76	Fort Hamilton	0	414,203	47
43	77	Fort Irwin	0	409,088	47
44	79	Fort Myer	1	400,128	46
45	82	MTMC Mot Bayonne	1	336,471	38

* Installations recommended for closure.

** Coal is used in the CHPs. From USACERL'S INV program there are 104 CHPs with capacity >50 MBtu/hr, of which 88 CHPs firing gas/oil only.

*** AMC installation with limited inventory data available.

Table 4
Boiler Cost Data

Boiler	Fuel	Type	Capacity (MMBtu/hr)	Cost per boiler (\$)		
				1979 EPA Estimate	1991 EPA Estimate	CHPECON Equation
Stoker:			Input			
Underfeed	Coal Hi-S	Water	30	791700	1197003	1584883
Underfeed	Coal Lo-S	Water	30	679400	1027212	1584883
Chain-Grate	Coal Hi-S	Water	75	1865300	2820221	2282207
Chain-Grate	Coal Lo-S	Water	75	1639300	2478522	2282207
Spreader	Coal Hi-S	Water	150	3719200	5623206	3915500
Spreader	Coal Lo-S	Water	150	3220800	4869655	3915500
Pulverized	Coal Hi-S	Water	200	5633000	8516756	5150000
Pulverized	Coal Lo-S	Water	200	4881200	7380080	5150000
Gas/Oil:						
Oil	No. 6 Oil	Water	150	893100	1350313	951209
Oil	No. 2 Oil	Water	150	881000	1332019	951209
Gas	Nat. Gas	Water	150	832100	1258085	951209
Oil	No. 6 Oil	Water	30	274800	415481	370242

Table 5

CHPECON Cost Validation

	Fuel									
	Res Oil					Coal				
	Res Oil	Coal	E low S	E hi S	Coal	E low S	E hi S	Chain-Grate Siding	Coal	E hi S
Thermal Input										
Capacity (MBo/hr)										
Costs in 1979 (\$ \$1000)										
Capital	797.8	1665.2	1891.3	1891.3	4067.9	4554.4	4554.4		2379.7	8784.2
O&M	678.8	721.6	682.5	682.5	1330.5	1217.9	1217.9		2793.9	1849.1
Fixed	109.6	236.3	269.8	269.8	563.4	633.3	633.3		317.1	1225.9
Extrapolated to 1991 dollars										
Capital	1206.2	2517.7	2859.5	2859.5	6150.4	6886.0	6886.0		3712.5	13703.9
O&M	1157.6	1230.6	1163.9	1163.9	2269.0	2077.0	2077.0		4764.6	3153.4
Fixed	165.7	357.3	407.9	407.9	851.8	957.5	957.5		479.4	1853.5
Total 1991 dollars, 25-year life	34289	4221.4	42155	42155	84170	82748	82748		13481.3	19887.5
Energy input, MBo/year (55% load yearly)	144540	144540	144540	144540	361350	361350	361350		722700	722700
Dollars/MBo (1991 dollars, 25-year life)	9.49	11.68	11.67	11.67	9.32	9.16	9.16		7.46	7.69
Comparable system, evaluated by CHPECON	9.49	11.68	11.67	11.67	9.32	9.16	9.16		7.46	7.69
Dollars/MBo	9.2	37.72	39.03	39.03	57.14	57.78	57.78		8.65	90.34

Table 6

Items Included in Boiler Costs (of Table 4)

Boiler pressure parts and drums
 Boiler trim and soot blowers
 Boiler refractory, insulation and lagging
 Stoker and grate
 F.D. Fan and overfire air fan
 Combustion air ductwork and distribution system
 Boiler convective sections
 Economizer or air heater
 Main steam non-return and block valve
 Coal feeders
 Coal distribution duct
 Coal scale
 Fly ash reinjection system
 Ash hoppers
 Boiler steel
 Boiler instruments
 Erection and erection supervisor
 Start-up supervision
 Boilout and initial operator training
 Operation manuals

Table 7

Comparison of CHPECON and Status Quo Costing

Parameters	STATUS QUO	CHPECON	SQ Rev 1	SQ Rev 2
Annual labor	129476	463732	463732	463732
Annual supplies	90000	6510	6510	81987
Annual service	12162	15166	15166	15166
Annual utilities	60811	25909	25909	25909
Annual insurance	0	75477	0	Added to Supply
Sum of listed R/R costs	1143895	362299	1143894	1143894
Nat gas/oil use (MBtu/yr)	106641	119956	119956	119956
LCC of O&M	3722461	6398620	6508341	7469057
LCC of R/R	1143894	173957	1143894	1143894
LCC of Energy	6755133	9169737	7597808	7597808
Capital invest	0	3750969	0	0
LCC (total)	11621490	19493285	15250040	16210760

Note: All costs in Present Worth Value (1992 dollars)

Table 8

Base Selection Criteria and Point Assignment

Criterion #	Description	Point Assignment
1	Location of site relative to population centers	(no point)
2	Cooperation, response to previous surveys	(P=poor,2, F=fair,8, G=good,14, VG=very good,20)
3	Land available for coal/ash (no,1; some,5; yes,10)	
4	Problems related to local emission standards (ozone, CO ₂ , particulates, SO ₂ , NO _x , etc.)	(OK=20, Average=10, Poor=2)
5	Condition of present boilers	(P=poor,9, F=fair,7, G=good,5, VG=very good,3, NRNEW=nearly new,1, NEW=new boiler,1)
6	Condition of existing steam system	(P=poor,9, F=fair,7, G=good,5, VG=very good,3, RP=repairing,6)
7	Master planning notes and comments	(C=construction,6, CLCP=has coal capability,9, RP=replacement construction,5, CVEL=converting to electricity,2, RTDF=coal retrofit difficult,2, NONE=no additional comments,1)
8	Future addition/reduction in load planned	(ADD,8; RED,1; NO,1)
9	Coal burning feasible	(ACC=acceptable,9, NC=no comment,5, WOOD=will increase wood burning,3, WT=system too small,3, NORR=no rail access,3, NVB=not viable,2, UNW=unwanted,1)

Table 9

Base Selection Criteria

Base	1	2	3	4	5	6	7	8	9
Lone Star	out 35K	P-F	no	OK	O	O	NONE	NO	NC
Red River	out 35K	P-F	no	OK	O	O	NONE	NO	ACC
Fort Bragg	out 80K	VG	some	O3CO2	VG	G	C	ADD	ACC
Fort Cmpbl	rural TN	VG	yes	O3CO2SO2	P-VG	G	C	ADD	NC
Fort Carson	out 291K	VG	yes	CO2PART	NRNEW	G	C	ADD	NORR
Fort Hood	out 64K	G	yes	OK	F	G	C	NO	WT
Fort Polk	rural LA	G	yes	OK	VG	O	C	NO	ACC
Fort Riley	near 33K	VG	some	OK	G-VG	G	C	ADD	NVB
Fort Houstn	in 985K	VG	no	OK	P-NEW	G	CLCP	ADD	NC
Fort Stewrt	near 153K	F	yes	OK	G-NEW	G	CLCP	NO	WOOD
Fort Bliss	out 580K	F-G	yes	O3CO2PRT	G	O	RP	NO	UNW
Fort Eustis	out 296K	F	yes	O3	G	F	C	ADD	UNW
Fort Gordon	out 47K	G	yes	OK	G	O	C	ADD	UNW
Fort Jacksn	out 96K	G	yes	OK	F-G	F	C	ADD	UNW
Fort L Wood	rural MO	G-VG	no	OK	VG	O	C	NO	UNW
Fort MCleln	out 31K	F	no	O3	G	G	RTDF	NO	UNW
Fort Rucker	rural AL	F	yes	OK	P-VG	RP	CVEL	ADD	ACC
Fitzsimns	Denver	G	no	CO2 PART	G	RP	C	ADD	NC
Fort Myer	DC area	G	no	O3 CO2	NRNEW	F	C	ADD	UNW
Bayonne	NYC area	G-VG	no	O3 CO2	F	RP	C	ADD	NC

Table 10

Points and Scores In Base Selection

Base	1	2	3	4	5	6	7	8	9	Total
Lone Star	out 35K		0	20	8	5	1	1	5	42
Red River	out 35K	2	0	20	8	5	1	1	9	46
Fort Bragg	out 80K	18	5	12	3	5	6	8	9	66
Fort Campbell	rural TN	18	10	8	6	5	6	8	5	66
Fort Carson	out 291K	10	10	12	1	5	6	8	3	55
Fort Hood	out 64K	10	10	20	7	5	6	1	3	62
Fort Polk	rural LA	10	10	20	3	5	6	1	9	64
Fort Riley	near 33K	16	5	20	4	5	6	8	2	66
Fort Houston	in 985K	16	0	20	5	5	9	8	5	68
Fort Stewart	near 153K	6	10	20	3	5	9	1	3	57
Fort Bliss	out 580K	8	10	8	5	5	5	1	1	43
Fort Eustis	out 296K	6	10	16	5	7	6	8	1	59
Fort Gordon	out 47K	14	10	20	5	5	6	8	1	69
Fort Jackson	out 96K	10	10	20	6	7	6	8	1	68
Fort Leonard Wood	rural MO	14	0	20	3	5	6	1	1	50
Fort McClellan	out 31K	6	0	16	5	5	2	1	1	36
Fort Rucker	rural AL	6	10	20	6	6	2	8	9	67
Fitzsimmons	Denver	10	0	12	5	6	6	8	5	52
Fort Myer	DC area	10	0	12	1	7	6	8	1	45
Bayonne	NYC area	10	0	12	7	6	6	8	5	54

Table 11

Fort Campbell Heating Plant Information

Plant	Boiler	Fuel	Reserve	Year Installed	Capacity (lb/hr)	In use	Rating	Energy Use Heat/Cool/ Process/Losses/ Internal/Pwr Gen
3902	1	Nat. gas	FS2	1976	15000	Y*	6	H/C
3902	2	Nat. gas	FS2	1976	50000	Y*	5	H/C
3902	3	Nat. gas	FS2	1976	50000	Y	6	H/C
650	1	Nat. gas	FS2	1982	15000	Y*	9	H/C
650	2	Nat. gas	FS2	1982	15000	Y	9	H/C
650	3	Nat. gas	FS2	1982	15000	Y	9	H/C
7008	1	Nat. gas	FS2	1985	25106	Y*	8	H
7008	2	Nat. gas	FS2	1985	25106	Y	8	H
7008	3	Nat. gas	FS2	1958	12500	N	1	H
7223	1	Nat. gas	FS2	1972	10000	Y*	6	H
7223	2	Nat. gas	FS2	1972	10000	Y	6	H
7223	3	Nat. gas	FS2	1972	10000	Y	5	H
858	1	Nat. gas	FS2	1986	11716	Y*	8	H
858	2	Nat. gas	FS2	1986	11716	Y	8	H

Table 12

Fort Campbell Energy Use Data

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 use	\$/MBtu	MBtu '90
Dist. oil	Gal	138690	0.56	1018962	631518	4.04	87585
Res. oil	Gal	149690	0.53	301266	93219	3.54	13954
Nat. gas							
Interr.	kscf						
Unintr.	kscf	1031000	3.08	1364848	1391702	2.99	1434845
Building:		650	3902	7008	7223	858	
Capacity (lb/hr):		45000	115000	62712	30000	23432	
SQ file:		CAM1	CAM2	CAM3	CAM4	CAM5	
Annual Costs							
Labor		129476	138100	94000	85600	94000	
Utilities*		60811	155405	84746	20270	31665	
Service*		12162	31081	16949	4054	6333	
Supplies*		90000	22400*	125424	30000	46864	
Average Steam Production, 1990 (lb/hr):							
October		9250.0	14250.0	8541.7	0.0	4058.3	
November		10833.3	26625.0	11250.0	4083.3	4458.3	
December		14416.7	39250.0	17541.7	8687.9	7291.7	
January		12416.7	38500.0	15000.0	7375.0	4125.0	
February		16458.3	32541.7	14666.7	5616.7	4541.7	
March		12791.7	29958.3	10875.0	4600.1	4408.3	
April		10000.0	22541.7	9375.0	0.0	4133.3	
May		9166.7	6166.7	9100.0	0.0	4012.5	
June		6625.0	8041.7	11958.3	0.0	3662.5	
July		6916.7	7583.3	11916.7	0.0	3900.0	
August		5958.3	6958.3	10791.7	0.0	4075.0	
September		6833.3	5458.3	18225.0	0.0	3675.0	
Fuel energy, based on steam production, 1990 (MBtu):							
October		8291.6	12773.5	7656.7	0.0	3637.8	
November		9397.6	23096.4	9759.0	3542.1	3867.4	
December		12922.9	35183.1	15724.1	7787.7	6536.2	
January		11130.2	34510.8	13445.8	6610.8	3697.6	
February		13325.3	26347.0	11874.7	4547.5	3677.1	
March		11466.3	26854.2	9748.2	4123.5	3951.5	
April		8674.7	19554.2	8132.5	0.0	3585.5	
May		8216.9	5527.7	8157.1	0.0	3596.7	
June		5747.0	6975.9	10373.5	0.0	3177.1	
July		6200.0	6797.6	10682.0	0.0	3495.9	
August		5340.9	6237.3	9673.5	0.0	3652.8	
September		5927.7	4734.9	15809.6	0.0	3188.0	
Total		106641.0	208592.8	131036.7	26611.7	46063.7	518945.8
Percent of Total		20.5	40.2	25.3	5.1	8.9	
Reserve Fuel		#2	#2	#2	#2	#2	
Fuel use (MBtu/year):							Total
Natural Gas		99176.1	193991.3	121864.2	24748.8	42839.2	482620
Dist. Oil		7464.9	14601.5	9172.6	1862.8	3224.5	36326
Res. Oil		0.0	0.0	0.0	0.0	0.0	0
Total \$/yr:		618867.9	1187071.9	722211.9	221380.4	319858.9	
\$/MBtu:							

Table 12 (Cont'd)

Labor	1.21	0.66	0.72	3.22	2.04	
Utilities	0.57	0.75	0.65	0.76	0.69	
Service	0.11	0.15	0.13	0.15	0.14	
Supplies	0.84	1.07	0.96	1.13	1.02	
Fuel	3.05	3.05	3.05	3.05	3.05	
Total \$/MBtu:	5.79	5.68	5.50	8.31	6.93	Average
Reported \$/klb steam:	7.25	7.25	7.25	7.25	7.25	6.44

* = estimated

Table 13a

Boiler Parts Evaluation List—Port Campbell Bldg. 650

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)					
1. Boiler Pressure Parts and Setting	1978	3	15000 lb/hr		Good
2. Relief Valve(s)	1978	4	100 psig	332 temp	Good
2. Relief Valve(s)	1991	2	1.5 in.	150 psig	Good
3. Feedwater Regulator(s)	1978	3	1.5 in.	150 psig	Good
4. Boiler Burner(s)	1978	3	1.5 in.	160 psig	Good
5. Boiler Fan(s) (FD)	1978	3	70 MBtu/ft ³ /hr		
6. Boiler Economizer	1978	3	15 Hp		
		3	684 MBtu, 15,000 lb/hr water		
7. Boiler Drum Level Control	1978	3	flow		Good
B. Feedwater System					
8. Deaerating Heater	1978	1	45000 lb/hr		Good
12. Condensate Pumps	1978	2	3 Hp		Good
13. Condensate Receiver	1978	1	1100 gal	(7.5'x5')	Good
14. Boiler Feed Pumps	1978	3	20 Hp		Good
19. Feedwater Piping System (valve)	1978	3	1.5 diam (in.)	160 psig	Good
20. Cooling Water Pumps	1978	3	60 Hp	(motor)	Good
20. Cooling Water Pumps	1978	1	62.6 Hp	(turbine)	Good
21. HTW Distribution System Pumps	1978	1			Good
C. Fuel Handling System					
1. Fuel Oil Unloading Pump			Hp		
2. Fuel Oil Tank - Above ground			gal		
3. Fuel Oil Tank - Underground	1978	1	50000 gal		
4. Fuel Oil Pump	1978	1	15 gpm		Good
5. Fuel Oil Heater	1978	2	gpm		
6. Fuel Oil Piping System (ABV/BLW)	1978		0.75 diam (in.)		
7. Natural Gas Piping System (BLW)	1990		2 diam (in.)		Good
D. Heat Recovery System					
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1978	3	2 diam (ft)	25 height (ft)	

Table 13a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1978	1			Good
2. Boiler Master	1978	3			Good
3. Flame Safeguard System	1978	3			Good
4. Furnace Draft Control (DAMPACT)	1978	3			Good
5. Additional Boiler Instrumentation/Indicators	1978		O2 TRIM		Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1978	1	30 gal	0.25 Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1992	2	120 gpm	(alternate use)	Good
I. Condensate Purlishing					
J. Compressed Air System					
1. Air Compressor (CENTR/RECIP)	1978	1	16.2 SCFM	(3 Hp, 145 psi)	Good
2. Air Dryer (DESC/REFR)	1978	1	16.2 SCFM		
3. Air Receiver	1978	1	60 gal		Good
K. Electrical System					
1. Transformer	1978	2	1500/1725 KVA		
2. Switchgear -- Main Circuit Breaker	1978	2	3000 amps		
3. Motor Control Center/Starter	1979	3	300 amps		
4. Emergency Generator	1978	2	1000 KVA	(800 Continuous)	Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1978				Good
2. Building Concrete and Building Steel	1978				Good
3. Sump Pump (SUBMERGE/VERTICAL)	1978	1	75 gpm	(1.5 Hp)	Good
4. Building Lighting (Fluorescent)	1978				Good
Building Outside Dimensions	30 Ht (ft)		95 Lgth (ft)	132 Width (ft)	
Building Basement (Yes/No)	No				

Table 13b

STATUS QUO LIFE-CYCLE COST ANALYSIS FOR FORT CAMPBELL BLDG. 650

LIFE CYCLE COST ANALYSIS
 LCCID 1.065
 PROJECT NO., FY, & TITLE: FY 1992
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

STUDY: TDCAMI

DATE/TIME: 05-14-92 15:37:38

BUILDING 650

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) MAY 92
 MIDPOINT OF CONSTRUCTION (MPC) JUN 92
 BENEFICIAL OCCUPANCY DATE (BOD) JAN 93
 ANALYSIS END DATE (AED) JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	COST INCURRED
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	30158.6	1.58	JUL93-JUL17
NATURAL GAS	296536.3	3.64	JUL93-JUL17
MAINT LABOR	129476.0	.00	JUL93-JUL17
MAINT SERV	12162.0	.00	JUL93-JUL17
MAINT SUPPLY	90000.0	.00	JUL93-JUL17
MAINT UTIL	60811.0	.00	JUL93-JUL17
STACK	18000.0	.00	JAN 18
STACK	36000.0	.00	JAN 18
DRUMCTL	15000.0	.00	JAN 98
ECONOMIZER	105000.0	.00	JAN 98
F_FAN	21000.0	.00	JAN 18
RELVALVE	6800.0	.00	JAN 98
RELVALVE	3400.0	.00	JAN 11
WTSOILER	1800000.0	.00	JAN 18
WTSOILER	150000.0	.00	JAN 18
PUMPSIMPLEX	3000.0	.00	JAN 98
TANKPOLY	200.0	.00	JAN 98
BOILMASTER	15000.0	.00	JAN 08
DAMPACT	3000.0	.00	JAN 08
FLAMESAFE	30000.0	.00	JAN 08
O2TRIM	30000.0	.00	JAN 08
PLANTMASTER	5000.0	.00	JAN 08
AIRCOMPRESSIP	20000.0	.00	JAN 98
AIRDRYERREPR	12000.0	.00	JAN 93
AIRRCV	600.0	.00	JAN 08
EMERGENCYOGEN	276000.0	.00	JAN 08
SWITCH	20000.0	.00	JAN 18
CONDOPUMP	8000.0	.00	JAN 98
CONDREC	22000.0	.00	JAN 08
COOLPUMP	34200.0	.00	JAN 98
COOLPUMP	11400.0	.00	JAN 98
DAIRHEATER	25000.0	.00	JAN 18
FEEDPUMP	45750.0	.00	JAN 08
FWPIPINGVAL	3339.0	.00	JAN 98
NAGPIPERELON	13.0	.00	JAN 15
OILPIPERELON	25.0	.00	JAN 03
PUMP	3250.0	.00	JAN 03
TANKSELON	42000.0	.00	JAN 08
SISOFT	231000.0	.00	JAN 12
SUMPUMPVERT	5000.0	.00	JAN 93

OTHER KEY INPUT DATA

LOCATION - KENTUCKY CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE: 10**6 BTUS ELECTRIC DEMAND: 10**0 DOLLARS
 ENERGY TYPE \$/MBTU AMOUNT ELECT. DEMAND PROJECTED DATES
 DIST 4.04 7465.0 JAN93-JAN18
 NAT G 2.99 99176.0 JAN93-JAN18

Table 13b (Cont'd)

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	519369.
NATURAL GAS	6478871.
TOTAL ENERGY COSTS	6998240.
RECURRING M&R/CUSTODIAL COSTS	4260154.
MAJOR REPAIR/REPLACEMENT COSTS	1160392.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	12418790.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

LCCID 1.065 DATE/TIME: 05-14-92 15:37:38
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 650
 INSTALLATION & LOCATION: PORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QOO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	28852.	284669.	277500.	16498.	0.
2	27605.	276385.	265297.	0.	0.
3	26328.	264967.	253630.	0.	0.
4	25165.	253314.	242476.	0.	0.
5	24081.	244182.	231812.	0.	0.
6	23166.	236963.	221618.	160385.	0.
7	22622.	238399.	211872.	0.	0.
8	22234.	243697.	202554.	0.	0.
9	21914.	251130.	193647.	0.	0.
10	21690.	263000.	185131.	0.	0.
11	21463.	271218.	176989.	2027.	0.
12	21206.	274010.	169206.	0.	0.
13	20935.	279887.	161764.	0.	0.
14	20561.	283054.	154650.	0.	0.
15	20110.	284282.	147849.	0.	0.
16	19570.	281212.	141347.	232007.	0.
17	18978.	274326.	135131.	0.	0.
18	18325.	270636.	129189.	0.	0.
19	17750.	263944.	123507.	1469.	0.
20	17288.	257076.	118076.	95387.	0.
21	16856.	250655.	112843.	0.	0.
22	16396.	243803.	107919.	0.	0.
23	15932.	236907.	103173.	5.	0.
24	15416.	229236.	98636.	0.	0.
25	14924.	221922.	94298.	0.	0.
***	519369.	6478871.	4260154.	1160392.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 14a

Boiler Evaluation Parts List—Fort Campbell Bldg. 3902

Equipment	Year		Specification 1	Specification 2	Condition
	Installed	Units			
A. Boiler (WT)	1976	2	50 MBtu/hr		Good
A. Boiler (WT)	1976	1	15 MBtu/hr		Good
1. Boiler Pressure Parts and Setting.					
2. Relief Valve(s)	1976	4	100 psig	333 temp	Good
2. Relief Valve(s)	1990	2	4 in.	115 psig	Good
3. Feedwater Regulator(s)	1991	2	2 in.	115 psig	Good
4. Boiler Burner(s)	1976	2	2-2.5, 1-1.5 in.	150 psig	Good
5. Boiler Fan(s) (FD)	1976	2	MBtu		Good
5. Boiler Fan(s) (FD)	1976	1	25 Hp		Good
6. Boiler Economizer	1976	2	5 Hp		Good
7. Boiler Drum Level Control	1991	2	159000 MBtu	(on 2 larger blrs)	Good
B. Feedwater System					
8. Deserating Heater	1976	1	7500 lb/hr		Good
12. Condensate Pumps	1976	1	3 Hp		Good
12. Condensate Pumps	1991	3	5 Hp		Good
13. Condensate Receiver	1976	1	10000 gal		Good
14. Boiler Feed Pumps	1976	3	40 Hp	(1-turbine, 2-motor)	Good
19. Feedwater Piping System (valve)	1976		2 diam (in.)	150 psig	Good
20. Cooling Water Pumps	1976	3	60 Hp		Good
C. Fuel Handling System					
1. Fuel Oil Unloading Pump	1976	3	30 Hp		Good
2. Fuel Oil Tank - Above ground	1976	1	1000000 gal		Good
3. Fuel Oil Tank - Underground	1976	1	20000 gal		Good
4. Fuel Oil Pump	1976	1	10 gpm	(20 Hp)	Good
6. Fuel Oil Piping System (BLW)	1976		2 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1976		3 diam (in.)		Good
D. Heat Recovery System					
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack			diam (ft)	height (ft)	

Table 14a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1991	1			Good
2. Boiler Master	1991	3			Good
3. Flame Safeguard System	1976	3			Good
4. Furnace Draft Control (DAMPACT)	1991	3			Good
5. Additional Boiler Instrumentation/Indicators	1976	2	O2 TRIM on larger btrs		Good
G. Chemical Feed Systems					
1. Chemical Storage Tanks and Pumps	1976	5	50 gal	0.333 Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1989	1	270 gpm	(185 continuous)	Good
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECTIP)	1976	1	48 SCFM	(15 Hp)	Good
1. Air Compressor (RECTIP)	1990	2	48 SCFM	(15 Hp)	Good
2. Air Dryer (REFR)	1976	1	50 SCFM		
3. Air Receiver	1976	1	200 gal		Good
3. Air Receiver	1976	1	100 gal		Good
K. Electrical System					
1. Transformer	1993	1	2600 KVA		Good
1. Transformer	1993	1	1500 KVA		Good
2. Switchgear - Main Circuit Breaker	1976	1	50 amps		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1976				Good
2. Building Concrete and Building Steel	1976				Good
3. Sump Pump (SUBMERGE/VERTICAL)	1989	1	gpm	(3 Hp)	Good
4. Building Lighting	1976				Good
Building Outside Dimensions		Ht (ft)	—	—	Width (ft)
Building Basement (Yes/No)					

Table 14a

Status Quo Life-Cycle Cost Analysis for Fort Campbell Bldg. 3902

LIFE CYCLE COST ANALYSIS
 LOCID 1.065
 PROJECT NO., FY, & TITLE: FY 1992
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURES:
 ALT. ID. A; TITLE: STATUS QAO
 NAME OF DESIGNER:

STUDY: TDCAM2

DATE/TIME: 05-14-92 15:44:57

BUILDING 3902

KENTUCKY

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.66

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) JAN 92
 MIDPOINT OF CONSTRUCTION (MPC) JUL 92
 BENEFICIAL OCCUPANCY DATE (BOD) JAN 93
 ANALYSIS END DATE (AED) JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL	TIME(S)
DESCRIPTION	IN DOS \$	ESCALATION RATE	COST INCURRED
	(\$ X 10**0)	(\$ PER YEAR)	
INVESTMENT COSTS	.0	.00	JUL 92
DISTILLATE OIL	58992.1	1.58	JUL93-JUL17
NATURAL GAS	580033.1	3.39	JUL93-JUL17
MAINT LABOR	138100.0	.00	JUL93-JUL17
MAINT SERV	31081.0	.00	JUL93-JUL17
MAINT SUPPLY	224000.0	.00	JUL93-JUL17
MAINT UTIL	155405.0	.00	JUL93-JUL17
STACK	25000.0	.00	JAN 16
DRUMCYL	15000.0	.00	JAN 11
ECONOMIZER	140000.0	.00	JAN 96
F_JAN	7000.0	.00	JAN 16
F_JAN	23750.0	.00	JAN 16
RELVALVE	6400.0	.00	JAN 96
RELVALVE	3200.0	.00	JAN 10
WTBOILER	600000.0	.00	JAN 16
WTBOILER	1950000.0	.00	JAN 16
WTBURNER	50000.0	.00	JAN 16
WTBURNER	200000.0	.00	JAN 16
PUMPSIMPLEX	15000.0	.00	JAN 96
TANKPOLY	1000.0	.00	JAN 96
FLAMESAFE	30000.0	.00	JAN 06
O2TRIM	20000.0	.00	JAN 06
AIRCOSPRECIP	32000.0	.00	JAN 96
AIRCOSPRECIP	64000.0	.00	JAN 10
AIRDRYERREFR	20000.0	.00	JAN 91
AIRDRYCV	600.0	.00	JAN 06
AIRDRYCV	1100.0	.00	JAN 06
SWITCH	12000.0	.00	JAN 16
TRANSFORMER	38000.0	.00	JAN 16
TRANSFORMER	51200.0	.00	JAN 16
CONDUMP	4000.0	.00	JAN 96
CONDUMP	13500.0	.00	JAN 96
COOLPUMP	34200.0	.00	JAN 96
DAIRHEATER	55000.0	.00	JAN 16
FEEDPUMP	53250.0	.00	JAN 06
FWDPIPINGVAL	1100.0	.00	JAN 96
WAGPIPERELON	18.0	.00	JAN 01
OILPIPERELON	25.0	.00	JAN 01
PUMP	4000.0	.00	JAN 01
TANKABOVE	320000.0	.00	JAN 16
TANKBELOW	26000.0	.00	JAN 06
UNLOADPUMP	23400.0	.00	JAN 96
SISSOFT	191000.0	.00	JAN 09
SUMPUMPVERT	4900.0	.00	JAN 04

OTHER KEY INPUT DATA

LOCATION - KENTUCKY CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE: 10**6 BTUS ELECTRIC DEMAND: 10**0 DOLLARS
 ENERGY TYPE \$/MBTU AMOUNT ELECT. DEMAND PROJECTED DATES
 DIST 4.04 14602.0 JAN93-JAN18
 NAT G 2.99 193991.0 JAN93-JAN18

Table 14b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:44:57
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 3902
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 0.

ENERGY COSTS:

DISTILLATE OIL 1005860.
 NATURAL GAS 12388260.

TOTAL ENERGY COSTS 13394120.

RECURRING M&R/CUSTODIAL COSTS 7872439.

MAJOR REPAIR/REPLACEMENT COSTS 1558820.

OTHER O&M COSTS & MONETARY BENEFITS 0.

DISPOSAL COSTS/RETENTION VALUE 0.

LCC OF ALL COSTS/BENEFITS (NET PW) 22825380.

*NET PW EQUIVALENTS ON JAN92; IN 10**0 DOLLARS; IN CONSTANT JAN92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	55878.	544316.	512799.	0.	0.
2	53462.	528476.	490248.	0.	0.
3	50990.	506643.	468688.	0.	0.
4	48737.	484362.	448076.	226048.	0.
5	46637.	466900.	428371.	0.	0.
6	44866.	453096.	409533.	0.	0.
7	43812.	455844.	391523.	0.	0.
8	43060.	465973.	374305.	0.	0.
9	42441.	480185.	357844.	2697.	0.
10	42007.	502883.	342107.	0.	0.
11	41567.	518597.	327062.	0.	0.
12	41070.	523934.	312679.	2856.	0.
13	40545.	535173.	298928.	0.	0.
14	39820.	541227.	285782.	69769.	0.
15	38947.	543575.	273214.	0.	0.
16	37902.	537705.	261199.	0.	0.
17	36755.	524538.	249712.	88919.	0.
18	35491.	517484.	238731.	29909.	0.
19	34377.	504687.	228232.	6382.	0.
20	33482.	491555.	218195.	0.	0.
21	32646.	479278.	208600.	0.	0.
22	31753.	466176.	199426.	0.	0.
23	30855.	452991.	190656.	0.	0.
24	29856.	438321.	182271.	1132239.	0.
25	28904.	424337.	174256.	0.	0.
1005860.	**	7872439.	1558820.	0.	0.

*NET PW EQUIVALENTS ON JAN92; IN 10**0 DOLLARS; IN CONSTANT JAN92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 15a

Boiler Evaluation Parts List—Fort Campbell Bldg 7068

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (FT)	1985	2	25.106 MBtu/hr		Good
1. Boiler Pressure Parts and Setting			100 psig	333 temp	Good
2. Relief Valve(s)	1990	4	2.5 in.	150 psig	Good
3. Feedwater Regulator(s)	1985	1	1.5 in.	165 psig	Good
4. Boiler Burner(s)	1985	2	31383 MBtu		Good
5. Boiler Fan(s) (FD)	1985	2	30 Hp		Good
6. Boiler Economizer	1985	1	530909 MBtu		Good
7. Boiler Drum Level Control	1985	2			Good
B. Feedwater System					
8. Desecrating Heater	1985	1	57750 lb/hr		Good
14. Boiler Feed Pumps	1990	2	20 Hp	(with DA tank)	Good
15. Make-up Pumps					
19. Feedwater Piping System (valve)	Base water supply pressure		2.5 diam (in.)	165 psig	Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1985	1	30000 gal		Good
4. Fuel Oil Pump	1985	2	18 gpm	(2 Hp)	Good
6. Fuel Oil Piping System (BLW)	1985		1.25 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1985		4 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	Outside Pit		_____ diam (ft)	_____ height (ft)	Good
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1960	2	2'4" diam	40 height (ft)	Good
F. Combustion Controls					
3. Flame Safeguard System	1987	2			Good
4. Furnace Draft Control (DAMPACT)	1985	2			Good
5. Additional Boiler Instrumentation/Indicators	1985	2	O2 TRIM		Good

Table 15a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1987	3	50 gal	0.333 Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1985	1	290 gpm		
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1991	1	33.60 SCFM	(15 Hp)	Good
2. Air Dryer (REFR)	1991	1	40.50 SCFM		
3. Air Receiver	1991	1	50 gal		Good
K. Electrical System					
1. Transformer/TransPCB	—	3	75 KVA		Good
2. Switchgear - Main Circuit Breaker	1985	1	60 amps		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1985				Good
2. Building Concrete and Building Steel	1985				Good
3. Sump Pump		1	gpm	(3 Hp)	
(SUBMERGE/VERTICAL)	1989				
4. Building Lighting	1985				Good
Building Outside Dimensions		Ht (ft)	—	—	Width (ft)
Building Basement (Yes/No)	No		—	—	
Building Size	1956		2828 sq ft		

Table 15b

**Status Quo Life-Cycle Cost Analysis
for Fort Campbell Bldg. 7008**

LIFE CYCLE COST ANALYSIS **STUDY: TDCAM3**
 LCCID 1.065 **DATE/TIME: 05-14-92 15:47:36**
PROJECT NO., FY, & TITLE: FY 1992 **BUILDING 7008**
INSTALLATION & LOCATION: PORT CAMPBELL **KENTUCKY**
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) **MAY 92**
MIDPOINT OF CONSTRUCTION (MPC) **JUN 92**
BENEFICIAL OCCUPANCY DATE (BOD) **JAN 93**
ANALYSIS END DATE (AED) **JAN 18**

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S) COST INCURRED
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	
=====	=====	=====	=====
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	37058.9	1.58	JUL93-JUL17
NATURAL GAS	364373.4	3.64	JUL93-JUL17
MAINT LABOR	94000.0	.00	JUL93-JUL17
MAINT SERV	16949.0	.00	JUL93-JUL17
MAINT SUPPLY	125424.0	.00	JUL93-JUL17
MAINT UTIL	84746.0	.00	JUL93-JUL17
DRUMCTL	10000.0	.00	JAN 05
ECONOMIZER	35000.0	.00	JAN 05
FTBOILER	1327500.0	.00	JAN 10
FTBURNER	112800.0	.00	JAN 10
RELVALVE	6800.0	.00	JAN 10
PUMPSIMPLEX	9000.0	.00	JAN 07
TANKPOLY	600.0	.00	JAN 07
DAMPACT	2000.0	.00	JAN 15
FLAMESAFE	20000.0	.00	JAN 17
O2TRIM	20000.0	.00	JAN 15
AIRCOMPRECIP	32000.0	.00	JAN 11
AIRDRYERREFR	16000.0	.00	JAN 06
FWPIPINGVAL	1120.0	.00	JAN 05
NAGPIPEBELOW	23.0	.00	JAN 10
OILPIPEBELOW	25.0	.00	JAN 10
PUMP	7400.0	.00	JAN 10
TANKBELOW	42000.0	.00	JAN 15
SZSOFT	191000.0	.00	JAN 05
SUMPPUMPVERT	4900.0	.00	JAN 04
=====	=====	=====	=====

Table 15b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:47:36
PROJECT NO., FY, & TITLE: FY 1992 BUILDING 7008
INSTALLATION & LOCATION: PORT CAMPBELL KENTUCKY
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

OTHER KEY INPUT DATA

LOCATION - KENTUCKY CENSUS REGION: 3
RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	4.04 9173.0		JAN93-JAN18
NAT G	2.99 121864.0		JAN93-JAN18

Table 15b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:47:36
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 7008
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	638201.
NATURAL GAS	7961011.
TOTAL ENERGY COSTS	8599212.
RECURRING M&R/CUSTODIAL COSTS	4677794.
MAJOR REPAIR/REPLACEMENT COSTS	851324.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	14128330.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 15b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:47:36
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 7008
 INSTALLATION & LOCATION: PORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	35454.	349791.	304705.	0.	0.
2	33921.	339612.	291305.	0.	0.
3	32352.	325582.	278494.	0.	0.
4	30923.	311264.	266247.	0.	0.
5	29591.	300042.	254538.	0.	0.
6	28466.	291171.	243344.	0.	0.
7	27798.	292937.	232642.	0.	0.
8	27321.	299446.	222412.	0.	0.
9	26928.	308579.	212631.	0.	0.
10	26653.	323166.	203280.	0.	0.
11	26374.	333264.	194340.	0.	0.
12	26058.	336694.	185794.	2900.	0.
13	25725.	343916.	177623.	134143.	0.
14	25265.	347807.	169812.	8653.	0.
15	24711.	349315.	162344.	4964.	0.
16	24048.	345543.	155204.	0.	0.
17	23320.	337082.	148379.	0.	0.
18	22518.	332548.	141854.	657156.	0.
19	21811.	324325.	135615.	13822.	0.
20	21244.	315886.	129651.	0.	0.
21	20713.	307996.	123950.	0.	0.
22	20147.	299577.	118499.	0.	0.
23	19577.	291103.	113287.	23092.	0.
24	18943.	281677.	108305.	0.	0.
25	18339.	272690.	103542.	6596.	0.
***	638201.	7961011.	4677794.	851324.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 16a

Boiler Evaluation Parts List—Fort Campbell Bldg. 7223

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)					
1. Boiler Pressure Parts and Setting	1972	3	10 MBtu/hr		Good
2. Relief Valve(s)	1972	3	100 psig	333 temp	Good
2. Relief Valve(s)	1992	3	1.5 in.	115 psig	Good
3. Feedwater Regulator(s)	1991	3	1.5 in.	110 psig	Good
4. Boiler Burner(s)	1972	3	1 in.	165 psig	Good
5. Boiler Fan(s) (FD)	1972	3	12600 MBtu		Good
6. Boiler Economizer	1972	1	5 Hp		Good
7. Boiler Drum Level Control	1991	3	520,475 MBtu	(711927 MBtu/hr)	Good
B. Feedwater System					
8. Deserating Heater	1972	1	19,500 lb/hr		Good
12. Condensate Pumps	1972	1	1.5 Hp		Good
12. Condensate Pumps	1990	2	1.5 Hp		Good
13. Condensate Receiver	1972	1	500 gal		Good
14. Boiler Feed Pumps	1972	3	10 Hp	(1-turbine, 2-motor)	Good
19. Feedwater Piping System (valve)	1972/1991		2 diam (in.)	160 psig	Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1972	1	20000 gal		Good
4. Fuel Oil Pump	1972	6	20 gpm	(1.5 Hp)	Good
6. Fuel Oil Piping System (BLW)	1972		1.5 diam (in.)	(narrows to 0.5)	Good
7. Natural Gas Piping System (BLW)	1972		4 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	Outside Pit (-6'x6'x6')				Good
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1972	3	20 diam (in.)	32 height (ft)	
F. Combustion Controls					
1. Plant Master	1991	1			Good
2. Boiler Master	1991	3			Good
3. Flame Safeguard System	1985	3			Good
4. Furnace Draft Control (DAMPACT)	1991	3			Good

Table 16a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1972	5	30 gal	0.333 Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1972	1	58 gpm		Good
I. Condensate Puhishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1989	1	250 SCFM	(50 Hp)	Good
1. Air Compressor (RECIP)	1991	1	250 SCFM	(25 Hp)	Good
2. Air Dryer (REFR)	1972	2	250 SCFM		Good
3. Air Receiver	1972	1	100 gal		Good
K. Electrical System					
1. Transformer/TransPCB	1972	3	75 KVA		Good
2. Switchgear - Main Circuit Breaker	1972	1	600 amps		
3. Motor Control Center/Starter	1972	—	—		
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1972				Good
2. Building Concrete and Building Steel	1972				Good
4. Building Lighting	1972				Good
Building Outside Dimensions		Ht (ft)	Lgth (ft)	Width (ft)	
Building Basement (Yes/No)	No		2530 sq ft		
Building Size					

Table 16a

**Status Quo Life-Cycle Cost Analysis
for Fort Campbell Bldg. 7223**

LIFE CYCLE COST ANALYSIS		STUDY: TDCAM4
LCCID 1.065	DATE/TIME:	05-14-92 15:50:22
PROJECT NO., FY, & TITLE:	FY 1992	BUILDING 7223
INSTALLATION & LOCATION:	FORT CAMPBELL	KENTUCKY
DESIGN FEATURE:		
ALT. ID. A;	TITLE: STATUS QUO	
NAME OF DESIGNER:		

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS)	MAY 92
MIDPOINT OF CONSTRUCTION (MPC)	JUN 92
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 93
ANALYSIS END DATE (AED)	JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL	TIME(S)
DESCRIPTION	IN DOS \$	ESCALATION RATE	COST INCURRED
	(\$ X 10**0)	(% PER YEAR)	
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	7526.5	1.58	JUL93-JUL17
NATURAL GAS	73999.5	3.64	JUL93-JUL17
MAINT LABOR	85600.0	.00	JUL93-JUL17
MAINT SERV	4054.0	.00	JUL93-JUL17
MAINT SUPPLY	30000.0	.00	JUL93-JUL17
MAINT UTIL	20270.0	.00	JUL93-JUL17
STACK	12500.0	.00	JAN 12
DRUMCTL	15000.0	.00	JAN 11
ECONOMIZER	35000.0	.00	JAN 92
F_FAN	21000.0	.00	JAN 12
RELVALVE	3096.0	.00	JAN 92
RELVALVE	3072.0	.00	JAN 92
WTBOILER	1800000.0	.00	JAN 12
WTBURNER	150000.0	.00	JAN 12
PUMPSIMPLEX	15000.0	.00	JAN 92
TANKPOLY	1000.0	.00	JAN 92
FLAMESAFE	30000.0	.00	JAN 15
AIRCOMPRECIP	39000.0	.00	JAN 11
AIRCOMPRECIP	48000.0	.00	JAN 09
AIRDYERREFR	40000.0	.00	JAN 87
AIRREC	600.0	.00	JAN 02
SWITCH	14667.0	.00	JAN 12
CONDPUMP	3625.0	.00	JAN 92
CONDPUMP	7250.0	.00	JAN 10
CONDREC	14000.0	.00	JAN 02
DAIRHEATER	25000.0	.00	JAN 12
FEEDPUMP	42000.0	.00	JAN 02
FWPIPINGVAL	3339.0	.00	JAN 92
NAGPIPEBELOW	23.0	.00	JAN 97

Table 14a (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:50:22
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 7223
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

OILPIPEBELOW	25.0	.00	JAN 97
PUMP	7800.0	.00	JAN 97
TANKBELOW	26000.0	.00	JAN 02
FLASHTANK	1730.0	.00	JAN 97
SZSOFT	75200.0	.00	JAN 92

OTHER KEY INPUT DATA

LOCATION - KENTUCKY CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	4.04 1863.0		JAN93-JAN18
NAT G	2.99 24749.0		JAN93-JAN18

Table 16b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:50:22
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 7223
 INSTALLATION & LOCATION: PORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	129616.
NATURAL GAS	1616778.
TOTAL ENERGY COSTS	1746394.
RECURRING M&R/CUSTODIAL COSTS	2038296.
MAJOR REPAIR/REPLACEMENT COSTS	956777.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	4741467.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 16b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:50:22
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 7223
 INSTALLATION & LOCATION: PORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	7201.	71038.	132772.	0.	0.
2	6889.	68971.	126933.	0.	0.
3	6571.	66121.	121351.	0.	0.
4	6280.	63214.	116014.	0.	0.
5	6010.	60935.	110912.	7765.	0.
6	5781.	59133.	106034.	0.	0.
7	5646.	59492.	101371.	0.	0.
8	5549.	60814.	96913.	0.	0.
9	5469.	62668.	92651.	0.	0.
10	5413.	65631.	88577.	53478.	0.
11	5356.	67682.	84681.	0.	0.
12	5292.	68378.	80957.	0.	0.
13	5225.	69845.	77397.	0.	0.
14	5131.	70635.	73993.	0.	0.
15	5019.	70941.	70739.	0.	0.
16	4884.	70175.	67629.	0.	0.
17	4736.	68457.	64654.	22684.	0.
18	4573.	67536.	61811.	3276.	0.
19	4430.	65866.	59093.	23324.	0.
20	4315.	64152.	56494.	835427.	0.
21	4207.	62550.	54010.	0.	0.
22	4092.	60840.	51634.	0.	0.
23	3976.	59119.	49364.	10824.	0.
24	3847.	57205.	47193.	0.	0.
25	3725.	55380.	45117.	0.	0.
***	129616.	1616778.	2038296.	956777.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 17a

Boiler Evaluation Parts List—Fort Campbell Bldg. 858

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (FT)					
1. Boiler Pressure Parts and Setting	1986	2	11.716 MBtu/hr		Good
2. Relief Valve(s)	1990	2	100 psig	333 temp	Good
2. Relief Valve(s)	1990	2	2.5 in.	150 psig	Good
3. Feedwater Regulator(s)	1986	2	1.5 in.	150 psig	Good
4. Boiler Burner(s)	1986	2	1.5 in.	160 psig	Good
5. Boiler Fan(s) (FD)	1986	2	14645 MBtu		Good
7. Boiler Drum Level Control	1986	2	15 Hp		Good
B. Feedwater System					
8. Deserating Heater	1986	1	35375 lb/hr		
12. Condensate Pumps	1986	1	3 Hp		Good
14. Boiler Feed Pumps	1986	2	7.5 Hp		Good
15. Make-up Pumps	Base water supply pressure				
19. Feedwater Piping System (valve)	1986		2 diam (in.)	160 psig	Good
21. HTW Distribution System Pumps	Base water pressure				
C. Fuel Handling System					
2. Fuel Oil Tank - Above ground	1986	1	15000 gal		Good
4. Fuel Oil Pump	1986	2	18 gpm	(0.5 Hp)	
6. Fuel Oil Piping System (BLW)	1986		2 diam (in.)	(narrows to 0.5)	Good
7. Natural Gas Piping System (BLW)	1986		4 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	Outside Pit		diam (ft)	height (ft)	Good
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1942	1	20 diam (in)	24'2" height (ft)	
F. Combustion Controls					
3. Flame Safeguard System	1986	2			Good
4. Furnace Draft Control (DAMPACT)	1986	2			Good
5. Additional Boiler Instrumentation/Indicators	1986	2	O2 TRIM		Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1986	4	55 gal	0.333 Hp	Good

Table 17a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
H. Make-up Water System					
9. Sodium Zeolite Softener	1991	1	200 gpm		
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1990	1	3.4 SCFM	(2 Hp)	Good
3. Air Receiver	1990	1	30 gal		
K. Electrical System					
1. Transformer/TransPCB		3	25 KVA		Good
2. Switchgear -- Main Circuit Breaker	1986	1	200 amps		
3. Motor Control Center/Starter			amps		
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1986				Good
2. Building Concrete and Building Steel	1986				Good
4. Building Lighting	1986				Good
Building Outside Dimensions		Ht (ft)	Lgth (ft)	Width (ft)	
Building Basement (Yes/No)	No				
Building Size			3808 sq ft		

Table 17b

**Status Quo Life-Cycle Cost Analysis
for Fort Campbell Bldg. 858**

LIFE CYCLE COST ANALYSIS **STUDY: TDCAMS**
 LCCID 1.065 **DATE/TIME: 05-14-92 15:53:27**
PROJECT NO., FY, & TITLE: **FY 1992 BUILDING 858**
INSTALLATION & LOCATION: **FORT CAMPBELL KENTUCKY**
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) **MAY 92**
MIDPOINT OF CONSTRUCTION (MPC) **JUN 92**
BENEFICIAL OCCUPANCY DATE (BOD) **JAN 93**
ANALYSIS END DATE (AED) **JAN 18**

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$	RATE	COST INCURRED
	(\$ X 10**0)	(% PER YEAR)	
=====	=====	=====	=====
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	13029.0	1.58	JUL93-JUL17
NATURAL GAS	128088.6	3.64	JUL93-JUL17
MAINT LABOR	94000.0	.00	JUL93-JUL17
MAINT SERV	6333.0	.00	JUL93-JUL17
MAINT SUPPLY	46864.0	.00	JUL93-JUL17
MAINT UTIL	31665.0	.00	JUL93-JUL17
DRUMCTL	10000.0	.00	JAN 06
FTBOILER	120000.0	.00	JAN 11
FTBURNER	100000.0	.00	JAN 11
RELVALVE	3400.0	.00	JAN 10
RELVALVE	4300.0	.00	JAN 10
PUMPSIMPLEX	12000.0	.00	JAN 06
TANKPOLY	800.0	.00	JAN 06
DAMPACT	2000.0	.00	JAN 16
FLAMESAFE	20000.0	.00	JAN 16
O2TRIM	20000.0	.00	JAN 16
AIRCOMPRECIP	20000.0	.00	JAN 10
CONDPUMP	4000.0	.00	JAN 06
FEEDPUMP	28000.0	.00	JAN 16
FWPIPINGVAL	2226.0	.00	JAN 06
NAGPIPEBELOW	23.0	.00	JAN 11
OILPIPEBELOW	25.0	.00	JAN 11
PUMP	2600.0	.00	JAN 11
SZSOFT	135000.0	.00	JAN 11
=====	=====	=====	=====

Table 17b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:53:27
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 858
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

OTHER KEY INPUT DATA

LOCATION - KENTUCKY CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	4.04 3225.0		JAN93-JAN18
NAT G	2.99 42839.0		JAN93-JAN18

Table 17b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:53:27
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 858
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	224376.
NATURAL GAS	2798544.
TOTAL ENERGY COSTS	3022920.
RECURRING M&R/CUSTODIAL COSTS	2605513.
MAJOR REPAIR/REPLACEMENT COSTS	673316.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	6301749.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 17b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 15:53:27
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 858
 INSTALLATION & LOCATION: FORT CAMPBELL KENTUCKY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	12465.	122963.	169719.	0.	0.
2	11926.	119384.	162255.	0.	0.
3	11374.	114452.	155120.	0.	0.
4	10872.	109419.	148298.	0.	0.
5	10403.	105474.	141777.	0.	0.
6	10008.	102356.	135542.	0.	0.
7	9773.	102976.	129581.	0.	0.
8	9605.	105265.	123882.	0.	0.
9	9467.	108475.	118434.	0.	0.
10	9370.	113603.	113226.	0.	0.
11	9272.	117153.	108247.	0.	0.
12	9161.	118358.	103486.	0.	0.
13	9044.	120897.	98935.	0.	0.
14	8883.	122265.	94584.	15698.	0.
15	8688.	122795.	90425.	0.	0.
16	8455.	121469.	86448.	0.	0.
17	8199.	118495.	82646.	0.	0.
18	7917.	116901.	79012.	12515.	0.
19	7668.	114010.	75537.	620957.	0.
20	7469.	111044.	72215.	0.	0.
21	7282.	108270.	69039.	0.	0.
22	7083.	105311.	66003.	0.	0.
23	6883.	102332.	63101.	0.	0.
24	6660.	99018.	60326.	24146.	0.
25	6447.	95859.	57673.	0.	0.
***	224376.	2798544.	2605513.	673316.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 18

CHPECON Run Results for Fort Campbell, Bldg. 7008

Technology (New Plant)	Boiler	\$/MBtu	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
GAS	21/21/21	10.565	12.631	4400	17161	28894	100
#2 OIL	21/21/21	12.216	14.605	4400	21677	33410	116
#6 OIL	21/21/21	12.680	15.161	4400	22947	34680	120
STOKER	15/25/25/25	24.347	29.109	35693	9360	66587	230
CWS	13/25/32/32	20.018	23.933	24269	13190	57211	198
COM	15/26/26/26	20.916	25.007	20867	20198	59778	207
FBC	12/23/29/29	24.023	28.721	33204	10837	65699	227
FILE PREFIX: FCB1		1@ 12.5 L					
PMCR: 63 L		FUEL = NG,FS2					
AVE MON. LOAD: 21 M		AGE = 1958					
CHP #1 2@ 25.1 L		L=(K# STEAM/HR)					
FUEL = NG,FS2		M=(MBTU/HR)					
AGE = 1985							

Table 19

CHPECON Run Results for Fort Campbell, Bldg. 7008

Technology (New Plant)	Boiler	\$/MBtu	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
GAS	39/39/39	8.933	10.680	5495	30835	44209	100
#2 OIL	39/39/39	10.584	12.654	5495	39006	52381	118
#6 OIL	39/39/39	11.049	13.210	5495	41305	54679	124
STOKER	26/45/45/45	16.817	20.106	42349	15622	83224	188
CWS	23/45/58/58	14.684	17.556	31094	23159	75940	172
COM	28/47/47/47	15.628	18.685	25296	35545	80823	183
FBC	21/42/53/53	17.108	20.455	39995	19198	84667	192
FILE PREFIX: FCB2		FUEL = NG,FS2					
PMCR: 115 L		AGE = 1976					
AVE MON. LOAD: 38 M		L = (K# STEAM/HR)					
CHP #2 1@ 15 L		M = (MBTU/HR)					

Table 20

**Cost Sensitivity Analysis for
a Gas-/Oil-Fired Boiler Plant**

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: FCB Type: New plant (NP)

04/29/92

Desc: FORT CAMPBELL

Tech: Gas / Oil Fired Boiler

Base and Plant Information

State: KY - Kentucky

Base DOE Region: 3

PMCR: 248,000 lb/hr steam

Number of boilers: 3

Height of the plant: 40 ft

Building area: 9000 sq ft

Plant area: 1.97 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 1,107,534 kW-hr

1991 cost for distillate: 0.631 \$/gallon

1991 cost for residual: 0.400 \$/gallon

1991 cost for natural gas: 2.722 \$/million Btu

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 504,528 thousand lb steam

Annual #6 Fuel Oil Usage: 4,419 10³ gal

Heating plant efficiency: 87.8% #6 fuel oil

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 1,659,820	Stack:	\$ 32,911
Building/service:	\$ 1,375,970	Water trtmnt:	\$ 909,326
Feedwtr pmps:	\$ 30,866	Cond xfr pmps:	\$ 31,970
Cond strg tnk:	\$ 8,326	Oil (long) storage:	\$ 338,767
Oil day strg pmp:	\$ 5,015	Oil heaters:	\$ 8,828
Oil day strg tanks:	\$ 22,024	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 6,425	Fire protection:	\$ 52,241
Cont bldn tnk:	\$ 1,170	Intr bldn tnk:	\$ 1,170
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 22,202	Site preparation:	\$ 5,145
Site improvements:	\$ 234,040	Mobile equipment:	\$ 40,748
Elec substation:	\$ 71,047	Electrical:	\$ 196,557
Piping:	\$ 1,113,824	Instrumentation:	\$ 411,834
Direct costs:	\$ 2,445,479		

Table 20 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FCB Type: New plant (NP)
 Desc: FORT CAMPBELL
 Tech: Gas / Oil Fired Boiler

Page 2
 04/29/92

 Facility Capital Costs, cont

Plant installed cost: \$ 10,005,382

 Facility Annual O & M and Energy Costs

Operating staff: 11

Annual Labor Costs: \$ 463,732

Annual Year Non-Labor O & M Costs : \$ 636,375

1995 #6 fuel oil costs : \$ 2,375,110

1995 Auxiliary Energy Costs : \$ 58,831

 Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 6,545
10 years	\$ 380,276	15 years	\$ 111,936
18 years	\$ 12,788	20 years	\$ 14,981

 Facility Life Cycle Cost Summary

Analysis using #6 fuel oil as primary fuel

+ PV 'Adjusted' Investment Costs	= \$ 8,717,534
+ PV Energy + Transportation Costs	= \$ 46,049,710
+ PV Annually Recurring O&M Costs	= \$ 8,038,518
+ PV Non-Annually Recurring Repair & Replacement	= \$ 533,848
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991) = \$ 63,339,610

Levelized Cost of Service (1995 start) = 8.6855 \$/MMBtu

Levelized Cost of Service (1995 start) = 10.384 \$/1000 lb steam

 Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	22,623,314	40,716,296	6.675
60%	27,147,976	45,240,959	7.417

Table 20 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FCB Type: New plant (NP)
 Desc: FORT CAMPBELL
 Tech: Gas / Oil Fired Boiler

Page 3
 04/29/92

 Sensitivity Analysis, cont

80%	36,197,302	54,290,285	8.900
90%	40,721,965	58,814,948	9.642
100%	45,246,628	63,339,610	10.384
110%	49,771,290	67,864,273	11.126
120%	54,295,953	72,388,936	11.868
130%	58,820,616	76,913,599	12.609
140%	63,345,279	81,438,262	13.351
150%	67,869,942	85,962,925	14.093

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	32,119,095	50,212,078	8.232
-2%	35,870,371	53,963,354	8.847
-1%	40,211,168	58,304,151	9.558
0%	45,246,628	63,339,610	10.384
1%	51,101,477	69,194,460	11.344
2%	57,923,694	76,016,677	12.462
3%	65,888,844	83,981,826	13.768
4%	75,205,203	93,298,186	15.296
5%	86,119,823	104,212,805	17.085
6%	98,925,680	117,018,663	19.184

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	642,465	63,178,994	10.358
90%	722,773	63,259,302	10.371
100%	803,081	63,339,610	10.384
110%	883,390	63,419,919	10.397
120%	963,698	63,500,227	10.410

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,695,839	62,165,650	10.191
90%	5,282,819	62,752,630	10.288
100%	5,869,799	63,339,610	10.384
110%	6,456,779	63,926,590	10.480
120%	7,043,759	64,513,570	10.576

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,734,974	62,905,867	10.313
90%	1,951,846	63,122,739	10.348
100%	2,168,718	63,339,610	10.384
110%	2,385,590	63,556,482	10.419

Table 20 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FCB Type: New plant (NP)
 Desc: FORT CAMPBELL
 Tech: Gas / Oil Fired Boiler

Page 4
 04/29/92

 Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	427,078	63,232,841	10.366
90%	480,463	63,286,226	10.375
100%	533,848	63,339,610	10.384
110%	587,233	63,392,995	10.393
120%	640,618	63,446,380	10.401

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	6,974,027	61,388,790	10.064
90%	7,845,780	62,364,200	10.224
100%	8,717,534	63,339,610	10.384
110%	9,589,287	64,315,021	10.544
120%	10,461,041	65,290,431	10.704

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0. Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-238,027	63,577,638	10.423
-10%	-158,684	63,498,295	10.410
-5%	-79,342	63,418,953	10.397
0%	0	63,339,610	10.384
5%	79,342	63,260,268	10.371
10%	158,684	63,180,926	10.358
15%	238,027	63,101,583	10.345

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	123,547,118	20.255
0.7%	110,712,626	18.151
1.7%	95,258,973	15.617
2.7%	82,563,411	13.536
3.7%	72,068,750	11.815
4.7%	63,339,610	10.384
5.7%	56,034,200	9.186
6.7%	49,882,942	8.178
7.7%	44,672,220	7.323
8.7%	40,231,975	6.595

Table 20 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FCB Type: New plant (NP)

04/29/92

Desc: FORT CAMPBELL

Tech: Gas / Oil Fired Boiler

 Sensitivity Analysis, cont

10.7%	33,145,571	5.434
11.7%	30,301,894	4.967
12.0%	29,522,925	4.840

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	34,427,574	10.465
11 yr	36,763,053	10.375
12 yr	39,059,039	10.319
13 yr	41,280,910	10.278
14 yr	43,437,935	10.252
15 yr	45,598,452	10.252
16 yr	47,634,079	10.246
17 yr	49,601,623	10.245
18 yr	51,523,849	10.253
19 yr	53,369,701	10.262
20 yr	55,296,760	10.301
21 yr	57,029,348	10.316
22 yr	58,689,452	10.331
23 yr	60,292,720	10.347
24 yr	61,846,207	10.365
25 yr	63,339,610	10.384

Table 21

**Cost Sensitivity Analysis for
a #6 Oil-Fired Boiler Plant**

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: FCB6 Type: New plant (NP)

05/04/92

Desc: FORT CAMPBELL

Tech: Gas / Oil Fired Boiler

Base and Plant Information

State: KY - Kentucky

Base DOE Region: 3

PMCR: 188,000 lb/hr steam

Number of boilers: 3

Height of the plant: 40 ft

Building area: 7500 sq ft

Plant area: 1.66 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 1,090,986 kW-hr

1991 cost for distillate: 0.631 \$/gallon

1991 cost for residual: 0.400 \$/gallon

1991 cost for natural gas: 2.722 \$/million Btu

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 504,528 thousand lb steam

Annual #6 Fuel Oil Usage: 4,419 10³ gal

Heating plant efficiency: 87.8% #6 fuel oil

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 1,394,832	Stack:	\$ 32,911
Building/service:	\$ 1,139,387	Water trtmnt:	\$ 638,409
Feedwtr pmps:	\$ 25,260	Cond xfr pmps:	\$ 25,078
Cond strg tnk:	\$ 7,177	Oil (long) storage:	\$ 275,721
Oil day strg pmp:	\$ 5,015	Oil heaters:	\$ 7,261
Oil day strg tanks:	\$ 19,147	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 5,642	Fire protection:	\$ 41,792
Cont bldn tnk:	\$ 1,013	Intr bldn tnk:	\$ 1,013
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 11,101	Site preparation:	\$ 4,336
Site improvements:	\$ 202,695	Mobile equipment:	\$ 40,748
Elec substation:	\$ 65,348	Electrical:	\$ 165,245
Piping:	\$ 936,393	Instrumentation:	\$ 346,229
Direct costs:	\$ 2,017,766		

Table 21 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FCB6 Type: New plant (NP)

05/04/92

Desc: FORT CAMPBELL

Tech: Gas / Oil Fired Boiler

Facility Capital Costs, cont

Plant installed cost: \$ 8,196,142

Facility Annual O & M and Energy Costs

Operating staff: 11

Annual Labor Costs: \$ 463,732

Annual Year Non-Labor O & M Costs : \$ 629,310

1995 #6 fuel oil costs : \$ 2,375,137

1995 Auxiliary Energy Costs : \$ 57,952

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 6,310
10 years	\$ 260,368	15 years	\$ 93,794
18 years	\$ 10,031	20 years	\$ 13,867

Facility Life Cycle Cost Summary

Analysis using #6 fuel oil as primary fuel

+ PV 'Adjusted' Investment Costs	= \$ 7,182,251
+ PV Energy + Transportation Costs	= \$ 47,378,979
+ PV Annually Recurring O&M Costs	= \$ 8,161,860
+ PV Non-Annually Recurring Repair & Replacement	= \$ 429,474
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991) = \$ 63,152,565

Levelized Cost of Service (1995 start) = 8.4196 \$/MMBtu

Levelized Cost of Service (1995 start) = 10.066 \$/1000 lb steam

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	23,283,222	39,869,342	6.355
60%	27,939,866	44,525,987	7.097

Table 21 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FCB6 Type: New plant (NP)

05/04/92

Desc: FORT CAMPBELL

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

80%	37,253,155	53,839,276	8.582
90%	41,909,799	58,495,920	9.324
100%	46,566,444	63,152,565	10.066
110%	51,223,088	67,809,209	10.808
120%	55,879,733	72,465,853	11.551
130%	60,536,377	77,122,498	12.293
140%	65,193,021	81,779,142	13.035
150%	69,849,666	86,435,787	13.777

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	32,964,116	49,550,236	7.898
-2%	36,847,862	53,433,983	8.517
-1%	41,345,360	57,931,480	9.234
0%	46,566,444	63,152,565	10.066
1%	52,641,459	69,227,579	11.034
2%	59,725,098	76,311,219	12.164
3%	68,000,951	84,587,072	13.483
4%	77,686,882	94,273,003	15.027
5%	89,041,388	105,627,509	16.837
6%	102,371,106	118,957,227	18.961

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	650,028	62,990,057	10.040
90%	731,281	63,071,311	10.053
100%	812,535	63,152,565	10.066
110%	893,788	63,233,818	10.079
120%	975,042	63,315,072	10.092

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,820,558	61,947,425	9.874
90%	5,423,128	62,549,995	9.970
100%	6,025,698	63,152,565	10.066
110%	6,628,268	63,755,134	10.162
120%	7,230,838	64,357,704	10.258

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,708,929	62,725,332	9.998
90%	1,922,545	62,938,948	10.032
100%	2,136,161	63,152,565	10.066
110%	2,349,777	63,366,181	10.100

Table 21 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FCB6 Type: New plant (NP)
 Desc: FORT CAMPBELL
 Tech: Gas / Oil Fired Boiler

Page 4
 05/04/92

 Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	343,579	63,066,670	10.052
90%	386,526	63,109,617	10.059
100%	429,474	63,152,565	10.066
110%	472,421	63,195,512	10.073
120%	515,368	63,238,459	10.080

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	5,745,801	61,536,946	9.809
90%	6,464,026	62,344,755	9.937
100%	7,182,251	63,152,565	10.066
110%	7,900,476	63,960,374	10.195
120%	8,618,701	64,768,183	10.324

=== Existing salvage value variation ===

Change PV Existing Salvage Life Cycle Cost LCS, \$/1000lb steam
 Existing plant salvage values specified is 0.
 Variation of value is unnecessary. Analysis skipped.

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-206,154	63,358,719	10.099
-10%	-137,436	63,290,001	10.088
-5%	-68,718	63,221,283	10.077
0%	0	63,152,565	10.066
5%	68,718	63,083,846	10.055
10%	137,436	63,015,128	10.044
15%	206,154	62,946,410	10.033

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	121,276,910	19.331
0.5%	111,988,476	17.851
1.5%	96,020,352	15.305
2.5%	82,925,881	13.218
3.5%	72,121,733	11.496
4.5%	63,152,565	10.066
5.5%	55,661,275	8.872
6.5%	49,366,496	7.869
7.5%	44,045,501	7.020
8.5%	39,521,155	6.299

Table 21 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FCB6 Type: New plant (NP)
 Desc: FORT CAMPBELL
 Tech: Gas / Oil Fired Boiler

Page 5
 05/04/92

 Sensitivity Analysis, cont

10.5%	32,324,231	5.152
11.5%	29,446,442	4.693
12.0%	28,152,497	4.487

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	33,190,969	9.914
11 yr	35,585,495	9.861
12 yr	37,944,153	9.835
13 yr	40,231,088	9.820
14 yr	42,455,587	9.816
15 yr	44,679,810	9.833
16 yr	46,787,281	9.844
17 yr	48,828,203	9.858
18 yr	50,824,912	9.879
19 yr	52,747,026	9.900
20 yr	54,713,756	9.941
21 yr	56,524,919	9.966
22 yr	58,263,642	9.990
23 yr	59,946,079	10.015
24 yr	61,579,432	10.041
25 yr	63,152,565	10.066

Table 22

**Cost Sensitivity Analysis for
a Coal-Fired Stoker Plant**

Central Heating Plant Economics Evaluation -- Sensitivity Analysis Page 1
 File: FCBC Type: New plant (NP) 05/04/92
 Desc: FORT CAMPBELL
 Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

 Base and Plant Information

State: KY - Kentucky Base DOE Region: 3
 PMCR: 188,000 lb/hr steam Number of boilers: 4

 Coal code: W193122 Distance from base: 140 miles
 State: IN - Indiana DOE Region: 2
 Coal type: bituminous (properties on a dry basis)
 hhv: 12830 Btu/lb fixed carbon: 52.10% volatiles: 37.60%
 ash: 10.30% sulfur: 2.80%

Coal handling equipment capacity: 100 tons/hr
 Coal silo storage capacity: 713 tons
 Approx. building width: 66 feet
 Approx. building length: 185 feet
 Height of the plant: 69 ft
 Building area: 12267 sq ft
 Plant area: 1.73 acres

 Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)
 Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)
 Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)
 Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual diesel/distillate fuel usage: 16,752 gallons
 Annual electricity usage: 3,722,308 kW-hr
 Annual lime usage: 2,878 tons

1991 cost for coal: 1.534 \$/MMBtu
 1991 cost for distillate: 0.631 \$/gallon
 1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 504,528 thousand lb steam
 Annual Coal Usage: 26,568 tons (dry) / 28,853 tons (wet)
 Heating plant efficiency: 84%
 Year of Study: 1991
 Years of Operation: 1995 - 2019

 Facility Installed Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 12,453,778	Coal Handling:	\$ 5,835,423
Ash Handling:	\$ 3,104,084	Mechncl Collector:	\$ 165,316

Table 22 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FCBC Type: New plant (NP)

05/04/92

Desc: PORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Installed Capital Costs, cont

Water Treatment:	\$	1,094,858	Pumps:	\$	243,908
Air Compressor:	\$	87,327	Waste Water Trtmnt:	\$	126,806
Piping/Stack:	\$	4,581,222	Electrical System:	\$	1,775,832
Building Costs:	\$	6,232,328	Direct costs:	\$	13,645,671

Plant installed cost:	\$	58,804,507			

Facility Annual O & M and Energy Costs

Operating staff: 27

Annual Labor Costs: \$ 1,123,756

First Year Non-Labor O & M Costs : \$ 1,880,194

Annual Year Non-Labor O & M Costs : \$ 2,252,342

1995 Coal Costs (incl transport) : \$ 1,253,165

1995 Auxiliary Energy Costs : \$ 210,604

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 110,659	5 years	\$ 102,452
7 years	\$ 110,032	8 years	\$ 293,999
10 years	\$ 703,809	12 years	\$ 56,841
15 years	\$ 13,894	18 years	\$ 20,058
20 years	\$ 710,697		

Facility Life Cycle Cost Summary

+ PV 'Adjusted' Investment Costs	= \$	51,530,190
+ PV Energy + Transportation Costs	= \$	21,016,342
+ PV Annually Recurring O&M Costs	= \$	28,954,663
+ PV Non-Annually Recurring Repair & Replacement	= \$	2,222,765
+ PV Disposal Cost of Existing System	= \$	0
+ PV Disposal Cost of New/Retrofit Facility	= \$	0

Total Life Cycle Cost (1991)	= \$	103,723,962

Levelized Cost of Service (1995 start) = 13.828 \$/MMBtu

Table 22 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FCBC Type: New plant (NP)

05/04/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	9,009,308	94,714,654	15.097
60%	10,811,170	96,516,515	15.384
70%	12,613,032	98,318,377	15.672
80%	14,414,893	100,120,239	15.959
90%	16,216,755	101,922,100	16.246
100%	18,018,617	103,723,962	16.533
110%	19,820,478	105,525,824	16.820
120%	21,622,340	107,327,686	17.108
130%	23,424,202	109,129,547	17.395
140%	25,226,064	110,931,409	17.682
150%	27,027,925	112,733,271	17.969

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	13,062,520	98,767,866	15.743
-2%	14,483,961	100,189,307	15.970
-1%	16,123,144	101,828,489	16.231
0%	18,018,617	103,723,962	16.533
1%	20,216,101	105,921,446	16.883
2%	22,769,827	108,475,172	17.291
3%	25,744,126	111,449,471	17.765
4%	29,215,305	114,920,651	18.318
5%	33,273,870	118,979,216	18.965
6%	38,027,145	123,732,490	19.723

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	2,398,180	103,124,417	16.438
90%	2,697,952	103,424,190	16.485
100%	2,997,725	103,723,962	16.533
110%	3,297,498	104,023,735	16.581
120%	3,597,270	104,323,507	16.629

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	11,681,587	100,803,565	16.068
90%	13,141,786	102,263,764	16.300
100%	14,601,984	103,723,962	16.533
110%	16,062,183	105,184,161	16.766
120%	17,522,381	106,644,359	16.999

=== O&M non-labor cost variation ===

Table 22 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FCBC Type: New plant (NP)

05/04/92

Desc: PORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis, cont

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	11,482,143	100,853,426	16.076
90%	12,917,411	102,288,694	16.304
100%	14,352,679	103,723,962	16.533
110%	15,787,947	105,159,230	16.762
120%	17,223,214	106,594,498	16.991

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,788,212	103,279,409	16.462
90%	2,000,488	103,501,686	16.498
100%	2,222,765	103,723,962	16.533
110%	2,445,042	103,946,239	16.569
120%	2,667,318	104,168,515	16.604

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	41,224,152	91,470,671	14.580
90%	46,377,171	97,597,317	15.557
100%	51,530,190	103,723,962	16.533
110%	56,683,209	109,850,608	17.510
120%	61,836,228	115,977,253	18.486

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0. Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-1,394,131	105,118,093	16.755
-10%	-929,420	104,653,383	16.681
-5%	-464,710	104,188,673	16.607
0%	0	103,723,962	16.533
5%	464,710	103,259,252	16.459
10%	929,420	102,794,542	16.385
15%	1,394,131	102,329,831	16.311

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	161,034,128	25.669
0.5%	152,193,988	24.259
1.5%	136,779,317	21.802

Table 22 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FCBC Type: New plant (NP)

05/04/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

 Sensitivity Analysis, cont

3.5%	112,985,027	18.009
4.5%	103,723,962	16.533
5.5%	95,786,505	15.268
6.5%	88,931,588	14.175
7.5%	82,967,545	13.225
8.5%	77,741,219	12.392
9.5%	73,129,595	11.656
10.5%	69,033,368	11.003
11.5%	65,371,960	10.420
12.0%	63,683,284	10.151

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	78,391,926	23.416
11 yr	80,478,563	22.303
12 yr	82,571,218	21.403
13 yr	84,500,351	20.626
14 yr	86,405,609	19.977
15 yr	88,286,870	19.430
16 yr	90,124,913	18.962
17 yr	91,770,364	18.528
18 yr	93,405,064	18.155
19 yr	94,927,739	17.816
20 yr	96,943,797	17.615
21 yr	98,429,824	17.355
22 yr	99,785,712	17.110
23 yr	101,090,300	16.888
24 yr	102,486,189	16.711
25 yr	103,723,962	16.533

Table 23

Fort Bragg Heating Plant Information

Plant	Boiler	Fuel	Reserve	Year Installed	Capacity (lb/hr)	In use	Rating	Energy Use Heat/Cool/ Process/Losses/ Internal/Pwr Gen
4-3124	1	Nat. Gas	FS6	1972	37850	Y	8	H
4-3124	2	Nat. Gas	FS6	1972	37850	Y	8	H
4-3124	3	Nat. Gas	FS6	1952	50000	Y	6	H
C-1432	1	Nat. Gas	FS6	1953	100000	Y	8	H
C-1432	2	Nat. Gas	FS6	1953	100000	Y	7	H
C-1432	3	Nat. Gas	FS6	1953	100000	Y	7	H
C-7549	1	Nat. Gas	FS2	1973	50000	NO	5	H
C-7549	2	Nat. Gas	FS2	1973	50000	NO	5	H
D-3529	1	Nat. Gas	FS6	1965	26000	Y	4	H/C 60/40
D-3529	2	Nat. Gas	FS6	1965	26000	Y	4	H/C 60/40
D-3529	3	Nat. Gas	FS6	1965	26000	Y	6	H/C 60/40
D-3529	4	Nat. Gas	FS6	1969	26000	Y	8	H/C 60/40
D-3529	5	Nat. Gas	FS6	1978	26000	Y	8	H/C 60/40
E-2823	1	Nat. Gas	FS2	1988	20000	Y	9	H/C 60/40
E-2823	2	Nat. Gas	FS2	1988	20000	Y	9	H/C 60/40
N-6002	1	Nat. Gas	FS6	1985	25000	Y	9	?
N-6002	2	Nat. Gas	FS6	1985	25000	Y	9	?

Table 24
Fort Bragg Energy Use Data

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 Use	\$/MBtu	MBtu '90	MBtu '89
Dist. oil	gal	138700	1.03	4309368	3667440	7.43	508674	597709
Res. oil	gal	149700	0.99	708876	1005564	6.61	150533	106119
Nat. gas	Total NAG use:							
Interr.	bcof	1031000	4.64	1142170	943459	4.50	972706	1177577
Unintr.	bcof	1031000	4.04			3.92		
Building:								
Capacity (lb/hr):								
SQ file:								
Annual Costs								
Labor		207900	134400	323400	134400	122500		
Utilities*		175676	54054	405405	67568	54054		
Service*		35135	10811	81081	13514	10811		
Supplies*		248000	80000	500000	100000	80000		
Average steam production, 1990 (lb/hr):								
October		22129.8	5572.0	57170.0	5427.0	12243.1		
November		29118.1	7105.0	61100.0	8100.0	13617.8		
December		41597.3	11457.5	79020.0	15013.0	11684.7		
January		32113.1	10964.0	87280.0	13200.0	16265.0		
February		34026.6	7362.5	72170.0	7508.0	16447.0		
March		33111.5	6679.0	71810.0	6177.0	15064.0		
April		28119.8	7656.0	69150.0	8397.0	13175.0		
May		29534.1	6636.5	59400.0	7333.0	11158.0		
June		29534.1	5389.0	44750.0	6303.0	10300.0		
July		34276.2	4610.0	40300.0	5190.0	9442.0		
August		31198.0	4333.0	38830.0	4783.0	10729.0		
September		30782.0	4596.5	41920.0	5001.0	9013.0		
Fuel energy, based on steam production, 1990 (MBtu):								
October		19836.8	4994.7	51246.4	4864.7	10974.5		
November		25259.1	6163.4	53002.4	7026.5	11813.0		
December		37287.3	10270.3	70832.4	13457.4	10474.0		
January		28785.8	9828.0	78236.5	11832.3	14579.7		
February		27549.3	5961.0	58431.6	6078.8	13316.1		
March		29680.7	5987.0	64369.4	5537.0	13503.2		

* = estimated

Table 24 (Cont'd)

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 Use	\$/Mbtu	Mbtu '89	Mbtu '90
Fuel energy, based on steam production, 1990 (Mbtu) (cont'd):								
April		24393.1	6641.3	59985.5	7284.1	11428.9		
May		26473.9	5948.9	53245.3	6573.1	10001.9		
June		25620.1	4674.8	38819.3	5467.7	8934.9		
July		30724.9	4132.3	36124.3	4652.2	8463.7		
August		27965.4	3884.0	34806.7	4287.4	9617.3		
September		26702.5	3987.3	36364.3	4338.2	7818.5		
Total		330278.5	72473.0	635464.2	81399.5	130925.8	1250841	
Percent of total		26.4	5.8	50.8	6.5	10.5		
Reserve fuel		#6	#2	#6	#6	#6		
Fuel use (Mbtu/year):								
Natural Gas		307159.0	67399.9	590981.7	75701.6	121761.0	Total	1163003
Dist. Oil		0.0	5073.1	0.0	0.0	0.0		5073
Res. Oil		23119.5	0.0	44482.5	5698.0	9164.8		82465
Total \$/yr:		2803775	752324.4	5421652	842176	11145196		
\$/Mbtu:								
Labor		0.63	1.85	0.51	1.65	0.94		
Utilities		0.53	0.75	0.64	0.83	0.41		
Service		0.11	0.15	0.13	0.17	0.08		
Supplies		0.75	1.10	0.79	1.23	0.61		
Fuel		5.43	5.43	5.43	5.43	5.43	Average	8.20
Total \$/Mbtu		7.45	9.29	7.50	9.31	7.48		

* = estimated

Table 25a

Boiler Evaluation Parts List—Fort Bragg Bldg. 1432

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)	1958	3	100 MBtu/hr		Fair
1. Boiler Pressure Parts and Setting				400 temp	Fair
2. Relief Valve(s)	1958	6	150 psig	180 psig	Fair
3. Feedwater Regulator(s)	1958	3	6 in.	350 psig	Fair
4. Boiler Burner(s)	1975	3	3 in.		Fair
5. Boiler Fan(s) (FD)	1958	3	MBtu		Fair
5. Boiler Fan(s) (ID)	1958	3	40 Hp		Fair
6. Boiler Economizer	Not in Service	3	125 Hp		Fair
7. Boiler Drum Level Control	1958	3	MBtu		Fair
B. Feedwater System					
8. Desaerating Heater	1958	1	165 lb/hr		Fair
9. Feedwater Heater	1958	1	200 gpm		Fair
10. Treated Water Storage	1958	1	20000 gal		Fair
11. Treated Water Storage Pumps	1958	1	25 Hp		Fair
12. Condensate Pumps	1958	3	10 Hp		Fair
13. Condensate Receiver	1958	1	500 gal		Fair
14. Boiler Feed Pumps	1991	3	60 Hp		Fair
19. Feedwater Piping System (valve)			6 diam (in.)	psig	Fair
C. Fuel Handling System					
1. Fuel Oil Unloading Pump	1975	4	10 Hp		Good
2. Fuel Oil Tank - Above ground	1975	1	50000 gal		Good
3. Fuel Oil Tank - Above ground	1975	1	20000 gal	(110 lb oil at 220 F)	Good
4. Fuel Oil Pump	1991	1	gpm		
5. Fuel Oil Heater	1991	1	gpm		
6. Fuel Oil Piping System (ABV)	1975		1.25 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1975		4 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	1958	1	2.5 diam (ft)	5 height (ft)	Good
2. Blowdown Heat Exchanger	1958	1	20 gpm		Good
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1975	3	4.333 diam (ft)	65 height (ft)	Good

Table 25a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1958	3			Good
2. Boiler Master	1991	3			Good
3. Flame Safeguard System	1991	3			Good
4. Furnace Draft Control (DAMPACT)	1990	3			Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1975	2	50 gal	0.5 Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1975	2	60 gpm		Good
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1975	3	SCFM	(15 Hp)	Good
2. Air Dryer (REPR)	1975	1	10 SCFM		Good
3. Air Receiver	1975	1	100 gal		Good
K. Electrical System					
1. Transformer/TransPCB	1958	1	KVA	(175 kW)	Good
2. Switchgear -- Main Circuit Breaker	1958	1	amps		Good
3. Motor Control Center/Starter	1958	1	amps		Good
4. Emergency Generator	1958	1	KVA		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1958	—	—	—	Good
2. Building Concrete and Building Steel	1958	—	—	—	Good
3. Sump Pump (SUBMERGE/VERTICAL)	1975	3	gpm	(3 Hp)	Good
4. Building Lighting	1958	—	—	—	Good
Building Outside Dimensions	—	Ht (ft)	Length (ft)	Width (ft)	
Building Basement (Yes/No)	—	—	—	—	

Table 25b

**Status Quo Life Cycle Cost Analysis
for Fort Bragg Bldg C-1432**

LIFE CYCLE COST ANALYSIS **STUDY: TDBRG3**
 LCCID 1.065 DATE/TIME: 05-15-92 09:46:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING C-1432
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) MAY 92
 MIDPOINT OF CONSTRUCTION (MPC) JUN 92
 BENEFICIAL OCCUPANCY DATE (BOD) JAN 93
 ANALYSIS END DATE (AED) JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	COST INCURRED
=====	=====	=====	=====
INVESTMENT COSTS	.0	.00	JUN 92
RESIDUAL OIL	294032.6	2.11	JUL93-JUL17
NATURAL GAS	2659419.0	3.64	JUL93-JUL17
MAINT LABOR	323400.0	.00	JUL93-JUL17
MAINT SERV	81081.0	.00	JUL93-JUL17
MAINT SUPPLY	500000.0	.00	JUL93-JUL17
MAINT UTIL	405405.0	.00	JUL93-JUL17
STACK	20000.0	.00	JAN 15
DRUMCTL	15000.0	.00	JAN 98
ECONOMIZER	345000.0	.00	JAN 98
FW_REG	4251.0	.00	JAN 98
F_FAN	50250.0	.00	JAN 98
I_FAN	105000.0	.00	JAN 98
RELVALVE	11910.0	.00	JAN 98
WTBOILER	4500000.0	.00	JAN 98
WTBURNER	350001.0	.00	JAN 15
PUMPSIMPLEX	6000.0	.00	JAN 95
TANKPOLY	400.0	.00	JAN 95
PLANTMASTER	15000.0	.00	JAN 98
AIRCOMPRECIP	60000.0	.00	JAN 95
AIRDRYERREPR	12000.0	.00	JAN 95
AIRREC	600.0	.00	JAN 05
EMERGENCYGEN	158454.0	.00	JAN 98
MOTORCTRL	3400.0	.00	JAN 98
SWITCH	21000.0	.00	JAN 98
CONDUMP	16500.0	.00	JAN 98
CONDREC	14000.0	.00	JAN 98
DAIRHEATER	25000.0	.00	JAN 98
FWHEATER	30000.0	.00	JAN 98
FWPIPINGVAP.	1400.0	.00	JAN 98

Table 25b (Cont'd)

LCCID 1.065 DATE/TIME: 05-15-92 09:46:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING C-1432
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

TREATPUMP	7000.0	.00	JAN 98	
WATERSTOR	38000.0	.00	JAN 98	
NAGPIPEBELOW	23.0	.00	JAN 00	
PUMP	2500.0	.00	JAN 16	
TANKABOVE	120000.0	.00	JAN 15	
TANKABOVE	210000.0	.00	JAN 15	
UNLOADPUMP	20000.0	.00	JAN 95	
FLASHTANK	1200.0	.00	JAN 98	
HEATEXCH	1600.0	.00	JAN 98	
SZSOFT	153000.0	.00	JAN 95	
SUMPPUMPVERT	14700.0	.00	JAN 00	

=====

OTHER KEY INPUT DATA

LOCATION - NORTH CAROLINA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
RESID	6.61 44483.0		JAN93-JAN18
NAT G	4.50 590982.0		JAN93-JAN18

Table 25b (Cont'd)

LCCID 1.065 DATE/TIME: 05-15-92 09:46:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING C-1432
 INSTALLATION & LOCATION: PORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 0.

ENERGY COSTS:

RESIDUAL OIL 5453950.
 NATURAL GAS 58104310.

TOTAL ENERGY COSTS 63558260.

RECURRING M&R/CUSTODIAL COSTS 19081330.

MAJOR REPAIR/REPLACEMENT COSTS 4644441.

OTHER O&M COSTS & MONETARY BENEFITS 0.

DISPOSAL COSTS/RETENTION VALUE 0.

LCC OF ALL COSTS/BENEFITS (NET PW) 87284020.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 25b (Cont'd)

LCCID 1.065 DATE/TIME: 05-15-92 09:46:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING C-1432
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	RESID	NAT G	M & R	R / R	OTHER
1	289339.	2552991.	1242930.	0.	0.
2	282634.	2478697.	1188269.	0.	0.
3	274722.	2376293.	1136013.	222988.	0.
4	263291.	2271791.	1086054.	0.	0.
5	251094.	2189888.	1038293.	0.	0.
6	241110.	2125145.	992632.	4157252.	0.
7	235905.	2138032.	948979.	0.	0.
8	232672.	2185542.	907245.	10429.	0.
9	230105.	2252200.	867347.	0.	0.
10	228518.	2358659.	829204.	0.	0.
11	226912.	2432362.	792738.	0.	0.
12	224740.	2457396.	757876.	0.	0.
13	222426.	2510106.	724547.	339.	0.
14	218751.	2538505.	692683.	0.	0.
15	213961.	2549517.	662221.	0.	0.
16	207937.	2521985.	633098.	0.	0.
17	201161.	2460229.	605257.	0.	0.
18	194225.	2427141.	578639.	0.	0.
19	188164.	2367120.	553192.	0.	0.
20	183268.	2305527.	528865.	0.	0.
21	178690.	2247943.	505607.	0.	0.
22	173806.	2186493.	483372.	0.	0.
23	168890.	2124649.	462114.	252569.	0.
24	163421.	2055847.	441792.	862.	0.
25	158207.	1990255.	422363.	0.	0.
***	5453950.	*****	*****	4644441.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 26a

Boiler Evaluation Parts List-Fort Bragg Bldg. D-3529

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)	1965	3	26 MBtu/hr		2 Fair, 1 Good
A. Boiler (WT)	1969	1	26 MBtu/hr		Good
A. Boiler (WT)	1970	1	26 MBtu/hr		Good
1. Boiler Pressure Parts and Setting			240 psig	400 temp	Good
2. Relief Valve(s)	65,69,70	5	2 in.	375 psig	Good
2. Relief Valve(s)	65,69,70	5	2 in.	385 psig	Good
3. Feedwater Regulator(s)			in.	—	Good
4. Boiler Burner(s)	65,69,70	5	26 MBtu		Good
5. Boiler Fan(s) (FD)	65,69,70	5	10 Hp		Good
7. Boiler Drum Level Control	Visual				
B. Feedwater System					
8. Deserating Heater	1965	1	10000 lb/hr		Good
15. Make-up Pumps	1972	1	7.5 Hp		Good
15. Make-up Pumps	1990	1	7.5 Hp		Good
18. Expansion Tank	1965	1	70 diam (in.)	27 length (ft)	Good
19. Feedwater Piping System (valve)	1965	1	2 diam (in.)	232 psig	Good
20. Cooling Water Pumps	1965	1	300 Hp		Fair
20. Cooling Water Pumps	1969	1	150 Hp		Fair
21. HTW Distribution System Pumps	1965	2	30 Hp		Good
21. HTW Distribution System Pumps	1965	2	50 Hp		Good
21. HTW Distribution System Pumps	1969	2	75 Hp		Good
21. HTW Distribution System Pumps	1970	1	100 Hp		Good
21. HTW Distribution System Pumps	1991	1	40 Hp		Good
C. Fuel Handling System					
2. Fuel Oil Tank - Above ground	1965	2	50000 gal		Good
3. Fuel Oil Tank - Above ground	1970	4	50000 gal		Good
4. Fuel Oil Pump	1965	2	15 gpm		Good
5. Fuel Oil Heater	1965	2	100 gpm		Good
6. Fuel Oil Piping System (BLW)	1965		5 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1965		5 diam (in.)		Good
D. Heat Recovery System					
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	—	—	— diam (ft)	— height (ft)	

Table 26a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1965	1			Good
2. Boiler Master	65,69,70	5			Good
3. Flame Safeguard System	65,69,70	5			Good
5. Additional Boiler Instrumentation/Indicators	1965		O2 TRIM, FLOWMETER, TEMPREC (O2 trim inoperable)		Recorders Poor
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps			gal	Hp	
H. Make-up Water System					
9. Sodium Zeolite Softener	1965	2	31 gpm		Good
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIPI)	1965	1	100 SCFM	(10 Hp)	Good
1. Air Compressor (RECIPI)	1991	1	100 SCFM	(10 Hp)	Good
2. Air Dryer (REFR)	1982	1	200 SCFM		Good
3. Air Receiver	1965	1	80 gal		Good
Soot blower Compressor	1965	1	25 gal		Fair
Soot blower Receiver	1965	1	80 gal	(4'x8')	Good
K. Electrical System					
1. Transformer/TransPCB			KVA		
2. Switchgear -- Main Circuit Breaker			amps		
4. Emergency Generator	1965	1	75 KVA		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1965				Good
2. Building Concrete and Building Steel	1965				Good
3. Sump Pump (SUBMERGE/VERTICAL)	1985	2	gpm	(2 Hp)	
4. Building Lighting	1965				Good
Steam generator for atomizer	1965	1	80-110 psi	3800 lb/hr	Good
Building Outside Dimensions		Hit (ft)	Length (ft)	Width (ft)	
Building Basement (Yes/No)					

Table 26b

**Status Quo Life Cycle Cost Analysis
for Fort Bragg Bldg D-3528**

LIFE CYCLE COST ANALYSIS **STUDY: TDBRG1**
 LCCID 1.065 **DATE/TIME: 05-14-92 16:46:47**
PROJECT NO., FY, & TITLE: **FY 1992 BUILDING D-3529**
INSTALLATION & LOCATION: **PORT BRAGG NORTH CAROLINA**
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) **JAN 92**
MIDPOINT OF CONSTRUCTION (MPC) **JUN 92**
BENEFICIAL OCCUPANCY DATE (BOD) **JAN 93**
ANALYSIS END DATE (AED) **JAN 18**

COST / BENEFIT DESCRIPTION	COST IN DOS \$ (\$ X 10**0)	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE (% PER YEAR)	TIME(S) COST INCURRED
INVESTMENT COSTS	.0	.00	JUN 92
RESIDUAL OIL	152823.2	2.21	JUL93-JUL17
NATURAL GAS	1382216.0	3.39	JUL93-JUL17
MAINT LABOR	207900.0	.00	JUL93-JUL17
MAINT SERV	35135.0	.00	JUL93-JUL17
MAINT SUPPLY	248000.0	.00	JUL93-JUL17
MAINT UTIL	175676.0	.00	JUL93-JUL17
STACK	45000.0	.00	JAN 05
DRUMCTL	5000.0	.00	JAN 90
F_FAN	21000.0	.00	JAN 05
F_FAN	7000.0	.00	JAN 09
F_FAN	7000.0	.00	JAN 10
RELVALVE	7875.0	.00	JAN 85
RELVALVE	2625.0	.00	JAN 89
RELVALVE	2625.0	.00	JAN 90
RELVALVE	7884.0	.00	JAN 85
RELVALVE	2628.0	.00	JAN 89
RELVALVE	2628.0	.00	JAN 90
WTBOILER	2025000.0	.00	JAN 05
WTBOILER	675000.0	.00	JAN 09
WTBOILER	675000.0	.00	JAN 10
WTBURNER	153000.0	.00	JAN 05
WTBURNER	51000.0	.00	JAN 09
WTBURNER	51000.0	.00	JAN 10
BOILMASTER	15000.0	.00	JAN 95
BOILMASTER	5000.0	.00	JAN 99
BOILMASTER	5000.0	.00	JAN 00
FLAMESAFE	30000.0	.00	JAN 95
FLAMESAFE	10000.0	.00	JAN 99
FLAMESAFE	10000.0	.00	JAN 00

Table 26 (Cont'd)

LOCID 1.065 DATE/TIME: 05-14-92 16:46:47
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING D-3529
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

PLANTMASTER	5000.0	.00	JAN 95
AIRCOMPRECIP	20000.0	.00	JAN 85
AIRCOMPRECIP	26000.0	.00	JAN 85
AIRCOMPRECIP	26000.0	.00	JAN 11
AIRDRYERREFR	18000.0	.00	JAN 97
AIRRECV	600.0	.00	JAN 95
AIRRECV	600.0	.00	JAN 95
EMERGENCYGEN	35000.0	.00	JAN 95
DAIRHEATER	25000.0	.00	JAN 05
EXPTANK	27433.0	.00	JAN 05
FWPIPINGVAL	1209.0	.00	JAN 85
HTWPUMP	38000.0	.00	JAN 95
HTWPUMP	38000.0	.00	JAN 95
HTWPUMP	46000.0	.00	JAN 99
HTWPUMP	24000.0	.00	JAN 00
MUPUMP	5000.0	.00	JAN 92
MUPUMP	5000.0	.00	JAN 10
HEATER	16000.0	.00	JAN 95
NAGPIPEBELOW	32.0	.00	JAN 90
OILPIPEBELOW	68.0	.00	JAN 90
PUMP	6500.0	.00	JAN 90
TANKABOVE	160000.0	.00	JAN 05
TANKABOVE	320000.0	.00	JAN 10
SZSOFT	140000.0	.00	JAN 85
SUMPPUMPVERT	9800.0	.00	JAN 00

=====

OTHER KEY INPUT DATA

LOCATION - NORTH CAROLINA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
RESID	6.61 23120.0		JAN93-JAN18
NAT G	4.50 307159.0		JAN93-JAN18

Table 26b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:46:47
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING D-3529
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
RESIDUAL OIL	2837420.
NATURAL GAS	29521140.
TOTAL ENERGY COSTS	32358560.
RECURRING M&R/CUSTODIAL COSTS	9567582.
MAJOR REPAIR/REPLACEMENT COSTS	2440823.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	44366970.

*NET PW EQUIVALENTS ON JAN92; IN 10**0 DOLLARS; IN CONSTANT JAN92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 26b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:46:47
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING D-3529
 INSTALLATION & LOCATION: PORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	RESID	NAT G	M & R	R / R	OTHER
1	150529.	1297102.	623218.	0.	0.
2	147040.	1259355.	595811.	0.	0.
3	142924.	1207327.	569609.	155709.	0.
4	136977.	1154232.	544559.	0.	0.
5	130632.	1112620.	520611.	14375.	0.
6	125438.	1079726.	497716.	0.	0.
7	122730.	1086273.	475828.	44525.	0.
8	121048.	1110411.	454902.	34054.	0.
9	119712.	1144279.	434897.	0.	0.
10	118886.	1198367.	415772.	0.	0.
11	118051.	1235814.	397487.	0.	0.
12	116921.	1248533.	380007.	0.	0.
13	115717.	1275313.	363295.	1368967.	0.
14	113805.	1289742.	347319.	0.	0.
15	111313.	1295337.	332045.	0.	0.
16	108179.	1281349.	317442.	0.	0.
17	104654.	1249972.	303482.	341244.	0.
18	101046.	1233161.	290136.	470886.	0.
19	97892.	1202666.	277377.	11063.	0.
20	95345.	1171372.	265178.	0.	0.
21	92964.	1142116.	253517.	0.	0.
22	90423.	1110895.	242368.	0.	0.
23	87865.	1079474.	231709.	0.	0.
24	85020.	1044517.	221519.	0.	0.
25	82307.	1011192.	211777.	0.	0.
***	2837420.	*****	9567582.	2440823.	0.

*NET PW EQUIVALENTS ON JAN92; IN 10**0 DOLLARS; IN CONSTANT JAN92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 27a

Boiler Evaluation Parts List—Fort Bragg Bldg. E-2823

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)					
1. Boiler Pressure Parts and Setting	1988	2	16 MBtu/hr		Good
2. Relief Valve(s)	1988	2	350 psig	385 temp	Good
2. Relief Valve(s)	1988	2	1.5 in.	340 psig	Good
3. Feedwater Regulator(s)	Manual	2	1.5 in.	350 psig	Good
4. Boiler Burner(s)	1988	1	in.	—	Good
5. Boiler Fan(s) (FD)	1988	2	MBtu		
7. Boiler Drum Level Control	Visual		7.5 Hp		Good
B. Feedwater System					
8. Desacrating Heater	1988	1	lb/hr		
10. Treated Water Storage (DA Tank)	1988	1	gal	(3'x7')	
11. Treated Water Storage Pumps	1988	2	3 Hp		Good
13. Condensate Receiver	Expansion Tank				
14. Boiler Feed Pumps	1988	2	10 Hp		Good
17. Sediment Tank (Dump Tank)	1988	1	72 diam (in.)	18.5 length (ft)	Good
18. Expansion Tank	1988	1	96 diam (in.)	20 length (ft)	Good
19. Feedwater Piping System (valve)	1988		1 diam (in.)	15-20 psig	Good
20. Cooling Water Pumps	1988	2	60 Hp		Good
20. Cooling Water Pumps (booster)	1988	2	10 Hp		Good
20. Cooling Water Pumps (booster)	1988	1	15 Hp		Good
20. Cooling Water Pumps	1988	2	125 Hp		Good
21. HTW Distribution System Pumps	1988	2	20 Hp		Good
21. HTW Distribution System Pumps	1988	2	30 Hp		Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1988	1	gal		
4. Fuel Oil Pump	1988	1	gpm		
5. Fuel Oil Heater			gpm		
6. Fuel Oil Piping System (BLW)	1988		1 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1988		3 diam (in.)		Good
D. Heat Recovery System					
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack			diam (ft)	height (ft)	Good

Table 27a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
2. Boiler Master	1988	2			Good
3. Flame Safeguard System	1988	2			Good
5. Additional Boiler Instrumentation/Indicators	Part of Boiler Master 1988	1	O2/CO/Opacity Monitor N2 Pressure Alarm		Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1988	1	50 gal	0.25 Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1988	1	31 gpm		Good
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1988	1	—	SCFM (10 Hp)	Good
2. Air Dryer (REFR)	1988	1	10	SCFM	Good
3. Air Receiver	1988	1	80 gal		Good
K. Electrical System					
1. Transformer/TransPCB	—	—	—	KVA	
2. Switchgear -- Main Circuit Breaker	—	—	—	amps	
3. Motor Control Center/Starter	—	—	—	amps	
4. Emergency Generator	1988	1	250	KVA	Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1988				Good
2. Building Concrete and Building Steel	1988				Good
4. Building Lighting	1988				Good
Building Outside Dimensions		Ht (ft)	Length (ft)	Width (ft)	
Building Basement (Yes/No)					

Table 27b

**Status Quo Life Cycle Cost Analysis
for Fort Bragg Bldg E-2823**

LIFE CYCLE COST ANALYSIS **STUDY: TDBRG2**
 LCCID 1.065 **DATE/TIME: 05-14-92 16:49:17**
PROJECT NO., FY, & TITLE: **FY 1992 BUILDING E-2823**
INSTALLATION & LOCATION: **FORT BRAGG NORTH CAROLINA**
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE:Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) **MAY 92**
MIDPOINT OF CONSTRUCTION (MPC) **JUN 92**
BENEFICIAL OCCUPANCY DATE (BOD) **JAN 93**
ANALYSIS END DATE (AED) **JAN 18**

COST / BENEFIT DESCRIPTION	COST IN DOS \$ (\$ X 10**0)	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE (% PER YEAR)	TIME(S) COST INCURRED
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	37692.4	1.58	JUL93-JUL17
NATURAL GAS	303300.0	3.64	JUL93-JUL17
MAINT LABOR	134400.0	.00	JUL93-JUL17
MAINT SERV	10811.0	.00	JUL93-JUL17
MAINT SUPPLY	80000.0	.00	JUL93-JUL17
MAINT UTIL	54054.0	.00	JUL93-JUL17
RELVALVE	3654.0	.00	JAN 08
RELVALVE	3666.0	.00	JAN 08
PUMPSIMPLEX	3000.0	.00	JAN 08
TANKPOLY	200.0	.00	JAN 08
BOILMASTER	10000.0	.00	JAN 18
FLAMESAFE	20000.0	.00	JAN 18
AIRCOMPRECIP	20000.0	.00	JAN 08
AIRDRYERREFR	12000.0	.00	JAN 03
AIRRECV	600.0	.00	JAN 18
EMERGENCYGEN	150571.0	.00	JAN 18
COOLPUMP	5500.0	.00	JAN 08
COOLPUMP	5500.0	.00	JAN 08
COOLPUMP	6250.0	.00	JAN 08
COOLPUMP	22800.0	.00	JAN 08
COOLPUMP	22800.0	.00	JAN 08
FEEDPUMP	28000.0	.00	JAN 18
FWPIPINGVAL	1100.0	.00	JAN 08
HTWPUMP	38000.0	.00	JAN 18
HTWPUMP	38000.0	.00	JAN 18
TREATPUMP	8000.0	.00	JAN 08
NAGPIPEBELOW	18.0	.00	JAN 13
OILPIPEBELOW	25.0	.00	JAN 13
PUMP	8000.0	.00	JAN 13

Table 27b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:49:17
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING E-2823
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

TANKBELOW	57000.0	.00	JAN 18
SZSOFT	70000.0	.00	JAN 08

=====

OTHER KEY INPUT DATA

LOCATION - NORTH CAROLINA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	7.43 5073.0		JAN93-JAN18
NAT G	4.50 67400.0		JAN93-JAN18

Table 27b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:49:17
PROJECT NO., FY, & TITLE: FY 1992 BUILDING E-2823
INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	649110.
NATURAL GAS	6626649.
TOTAL ENERGY COSTS	7275760.
RECURRING M&R/CUSTODIAL COSTS	4068100.
MAJOR REPAIR/REPLACEMENT COSTS	203734.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	11547590.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 27b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:49:17
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING E-2823
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	36060.	291162.	264990.	0.	0.
2	34501.	282689.	253337.	0.	0.
3	32905.	271010.	242196.	0.	0.
4	31451.	259092.	231545.	0.	0.
5	30096.	249751.	221362.	0.	0.
6	28953.	242367.	211627.	0.	0.
7	28273.	243837.	202320.	0.	0.
8	27788.	249256.	193423.	0.	0.
9	27389.	256858.	184917.	0.	0.
10	27108.	268999.	176785.	0.	0.
11	26825.	277405.	169010.	7428.	0.
12	26504.	280260.	161578.	0.	0.
13	26165.	286271.	154472.	0.	0.
14	25697.	289510.	147679.	0.	0.
15	25134.	290766.	141184.	0.	0.
16	24459.	287626.	134975.	85254.	0.
17	23719.	280583.	129039.	0.	0.
18	22903.	276809.	123365.	0.	0.
19	22184.	269964.	117939.	0.	0.
20	21607.	262939.	112753.	0.	0.
21	21067.	256372.	107794.	3175.	0.
22	20491.	249364.	103054.	0.	0.
23	19912.	242311.	98522.	0.	0.
24	19267.	234464.	94189.	0.	0.
25	18652.	226984.	90047.	0.	0.
***	649110.	6626649.	4068100.	203734.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 22a

Boiler Evaluation Parts List—Port Bragg Bldg, N-6002

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)	1985	2	25 MBtu/hr		Good
1. Boiler Pressure Parts and Setting			110 psig	345 temp	Good
2. Relief Valve(s)	1985	3	1.5 in.	400 psig	Good
2. Relief Valve(s)	1991	1	1.5 in.	400 psig	Good
3. Feedwater Regulator(s)	Base water supply		in.	psig	Good
4. Boiler Burner(s)	1985	2	25 MBtu		Good
5. Boiler Fan(s) (FD)	1985	2	15 Hp		Good
7. Boiler Drum Level Control	Manual				
B. Feedwater System					
8. Deaerating Heater	None		lb/hr		
14. Zone Pumps			10 Hp		
15. Make-up Pumps	1985	2	15 Hp		Good
16. Boiler Circulating Water Pumps	1985	3	10 Hp		Good
18. Expansion Tank	1985	1	72 diam (in.)	20 length (ft)	Good
19. Feedwater Piping System (valve)	Base water pressure		diam (in.)	psig	
20. Cooling Water Pumps	1985	2	200 Hp		Good
21. HTW Distribution System Pumps	1985	2	75 Hp		Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1985	1	30000 gal		Good
4. Fuel Oil Pump			gpm		
5. Fuel Oil Heater			gpm		
6. Fuel Oil Piping System (BLW)			diam (in.)		
7. Natural Gas Piping System (BLW)	1985		2.5 diam (in.)		Good
D. Heat Recovery System					
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1985	1	48 diam (ft)	80 height (ft)	Good
F. Combustion Controls					
1. Plant Master	1985	1			Good
2. Boiler Master	1985	2			Good
3. Flame Safeguard System	1985	2			Good
5. Additional Boiler Instrumentation/Indicators	1985	1	O ₂ /CO ₂ Recorders Low water level cut-off		Good

Table 28a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1985	2	50 gal		Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1985	1	50 gpm	(Solar Rock Salt)	Good
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1985	2	SCFM		Good
3. Air Receiver	1985	2	120 gal		Good
Soot blower - used daily to maintain it					
1. Air Compressor (RECIP)	1985	1	SCFM	(3 Hp)	Good
2. Air Dryer (REFR)	1985	1	105 SCFM		
3. Air Receiver	1985	1	gal	(4'x8')	Good
K. Electrical System					
1. Transformer/TransPCB	1985	1	KVA		Good
2. Switchgear - Main Circuit Breaker	1985	1	400 amps		
3. Motor Control Center/Starter	1985	1	113 KVA		Good
4. Emergency Generator	1985	1			
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1985				Good
2. Building Concrete and Building Steel	1985				Good
3. Sump Pump (SUBMERGE/VERTICAL)	1985	3	40 gpm		Good
4. Building Lighting	1985				Good
Building Outside Dimensions		Ht (ft)	Length (ft)	Width (ft)	
Building Basement (Yea/No)					

Table 28b

**Status Quo Life Cycle Cost Analysis
for Fort Bragg Bldg N-6002**

LIFE CYCLE COST ANALYSIS **STUDY: TDBRG4**
 LCCID 1.065 DATE/TIME: 05-14-92 16:44:33
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING N-6002
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS)	JAN 92
MIDPOINT OF CONSTRUCTION (MPC)	JUN 92
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 93
ANALYSIS END DATE (AED)	JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	COST INCURRED
INVESTMENT COSTS	.0	.00	JUN 92
RESIDUAL OIL	37663.8	2.21	JUL93-JUL17
NATURAL GAS	340659.0	3.39	JUL93-JUL17
MAINT LABOR	134400.0	.00	JUL93-JUL17
MAINT SERV	13514.0	.00	JUL93-JUL17
MAINT SUPPLY	100000.0	.00	JUL93-JUL17
MAINT UTIL	67568.0	.00	JUL93-JUL17
RELVALVE	5601.0	.00	JAN 05
RELVALVE	1867.0	.00	JAN 11
TANKPOLY	400.0	.00	JAN 05
BOILMASTER	10000.0	.00	JAN 15
FLAMESAFE	20000.0	.00	JAN 15
PLANTMASTER	5000.0	.00	JAN 15
AIRCOMPRECIP	40000.0	.00	JAN 05
AIRCOMPRECIP	20000.0	.00	JAN 05
AIRDRYERREFR	13300.0	.00	JAN 00
AIRRECV	1400.0	.00	JAN 15
AIRRECV	3000.0	.00	JAN 15
EMERGENCYGEN	71660.0	.00	JAN 15
CIRCPUMP	42000.0	.00	JAN 15
COOLPUMP	22800.0	.00	JAN 05
FWPIPINGVAL	1100.0	.00	JAN 05
HTWPUMP	57000.0	.00	JAN 15
HTWPUMP	46000.0	.00	JAN 15
MUPUMP	12500.0	.00	JAN 05
NAGPIPEBELOW	16.0	.00	JAN 10
TANKBELOW	42000.0	.00	JAN 15
SZSOFT	70000.0	.00	JAN 05
SUMPPUMPVERT	15225.0	.00	JAN 00

Table 2b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:44:33
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING N-6002
 INSTALLATION & LOCATION: PORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

=====

OTHER KEY INPUT DATA

LOCATION - NORTH CAROLINA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
RESID	6.61 5698.0		JAN93-JAN18
NAT G	4.50 75702.0		JAN93-JAN18

Table 28b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:44:33
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING N-6002
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
RESIDUAL OIL	699291.
NATURAL GAS	7275742.
TOTAL ENERGY COSTS	7975034.
RECURRING M&R/CUSTODIAL COSTS	4527299.
MAJOR REPAIR/REPLACEMENT COSTS	222730.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	12725060.

*NET PW EQUIVALENTS ON JAN92; IN 10**0 DOLLARS; IN CONSTANT JAN92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 25b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:44:33
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING N-6002
 INSTALLATION & LOCATION: FORT BRAGG NORTH CAROLINA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	RESID	NAT G	M & R	R / R	OTHER
1	37098.	319682.	294902.	0.	0.
2	36239.	310379.	281933.	0.	0.
3	35224.	297556.	269534.	0.	0.
4	33759.	284471.	257681.	0.	0.
5	32195.	274215.	246349.	0.	0.
6	30915.	266108.	235515.	0.	0.
7	30247.	267721.	225158.	0.	0.
8	29833.	273671.	215256.	19905.	0.
9	29504.	282017.	205790.	0.	0.
10	29300.	295348.	196740.	0.	0.
11	29094.	304577.	188088.	0.	0.
12	28816.	307712.	179816.	0.	0.
13	28519.	314312.	171908.	96079.	0.
14	28048.	317868.	164348.	0.	0.
15	27433.	319247.	157121.	0.	0.
16	26661.	315799.	150211.	0.	0.
17	25792.	308066.	143605.	0.	0.
18	24903.	303923.	137290.	7.	0.
19	24126.	296407.	131252.	794.	0.
20	23498.	288695.	125480.	0.	0.
21	22911.	281484.	119962.	0.	0.
22	22285.	273790.	114686.	0.	0.
23	21655.	266046.	109643.	105944.	0.
24	20953.	257430.	104821.	0.	0.
25	20285.	249217.	100211.	0.	0.
***	699291.	7275742.	4527299.	222730.	0.

*NET PW EQUIVALENTS ON JAN92; IN 10**0 DOLLARS; IN CONSTANT JAN92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 29

CHPECON Run Results for Fort Bragg Bldg. C-1432

Technology	Boiler	\$/MBTU	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	100/100/100	10.588	12.659	9051	118957	137895	100
#2 OIL	100/100/100	15.795	18.884	9051	186764	205702	149
#6 OIL	100/100/100	16.885	20.187	9051	200957	219895	159
STOKER	68/117/117/117	10.538	12.599	62367	38337	137239	100
CWS	59/117/150/150	10.372	12.401	53143	58437	141162	102
COM	71/123/123/123	16.138	19.295	37872	156267	219633	159
FBC	54/108/138/138	10.388	12.420	60181	40010	135292	98
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS
Retrofit							
STOKER				4575	36441	-215732	-174717
CWS				3787	55131	-298123	-239205
M-COAL				5888	35296	-210934	-169750

FILE PREFIX: FBG3

PMCR: 300 L

AVE MON. LOAD: 100 M

L=(K\$ STEAM/HR)

M=(MBTU/HR)

Table 30

CHPECON Run Results for Fort Bragg Bldg. D-3529

Technology	Boiler	\$/MBTU	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
#6 OIL	44/44/44	17.915	21.420	5715	86537	100328	154
STOKER	30/51/51/51	15.310	18.305	41825	17324	85737	132
CWS	26/51/65/65	13.515	16.159	31118	25665	79092	122
COM	31/53/53/53	19.358	23.145	25001	67880	113287	174
FBC	24/47/60/60	14.884	17.795	39757	17565	83350	128
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS
Retrofit							
STOKER				4500	15732	-93136	-72903
CWS				3211	23886	-129165	-102068
M-COAL				5302	15107	-90291	-69881

FILE PREFIX: FBG1

PMCR: 130 L

AVE MON. LOAD: 43 M

CHP #1 3@ 26 M FUEL = NG/FS6 AGE = 1965

1@ 26 M FUEL = NG/FS6 AGE = 1969

L=(K\$ STEAM/HR)

M=(MBTU/HR)

Table 31

CHPECON Run Results for Fort Bragg Bldg. N-6002

Technology	Boiler	\$/MBTU	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
#2 OIL	17/17/17	19.494	23.307	4020	31926	43159	136
#6 OIL	17/17/17	20.584	24.610	4020	34339	45572	144
STOKER	12/20/20/20	27.603	33.002	32334	7595	61111	193
CWS	10/20/25/25	21.877	26.150	21129	10605	50615	160
COM	12/21/21/21	27.791	33.227	18719	27526	64296	203
FBC	9/18/23/23	26.575	31.774	30190	7501	58837	186
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS

Retrofit

STOKER

CWS

M-COAL

FILE PREFIX: FBG5

PMCR: 50 L

AVE MON. LOAD: 17 M

CHP #5 2@ 25 L FUEL = NG,FS6 AGE = 1985

L = (K\$ STEAM/HR)

M = (MBTU/HR)

Table 32

CHPECON Run Results for Fort Bragg Bldg. 4-3124

Technology	Boiler	\$/MBTU	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	42/42/42	11.656	13.936	5625	50088	67757	100
#2 OIL	42/42/42	16.863	20.161	5625	78568	92237	136
#6 OIL	42/42/42	17.953	21.464	5625	84529	98198	145
STOKER	29/49/49/49	15.490	18.521	41320	16975	84731	125
CWS	25/49/63/63	13.650	16.321	30776	25051	78026	115
COM	30/52/52/52	19.358	23.144	24442	65901	110648	163
FBC	23/46/58/58	15.049	17.992	39269	17147	82311	121
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS

Retrofit

STOKER

CWS

M-COAL

3361

15381

-91056

-72314

2273

23295

-125967

-100400

3904

14764

-88234

-69565

FILE PREFIX: FBG2

PMCR: 126 L

AVE MON. LOAD: 42 M

CHP #2 2@ 37.9 L FUEL = NG,FS2 AGE = 1972

1@ 50 L FUEL = NG,FS2 AGE = 1952

L=(K\$ STEAM/HR)

M=(MBTU/HR)

Table 33

CHPECON Run Results for Fort Bragg Bldg. C-7549

Technology	Boiler	S/MBTU	\$/K#STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	34/34/34	12.133	14.506	5028	39387	52145	100
#2 OIL	34/34/34	17.340	20.732	5028	61764	74522	143
#6 OIL	34/34/34	18.430	22.034	5028	66447	79205	152
STOKER	23/39/39/39	17.292	20.675	37447	13377	74318	143
CWS	20/39/50/50	15.209	18.184	27421	19703	68307	131
COM	24/41/41/41	20.829	24.905	22346	51578	93547	179
FBC	18/36/46/46	16.875	20.176	35433	13658	72526	139
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS

Retrofit

STOKER

CWS

M-COAL

FILE PREFIX: FBG4

PMCR: 100 L

AVE MON. LOAD: 33 M

CHP #4 2@ 50 L FUEL = NG,FS2 AGE = 1973

L=(K# STEAM/HR)

M=(MBTU/HR)

Table 34

Cost Sensitivity Analysis for a Gas/Oil Fired Boiler Plant

Central Heating Plant Economics Evaluation -- Sensitivity Analysis Page 1
 File: FBGG Type: New plant (NP) 05/11/92
 Desc: FORT BRAGG
 Tech: Gas / Oil Fired Boiler

 Base and Plant Information

State: NC - North Carolina Base DOE Region: 3
 PMCR: 379,000 lb/hr steam Number of boilers: 3

Height of the plant: 40 ft
 Building area: 10200 sq ft
 Plant area: 2.44 acres

 Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)
 Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)
 Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)
 Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 2,051,666 kW-hr

1991 cost for distillate: 0.631 \$/gallon
 1991 cost for residual: 0.400 \$/gallon
 1991 cost for natural gas: 2.722 \$/million Btu
 1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 1,159,392 thousand lb steam
 Annual Natural Gas Usage: 1,423 10⁶ SCF
 Heating plant efficiency: 83.2% natural gas
 Year of Study: 1991
 Years of Operation: 1995 - 2019
 Annual #2 Fuel Oil Usage: 11,200 10³ gal
 Heating plant efficiency: 86.2% #2 fuel oil

 Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 2,242,793	Stack:	\$ 32,911
Building/service:	\$ 1,621,511	Water trtmnt:	\$ 930,583
Feedwtr pmps:	\$ 43,085	Cond xfr pmps:	\$ 46,709
Cond strg tnk:	\$ 10,835	Oil (long) storage:	\$ 476,208
Oil day strg pmp:	\$ 5,642	Oil heaters:	\$ 12,224
Oil day strg tanks:	\$ 28,304	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 7,992	Fire protection:	\$ 52,241
Cont bldn tnk:	\$ 1,512	Intr bldn tnk:	\$ 1,512
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 22,202	Site preparation:	\$ 6,373
Site improvements:	\$ 302,476	Mobile equipment:	\$ 40,748

Table 34 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FBGG Type: New plant (NP)

05/11/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Facility Capital Costs, cont

Piping:	\$	1,484,057	Instrumentation:	\$	548,726
Direct costs:	\$	3,125,845			

Plant installed cost:	\$	12,247,402			

Facility Annual O & M and Energy Costs

Operating staff: 12

Annual Labor Costs: \$ 499,778

Annual Year Non-Labor O & M Costs : \$ 832,832

1995 Natural gas costs : \$ 5,000,592

1995 Auxiliary Energy Costs : \$ 108,982

1995 #2 fuel oil costs : \$ 8,610,956

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 7,075
10 years	\$ 386,834	15 years	\$ 151,802
18 years	\$ 18,684	20 years	\$ 16,651

Facility Life Cycle Cost Summary

Analysis using natural gas as primary fuel

+ PV 'Adjusted' Investment Costs = \$ 10,732,356

+ PV Energy + Transportation Costs = \$ 106,846,953

+ PV Annually Recurring O&M Costs = \$ 10,802,151

+ PV Non-Annually Recurring Repair & Replacement = \$ 579,314

+ PV Disposal Cost of Existing System = \$ 0

+ PV Disposal Cost of New/Retrofit Facility = \$ 0

Total Life Cycle Cost (1991) = \$ 128,960,776

Levelized Cost of Service (1995 start) = 7.4820 \$/MMBtu

Levelized Cost of Service (1995 start) = 8.9454 \$/1000 lb steam

Facility Life Cycle Cost Summary

Analysis using #2 fuel oil as primary fuel

Table 34 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FBGG Type: New plant (NP)

05/11/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Facility Life Cycle Cost Summary, cont

+ PV Energy + Transportation Costs	= \$ 152,268,430
+ PV Annually Recurring O&M Costs	= \$ 10,802,151
+ PV Non-Annually Recurring Repair & Replacement	= \$ 579,314
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991)	= \$ 174,382,254
------------------------------	------------------

Levelized Cost of Service (1995 start)	= 10.117 \$/MMBtu
Levelized Cost of Service (1995 start)	= 12.096 \$/1000 lb steam

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	52,659,465	76,301,311	5.292
60%	63,191,358	86,833,204	6.023
70%	73,723,252	97,365,097	6.753
80%	84,255,145	107,896,990	7.484
90%	94,787,038	118,428,883	8.214
100%	105,318,931	128,960,776	8.945
110%	115,850,824	139,492,670	9.676
120%	126,382,717	150,024,563	10.406
130%	136,914,610	160,556,456	11.137
140%	147,446,504	171,088,349	11.867
150%	157,978,397	181,620,242	12.598

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	73,417,365	97,059,211	6.732
-2%	82,490,021	106,131,866	7.361
-1%	93,034,992	116,676,837	8.093
0%	105,318,931	128,960,776	8.945
1%	119,658,535	143,300,380	9.940
2%	136,429,937	160,071,782	11.103
3%	156,079,829	179,721,674	12.466
4%	179,138,616	202,780,462	14.066
5%	206,235,971	229,877,817	15.945
6%	238,119,197	261,761,042	18.157

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,222,417	128,655,172	8.924

Table 34 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FBGG Type: New plant (NP)

05/11/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

100%	1,528,022	128,960,776	8.945
110%	1,680,824	129,113,579	8.956
120%	1,833,626	129,266,381	8.966

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	5,195,256	127,661,962	8.855
90%	5,844,663	128,311,369	8.900
100%	6,494,070	128,960,776	8.945
110%	7,143,477	129,610,183	8.990
120%	7,792,884	130,259,590	9.035

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	3,446,465	128,099,160	8.885
90%	3,877,273	128,529,968	8.915
100%	4,308,081	128,960,776	8.945
110%	4,738,889	129,391,585	8.975
120%	5,169,698	129,822,393	9.005

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	463,451	128,844,914	8.937
90%	521,383	128,902,845	8.941
100%	579,314	128,960,776	8.945
110%	637,246	129,018,708	8.949
120%	695,177	129,076,639	8.953

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	8,585,885	126,573,245	8.779
90%	9,659,121	127,767,011	8.862
100%	10,732,356	128,960,776	8.945
110%	11,805,592	130,154,542	9.028
120%	12,878,828	131,348,308	9.111

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Table 34 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FBGG Type: New plant (NP)

05/11/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

-15%	-320,820	129,281,597	8.967
-10%	-213,880	129,174,657	8.960
-5%	-106,940	129,067,717	8.952
0%	0	128,960,776	8.945
5%	106,940	128,853,836	8.938
10%	213,880	128,746,896	8.930
15%	320,820	128,639,956	8.923

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	256,519,232	17.793
0.5%	235,989,485	16.369
1.5%	200,800,336	13.928
2.5%	172,065,641	11.935
3.5%	148,462,758	10.298
4.5%	128,960,776	8.945
5.5%	112,752,497	7.821
6.5%	99,203,005	6.881
7.5%	87,810,626	6.091
8.5%	78,177,169	5.422
9.5%	69,985,149	4.854
10.5%	62,980,290	4.368
11.5%	56,958,023	3.950
12.0%	54,262,405	3.763

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	61,410,016	7.982
11 yr	66,395,605	8.007
12 yr	71,413,865	8.055
13 yr	76,461,434	8.122
14 yr	81,481,943	8.198
15 yr	86,536,921	8.288
16 yr	91,378,302	8.366
17 yr	96,069,923	8.440
18 yr	100,646,253	8.513
19 yr	105,071,556	8.581
20 yr	109,517,217	8.659
21 yr	113,678,513	8.722
22 yr	117,688,331	8.781
23 yr	121,570,571	8.838
24 yr	125,329,299	8.893
25 yr	128,960,776	8.945

Table 35

Cost Sensitivity Analysis for a #6 Oil-Fired Boiler Plant

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: FBG6 Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Base and Plant Information

State: NC - North Carolina

Base DOE Region: 3

PMCR: 379,000 lb/hr steam

Number of boilers: 3

Height of the plant: 40 ft

Building area: 10200 sq ft

Plant area: 2.44 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 2,051,666 kW-hr

1991 cost for distillate: 0.631 \$/gallon

1991 cost for residual: 0.400 \$/gallon

1991 cost for natural gas: 2.722 \$/million Btu

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 1,159,392 thousand lb steam

Annual #6 Fuel Oil Usage: 10,155 10³ gal

Heating plant efficiency: 87.8% #6 fuel oil

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 2,242,793	Stack:	\$ 32,911
Building/service:	\$ 1,621,511	Water trtmnt:	\$ 930,583
Feedwtr pmps:	\$ 43,085	Cond xfr pmps:	\$ 46,709
Cond strg tnk:	\$ 10,835	Oil (long) storage:	\$ 476,208
Oil day strg pmp:	\$ 5,642	Oil heaters:	\$ 12,224
Oil day strg tanks:	\$ 28,304	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 7,992	Fire protection:	\$ 52,241
Cont bldn tnk:	\$ 1,512	Intr bldn tnk:	\$ 1,512
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 22,202	Site preparation:	\$ 6,373
Site improvements:	\$ 302,476	Mobile equipment:	\$ 40,748
Elec substation:	\$ 83,490	Electrical:	\$ 261,892
Piping:	\$ 1,484,057	Instrumentation:	\$ 548,726
Direct costs:	\$ 3,125,845		

Table 35 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FBG6 Type: New plant (NP)
 Desc: FORT BRAGG
 Tech: Gas / Oil Fired Boiler

Page 2
 07/29/92

 Facility Capital Costs, cont

Plant installed cost: \$ 12,247,402

 Facility Annual O & M and Energy Costs

Operating staff: 12

Annual Labor Costs: \$ 499,778

Annual Year Non-Labor O & M Costs : \$ 832,832

1995 #6 fuel oil costs : \$ 5,457,879

1995 Auxiliary Energy Costs : \$ 108,982

 Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 7,075
10 years	\$ 386,834	15 years	\$ 151,802
18 years	\$ 18,684	20 years	\$ 16,651

 Facility Life Cycle Cost Summary

Analysis using #6 fuel oil as primary fuel

+ PV 'Adjusted' Investment Costs	= \$ 10,732,356
+ PV Energy + Transportation Costs	= \$ 108,534,041
+ PV Annually Recurring O&M Costs	= \$ 10,802,151
+ PV Non-Annually Recurring Repair & Replacement	= \$ 579,314
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991) = \$ 130,647,864

Levelized Cost of Service (1995 start) = 7.5798 \$/MMBtu

Levelized Cost of Service (1995 start) = 9.0625 \$/1000 lb steam

 Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	53,503,009	77,144,855	5.351
60%	64,203,611	87,845,457	6.093

Table 35 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FBG6 Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

80%	85,604,815	109,246,660	7.578
90%	96,305,417	119,947,262	8.320
100%	107,006,019	130,647,864	9.062
110%	117,706,621	141,348,466	9.804
120%	128,407,222	152,049,068	10.547
130%	139,107,824	162,749,670	11.289
140%	149,808,426	173,450,272	12.031
150%	160,509,028	184,150,874	12.773

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	75,748,941	99,390,786	6.894
-2%	84,673,485	108,315,330	7.513
-1%	95,008,379	118,650,224	8.230
0%	107,006,019	130,647,864	9.062
1%	120,965,924	144,607,770	10.030
2%	137,243,569	160,885,414	11.159
3%	156,260,827	179,902,672	12.479
4%	178,518,333	202,160,179	14.023
5%	204,610,094	228,251,940	15.832
6%	235,240,735	258,882,581	17.957

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,222,417	130,342,260	9.041
90%	1,375,219	130,495,062	9.051
100%	1,528,022	130,647,864	9.062
110%	1,680,824	130,800,666	9.073
120%	1,833,626	130,953,469	9.083

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	5,195,256	129,349,050	8.972
90%	5,844,663	129,998,457	9.017
100%	6,494,070	130,647,864	9.062
110%	7,143,477	131,297,271	9.107
120%	7,792,884	131,946,678	9.152

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	3,446,465	129,786,248	9.002
90%	3,877,273	130,217,056	9.032
100%	4,308,081	130,647,864	9.062
110%	4,738,889	131,078,672	9.092

Table 35 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FBG6 Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	463,451	130,532,001	9.054
90%	521,383	130,589,933	9.058
100%	579,314	130,647,864	9.062
110%	637,246	130,705,796	9.066
120%	695,177	130,763,727	9.070

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	8,585,885	128,260,333	8.896
90%	9,659,121	129,454,098	8.979
100%	10,732,356	130,647,864	9.062
110%	11,805,592	131,841,630	9.145
120%	12,878,828	133,035,396	9.228

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-320,820	130,968,685	9.084
-10%	-213,880	130,861,744	9.077
-5%	-106,940	130,754,804	9.069
0%	0	130,647,864	9.062
5%	106,940	130,540,924	9.055
10%	213,880	130,433,984	9.047
15%	320,820	130,327,044	9.040

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	255,269,595	17.707
0.5%	235,312,174	16.322
1.5%	201,032,108	13.944
2.5%	172,956,540	11.997
3.5%	149,823,413	10.392
4.5%	130,647,864	9.062
5.5%	114,657,756	7.953
6.5%	101,244,910	7.022
7.5%	89,928,064	6.237
8.5%	80,324,620	5.571

Table 35 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FBG6 Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

10.5%	65,096,066	4.515
11.5%	59,028,170	4.094
12.0%	56,304,866	3.905

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	65,879,232	3.563
11 yr	71,036,145	8.566
12 yr	76,105,266	8.584
13 yr	81,043,821	8.608
14 yr	85,852,414	8.638
15 yr	90,623,666	8.679
16 yr	95,188,959	8.715
17 yr	99,613,272	8.751
18 yr	103,930,232	8.791
19 yr	108,103,900	8.829
20 yr	112,305,490	8.880
21 yr	116,231,144	8.918
22 yr	120,013,460	8.955
23 yr	123,675,606	8.991
24 yr	127,221,878	9.027
25 yr	130,647,864	9.062

Table 36

Cost Sensitivity Analysis for a Coal-Fired Stoker Plant

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: FBGC Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Base and Plant Information
*****State: NC - North Carolina
PMCR: 379,000 lb/hr steamBase DOE Region: 3
Number of boilers: 4

Coal code: W205320

Distance from base: 294 miles

State: KY - Kentucky

DOE Region: 3

Coal type: bituminous

(properties on a dry basis)

hhv: 12870 Btu/lb fixed carbon: 52.20% volatiles: 38.10%

ash: 9.70% sulfur: 0.50%

Coal handling equipment capacity: 200 tons/hr

Coal silo storage capacity: 1426 tons

Approx. building width: 84 feet

Approx. building length: 252 feet

Height of the plant: 91 ft

Building area: 21072 sq ft

Plant area: 2.63 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual diesel/distillate fuel usage: 17,516 gallons

Annual electricity usage: 6,373,949 kW-hr

Annual lime usage: 1,176 tons

1991 cost for coal: 1.715 \$/MMBtu

1991 cost for distillate: 0.631 \$/gallon

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 1,159,392 thousand lb steam

Annual Coal Usage: 60,569 tons (dry) / 64,204 tons (wet)

Heating plant efficiency: 84%

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Installed Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 18,234,113	Coal Handling:	\$ 7,109,178
Ash Handling:	\$ 2,563,757	Mechnc'l Collector:	\$ 219,181

Table 36 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FBGC

Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Installed Capital Costs, cont

Water Treatment:	\$	1,440,954	Pumps:	\$	359,045
Air Compressor:	\$	113,612	Waste Water Trtmnt:	\$	156,176
Piping/Stack:	\$	6,123,282	Electrical System:	\$	1,789,999
Building Costs:	\$	13,437,622	Direct costs:	\$	20,670,555

Plant installed cost:	\$	83,110,049			

Facility Annual O & M and Energy Costs

Operating staff: 34

Annual Labor Costs: \$ 1,455,295

First Year Non-Labor O & M Costs : \$ 2,465,522

Annual Year Non-Labor O & M Costs : \$ 2,885,447

1995 Coal Costs (incl transport) : \$ 3,324,765

1995 Auxiliary Energy Costs : \$ 352,044

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 144,735	5 years	\$ 126,244
7 years	\$ 131,192	8 years	\$ 449,078
10 years	\$ 950,959	12 years	\$ 85,105
15 years	\$ 23,650	18 years	\$ 37,366
20 years	\$ 1,525,196		

Facility Life Cycle Cost Summary

+ PV 'Adjusted' Investment Costs	= \$ 72,829,053
+ PV Energy + Transportation Costs	= \$ 52,914,546
+ PV Annually Recurring O&M Costs	= \$ 37,141,111
+ PV Non-Annually Recurring Repair & Replacement	= \$ 3,217,968
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991)	= \$ 166,102,680
------------------------------	------------------

Levelized Cost of Service (1995 start)	= 9.6368 \$/MMBtu
--	-------------------

Table 36 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FBGC

Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	23,965,836	142,136,844	9.859
60%	28,759,004	146,930,011	10.191
70%	33,552,171	151,723,178	10.524
80%	38,345,338	156,516,346	10.856
90%	43,138,506	161,309,513	11.189
100%	47,931,673	166,102,680	11.521
110%	52,724,840	170,895,848	11.854
120%	57,518,008	175,689,015	12.186
130%	62,311,175	180,482,183	12.519
140%	67,104,342	185,275,350	12.851
150%	71,897,510	190,068,517	13.184

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	34,739,514	152,910,522	10.606
-2%	38,523,048	156,694,055	10.869
-1%	42,886,234	161,057,242	11.171
0%	47,931,673	166,102,680	11.521
1%	53,781,039	171,952,046	11.927
2%	60,578,650	178,749,658	12.399
3%	68,495,693	186,666,700	12.948
4%	77,735,213	195,906,220	13.589
5%	88,538,020	206,709,028	14.338
6%	101,189,659	219,360,667	15.216

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	3,986,298	165,106,106	11.452
90%	4,484,586	165,604,393	11.487
100%	4,982,873	166,102,680	11.521
110%	5,481,160	166,600,968	11.556
120%	5,979,448	167,099,255	11.590

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	15,127,986	162,320,684	11.259
90%	17,018,984	164,211,682	11.390
100%	18,909,982	166,102,680	11.521
110%	20,800,980	167,993,679	11.653
120%	22,691,979	169,884,677	11.784

=== O&M non-labor cost variation ===

Table 36 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FBGC

Type: New plant (NP)

07/29/92

Desc: PORT BRAGG

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

 Sensitivity Analysis, cont

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	14,584,903	162,456,455	11.268
90%	16,408,015	164,279,568	11.395
100%	18,231,128	166,102,680	11.521
110%	20,054,241	167,925,793	11.648
120%	21,877,354	169,748,906	11.774

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	2,574,375	165,459,087	11.477
90%	2,896,171	165,780,884	11.499
100%	3,217,968	166,102,680	11.521
110%	3,539,765	166,424,477	11.544
120%	3,861,562	166,746,274	11.566

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	58,263,243	149,121,218	10.343
90%	65,546,148	157,611,949	10.932
100%	72,829,053	166,102,680	11.521
110%	80,111,959	174,593,412	12.110
120%	87,394,864	183,084,143	12.699

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-2,109,977	168,212,658	11.668
-10%	-1,406,651	167,509,332	11.619
-5%	-703,325	166,806,006	11.570
0%	0	166,102,680	11.521
5%	703,325	165,399,355	11.473
10%	1,406,651	164,696,029	11.424
15%	2,109,977	163,992,703	11.375

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	266,365,451	18.476
0.5%	250,785,946	17.396
1.5%	223,700,223	15.517

Table 36 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FBGC

Type: New plant (NP)

07/29/92

Desc: FORT BRAGG

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis, cont

3.5%	182,155,073	12.635
4.5%	166,102,680	11.521
5.5%	152,413,939	10.572
6.5%	140,654,135	9.756
7.5%	130,477,977	9.050
8.5%	121,609,843	8.435
9.5%	113,828,614	7.895
10.5%	106,956,012	7.419
11.5%	100,847,576	6.995
12.0%	98,042,265	6.800

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	120,349,774	15.644
11 yr	124,097,923	14.965
12 yr	127,827,924	14.418
13 yr	131,308,889	13.948
14 yr	134,721,953	13.555
15 yr	138,077,818	13.224
16 yr	141,378,128	12.944
17 yr	144,371,444	12.684
18 yr	147,328,849	12.462
19 yr	150,109,897	12.260
20 yr	153,736,320	12.156
21 yr	156,416,595	12.002
22 yr	158,908,029	11.857
23 yr	161,310,050	11.727
24 yr	163,832,833	11.625
25 yr	166,102,680	11.521

Table 37

Fort Gordon Heating Plant Information

Plant	Boiler	Fuel	Reserve	Year Installed	Capacity (B/hr)	In use	Rating	Energy Use Heat/Cool/ Process/Looses/ Internal/Pwr gen
25330	1	Nat. Gas	FS2	1975	35000	Y	7	H/C
25330	2	Nat. Gas	FS2	1975	35000	Y	7	H/C
2202	1	Nat. Gas	FS2	1972	30000	Y	7	H
2202	2	Nat. Gas	FS2	1972	30000	Y	7	H
25910	1	Nat. Gas	FS2	1965	35850	Y	6	H/C
25910	2	Nat. Gas	FS2	1965	35850	Y	6	H/C
25910	3	Nat. Gas	FS2	1965	35850	Y	6	H/C
25910	4	Nat. Gas	FS2	1967	34000	Y	6	H/C
25910	5	Nat. Gas	FS2	1967	34000	Y	6	H/C
310	1	Nat. Gas	FS2	1972	15300	Y	5	H/C
310	2	Nat. Gas	FS2	1972	15300	Y	5	H/C
310	3	Nat. Gas	FS2	1972	15300	Y	5	H/C
(Total)					351450			

Table 38

Fort Gordon Energy Use Data

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 Use	\$/MBtu	MBtu '90
Dist. oil	gal	138000	0.56	610386	700014	4.06	96602
Res. oil	gal			0	0		
Nat. gas	Total NAG use:						
Interr.	kscf	1028000	2.88	593517	532434	2.80	547342
Unintr.	kscf	1028000	5.65			5.50	
Building:							
Capacity (lb/hr):		25910	310	25330	2202		
SQ file:		175550	45900	70000	60000		
Annual Costs		GRD1	GRD2	GRD3	GRD4		
Labor*		385000	122500	167500	167500		
Utilities*		237230	62027	94595	81081		
Service*		47446	12405	18919	16216		
Supplies*		320880	91800	140000	120000		
Average steam production, 1990 (lb/hr):							
October		13829	5717.0	5427.0	6686.4		
November		18878	6110.0	8100.0	8526.0		
December		32727	7902.0	15013.0	13749.0		
January		23312	8728.0	13200.0	13156.8		
February		19822	7217.0	7508.0	8835.0		
March		17981	7181.0	6177.0	8014.8		
April		15081	6915.0	8397.0	9187.2		
May		11855	5940.0	7333.0	7963.8		
June		10515	4475.0	6303.0	6466.8		
July		9240	4030.0	5190.0	5532.0		
August		7661	3883.0	4783.0	5199.6		
September		9159	4192.0	5001.0	5515.8		
Fuel energy, based on steam production, 1990 (MBtu):							
October		12396.1	5124.6	4864.7	5993.6		
November		16376.1	5300.2	7026.5	7396.0		
December		29336.0	7083.2	13457.4	12324.4		
January		20896.5	7823.7	11832.2	11793.6		
February		16048.7	5843.2	6078.8	7153.2		
March		16117.9	6436.9	5537.0	7184.4		

* = estimated

Table 38 (Cont'd)

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 Use	\$/MBtu	MBtu '90
Fuel energy, based on steam production, 1990 (MBtu) (cont'd):							
April		13082.3	5998.6	7284.1	7969.6		
May		10626.7	5324.5	6573.2	7138.6		
June		9121.4	3881.9	5467.7	5609.8		
July		8282.6	3612.4	4652.2	4958.8		
August		6867.2	3480.7	4287.4	4660.8		
September		7945.2	3636.4	4338.2	4784.8		
Total		167096.7	63546.4	81399.5	86967.6		399010.2
Percent of total		41.9	15.9	20.4	21.8		
Reserve fuel		#2	#2	#2	#2		
Fuel use (MBtu/year):							
Natural Gas		155399.9	59098.2	75701.6	80879.8		Total
Dist. Oil		11696.8	4448.2	5698.0	6087.7		371080
Res. Oil		0.0	0.0	0.0	0.0		27931
Total \$/yr:		1900523	634790.6	864295.3	858401.2	0	0
\$/MBtu:							
Labor		2.30	1.93	2.06	1.93		
Utilities		1.42	0.98	1.16	0.93		
Service		0.28	0.20	0.23	0.19		
Supplies		1.92	1.44	1.72	1.38		
Fuel		4.14	4.14	4.14	4.14		Average
Total \$/MBtu		10.06	8.68	9.31	8.56		7.32
Reported \$/MBtu:							

* = estimated

Table 39a

Boiler Evaluation Parts List—Fort Gordon Bldg. 25330

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)					
1. Boiler Pressure Parts and Setting	1975	2	35 MBtu/hr		Good
2. Relief Valve(s)	1988	2	150 psig	365 temp	Good
2. Relief Valve(s)	1988	2	1.5 in.	250 psig	Good
3. Feedwater Regulator(s)	1975	2	2 in.	255 psig	Good
4. Boiler Burner(s)	1975	2	2 in.	200 psig	Good
5. Boiler Fan(s) (FD)	1975	2	35 MBtu		Good
7. Boiler Drum Level Control	1975	2	15 Hp		Good
B. Feedwater System					
8. Deserating Heater	1975	1	lb/hr	40 gal/min	Good
12. Condensate Pumps	1975	2	20 Hp		Good
13. Condensate Receiver	1975	1	175 gal		Good
15. Make-up Pumps	1975	2	20 Hp		Good
18. Expansion Tank (CASCADES)	1975	2	7 diam (in.)	12 length (ft)	Good
19. Feedwater Piping System (valve)	1975	2	2 diam (in.)	200 psig	Good
20. Cooling Water Pumps	1975	2	175 Hp		Good
21. HTW Distribution System Pumps	1975	2	100 Hp		Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1975	2	50000 gal		Good
4. Fuel Oil Pump	1975	2	gpm	5 Hp	
4. Fuel Oil Pump	1975	2	gpm	7.5 Hp	
5. Fuel Oil Heater	1975	1	gpm		
6. Fuel Oil Piping System (BLW)	1975		4 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1975		6 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	1975	1	3.5 diam (ft)	6 height (ft)	Good
E. Air Pollution Control Systems and Emission Monitoring					
5. Stack	1975	1	4 diam (ft)	65 height (ft)	Good

Table 39a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1975	1	_____		Good
2. Boiler Master	1975	2	_____		Good
3. Flame Safeguard System	1975	2	_____		Good
5. Additional Boiler Instrumentation/Indicators				O2 charted-part of master Stack Smoke Detector	Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	_____	_____	_____ gal	_____ Hp	
H. Make-up Water System					
9. Sodium Zeolite Softener	1975	2	_____ gpm		
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1975	3	_____ SCFM	10 Hp	Good
2. Air Dryer (REFR)	1975	1	_____ 55 SCFM		Good
3. Air Receiver	1975	1	_____ 200 gal		
K. Electrical System					
1. Transformer/TransPCB	_____	_____	_____ KVA		
2. Switchgear - Main Circuit Breaker	_____	_____	_____ amps		
3. Motor Control Center/Starter	_____	_____	_____ amps		
4. Emergency Generator	1975	1	_____ 165 KVA		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1975				Good
2. Building Concrete and Building Steel	1975				Good
3. Sump Pump (SUBMERGE/VERTICAL)	1975	2	_____ gpm	1.5 Hp	Good
4. Building Lighting	1975				Good
Building Outside Dimensions	_____	Ht (ft)	_____ Lgth (ft)	_____ Width (ft)	
Building Basement (Yes/No)	_____				

Table 39b

**Status Quo Life Cycle Cost Analysis for
Fort Gordon Building 25330**

LIFE CYCLE COST ANALYSIS **STUDY: TDGRD3**
LCCID 1.065 **DATE/TIME: 05-14-92 16:59:50**
PROJECT NO., FY, & TITLE: FY 1992 **BUILDING 25330**
INSTALLATION & LOCATION: FORT GORDON **GEORGIA**
DESIGN FEATURE:
ALT. ID. A; TITLE: STATUS QUO
NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS) **MAY 92**
MIDPOINT OF CONSTRUCTION (MPC) **JUN 92**
BENEFICIAL OCCUPANCY DATE (BOD) **JAN 93**
ANALYSIS END DATE (AED) **JAN 18**

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$	(\$ X 10**0)	COST INCURRED
		(% PER YEAR)	
=====	=====	=====	=====
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	23133.9	1.58	JUL93-JUL17
NATURAL GAS	416361.0	3.64	JUL93-JUL17
MAINT LABOR	167500.0	.00	JUL93-JUL17
MAINT SERV	18919.0	.00	JUL93-JUL17
MAINT SUPPLY	140000.0	.00	JUL93-JUL17
MAINT UTIL	94595.0	.00	JUL93-JUL17
STACK	18000.0	.00	JAN 15
DRUMCTL	10000.0	.00	JAN 95
FW_REG	1266.0	.00	JAN 15
F_FAN	17250.0	.00	JAN 15
RELVALVE	2492.0	.00	JAN 08
RELVALVE	2708.0	.00	JAN 08
WTBOILER	1575000.0	.00	JAN 15
WTBURNER	120000.0	.00	JAN 15
BOILMASTER	10000.0	.00	JAN 05
FLAMESAFE	20000.0	.00	JAN 05
PLANTMASTER	5000.0	.00	JAN 05
AIRCOMPRECIP	60000.0	.00	JAN 95
AIRDRYERREFR	12100.0	.00	JAN 90
AIRRECV	1100.0	.00	JAN 05
EMERGENCYGEN	172186.0	.00	JAN 05
CONDPUMP	14000.0	.00	JAN 95
CONDREC	7500.0	.00	JAN 05
COOLPUMP	22800.0	.00	JAN 95
DAIRHEATER	25000.0	.00	JAN 15
EXPTANK	49000.0	.00	JAN 15
FWPIPINGVAL	1167.0	.00	JAN 95
HTWPUMP	48000.0	.00	JAN 05
MUPUMP	14000.0	.00	JAN 95

Table 39b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:59:50
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 25330
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

HEATER	4000.0	.00	JAN 05
NAGPIPEBELOW	40.0	.00	JAN 00
OILPIPEBELOW	49.0	.00	JAN 00
PUMP	3000.0	.00	JAN 00
PUMP	5000.0	.00	JAN 00
TANKBELOW	114000.0	.00	JAN 05
FLASH TANK	1775.0	.00	JAN 00
SZSOFT	140000.0	.00	JAN 95
SUMPPUMPVERT	10000.0	.00	JAN 90

=====

OTHER KEY INPUT DATA

LOCATION - GEORGIA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	4.06 5698.0		JAN93-JAN18
NAT G	5.50 75702.0		JAN93-JAN18

Table 39b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:59:50
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 25330
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	398395.
NATURAL GAS	9096 ² 53.
TOTAL ENERGY COSTS	9495258.
RECURRING M&R/CUSTODIAL COSTS	6132983.
MAJOR REPAIR/REPLACEMENT COSTS	1109354.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	16737600.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 39b (Cont'd)

LOCID 1.065 DATE/TIME: 05-14-92 16:59:50
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 25330
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	22132.	399699.	399493.	0.	0.
2	21175.	388067.	381925.	0.	0.
3	20196.	372035.	365129.	232360.	0.
4	19303.	355674.	349072.	0.	0.
5	18472.	342851.	333720.	0.	0.
6	17770.	332715.	319044.	0.	0.
7	17353.	334732.	305014.	0.	0.
8	17055.	342170.	291600.	6987.	0.
9	16810.	352606.	278776.	0.	0.
10	16638.	369274.	266517.	0.	0.
11	16464.	380813.	254796.	0.	0.
12	16267.	384732.	243591.	0.	0.
13	16059.	392984.	232878.	215983.	0.
14	15772.	397431.	222637.	0.	0.
15	15426.	399155.	212846.	0.	0.
16	15012.	394844.	203486.	2570.	0.
17	14558.	385176.	194537.	0.	0.
18	14057.	379995.	185982.	0.	0.
19	13616.	370598.	177803.	0.	0.
20	13261.	360955.	169984.	0.	0.
21	12930.	351940.	162508.	0.	0.
22	12577.	342319.	155362.	0.	0.
23	12221.	332637.	148529.	651453.	0.
24	11825.	321865.	141998.	0.	0.
25	11448.	311596.	135753.	0.	0.
***	398395.	9096863.	6132983.	1109354.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 40a

Boiler Evaluation Parts List—Fort Gordon Bldg. 25910

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)	1965	3	33.25 MBtu/hr		Good
A. Boiler (WT)	1967	2	34 MBtu/hr		Good
1. Boiler Pressure Parts and Setting	1988	5	170 psig	365 temp	Good
2. Relief Valve(s)	1988	5	2 in.	250 psig	Good
3. Feedwater Regulator(s)	1988	6	2 in.	256 psig	Good
4. Boiler Burner(s)	1965	3	3 in.	250 psig	Good
4. Boiler Burner(s)	1967	2	45 MBtu		Good
5. Boiler Fan(s) (FD)	1965	3	45 MBtu		Good
5. Boiler Fan(s) (FD)	1967	2	20 Hp		Good
5. Boiler Fan(s) (ID)	1965	3	20 Hp		Good
5. Boiler Fan(s) (ID)	1967	2	20 Hp		Good
6. Boiler Economizer	Out of Service				
7. Boiler Drum Level Control	1988	5	20 Hp		Good
B. Feedwater System					
8. Desaerating Heater	1991	1	lb/hr	40 gal/min	Good
15. Make-up Pumps	1985	1	7 Hp		Good
18. Expansion Tank (Cascades)	1965	3	387000 lb/hr		Good
19. Feedwater Piping System (valve)	1965		3 diam (in.)	250 psig	Good
20. Cooling Water Pumps	1965	4	300 Hp		Good
21. HTW Distribution System Pumps	1985	6	75 Hp		Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1965	8	50000 gal		Good
4. Fuel Oil Pump	1965	2	gpm		
4. Fuel Oil Pump	1965	2	gpm		
5. Fuel Oil Heater	1965	2	gpm		
6. Fuel Oil Piping System (BLW)	1965		2.5 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1965		5 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	1965	1	3.5 diam (ft)	6 height (ft)	Good
E. Air Pollution Control Systems					
5. Stack	1982	1	4 diam (ft)	110 height (ft)	Good

Table 40a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1989	1			Good
2. Boiler Master	1989	5			Good
3. Flame Safeguard System	1965	3			Good
3. Flame Safeguard System	1967	2			Good
5. Additional Boiler Instrumentation/Indicators	1989		O2 TRIM - part of master		Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps			gal	Hp	Good
H. Make-up Water System					
9. Sodium Zeolite Softener	1982	2	gpm		
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1979	2	SCFM	15 Hp	
1. Air Compressor (RECIP)	1979	1	SCFM	10 Hp	
2. Air Dryer (REFR)	1965	1	55 SCFM		Good
3. Air Receiver	1965	2	200 gal		Good
3. Air Receiver	1965	1	75 gal		Good
K. Electrical System					
1. Transformer/TransPCB			KVA		
2. Switchgear - Main Circuit Breaker			amps		
3. Motor Control Center/Starter			amps		
4. Emergency Generator	1965	1	94 KVA		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1965				Good
2. Building Concrete and Building Steel	1965				Good
3. Sump Pump (SUBMERGE/VERTICAL)	1985	2	gpm	0.75 Hp	
4. Building Lighting	1965				Good
Building Outside Dimensions		Ht (ft)	Lgth (ft)	Width (ft)	
Building Basement (Yes/No)					

Table 40b

**Status Quo Life Cycle Cost Analysis for
Fort Gordon Building 25910**

LIFE CYCLE COST ANALYSIS		STUDY: TDGRD1
LCCID 1.065	DATE/TIME: 05-15-92 09:11:14	
PROJECT NO., FY, & TITLE: FY 1992	BUILDING 25910	
INSTALLATION & LOCATION: FORT GORDON	GEORGIA	
DESIGN FEATURE:		
ALT. ID. A; TITLE: STATUS QUO		
NAME OF DESIGNER:		

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS)	MAY 92
MIDPOINT OF CONSTRUCTION (MPC)	JUN 92
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 93
ANALYSIS END DATE (AED)	JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	COST INCURRED
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	47489.8	1.58	JUL93-JUL17
NATURAL GAS	854700.0	3.64	JUL93-JUL17
MAINT LABOR	385000.0	.00	JUL93-JUL17
MAINT SERV	47446.0	.00	JUL93-JUL17
MAINT SUPPLY	320880.0	.00	JUL93-JUL17
MAINT UTIL	237230.0	.00	JUL93-JUL17
DRUMCTL	25000.0	.00	JAN 08
F_FAN	30750.0	.00	JAN 05
F_FAN	20500.0	.00	JAN 07
I_FAN	30750.0	.00	JAN 05
I_FAN	20500.0	.00	JAN 07
RELVALVE	6730.0	.00	JAN 08
RELVALVE	6775.0	.00	JAN 08
WTBOILER	2298750.0	.00	JAN 05
WTBOILER	1550000.0	.00	JAN 07
WTBURNER	210000.0	.00	JAN 05
WTBURNER	140000.0	.00	JAN 07
FLAMESAFE	30000.0	.00	JAN 95
FLAMESAFE	20000.0	.00	JAN 97
AIRCOMPRECIP	20000.0	.00	JAN 99
AIRCOMPRECIP	46000.0	.00	JAN 99
AIRDRYERREFR	12100.0	.00	JAN 95
AIRRECV	600.0	.00	JAN 95
AIRRECV	2200.0	.00	JAN 95
EMERGENCYGEN	35000.0	.00	JAN 95
COOLPUMP	45600.0	.00	JAN 95
EXPTANK	73500.0	.00	JAN 05
FWPIPINGVAL	1233.0	.00	JAN 95
HTWPUMP	138000.0	.00	JAN 15

Table 40b (Cont'd)

LCCID 1.065 DATE/TIME: 05-15-92 09:11:14
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 25910
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

MUPUMP	4900.0	.00	JAN 05	
HEATER	5000.0	.00	JAN 95	
NAGPIPEBELOW	32.0	.00	JAN 00	
OILPIPEBELOW	31.0	.00	JAN 00	
PUMP	3000.0	.00	JAN 00	
PUMP	5000.0	.00	JAN 00	
TANKBELOW	456000.0	.00	JAN 95	
FLASHTANK	1775.0	.00	JAN 00	
SZSOFT	410000.0	.00	JAN 02	
SUMPPOMPVERT	9800.0	.00	JAN 00	

=====

OTHER KEY INPUT DATA

LOCATION - GEORGIA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	4.06 11697.0		JAN93-JAN18
NAT G	5.50 155400.0		JAN93-JAN18

Table 48b (Cont'd)

LCCID 1.065 DATE/TIME: 05-15-92 09:11:14
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 25910
 INSTALLATION & LOCATION: PORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	817834.
NATURAL GAS	18673910.
TOTAL ENERGY COSTS	19491750.
RECURRING M&R/CUSTODIAL COSTS	14429600.
MAJOR REPAIR/REPLACEMENT COSTS	3328013.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	37249360.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 40b (Cont'd)

LCCID 1.065 DATE/TIME: 05-15-92 09:11:14
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 25910
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	45433.	820496.	939923.	0.	0.
2	43469.	796618.	898588.	0.	0.
3	41458.	763707.	859070.	521309.	0.
4	39626.	730122.	821291.	0.	0.
5	37919.	703799.	785173.	16214.	0.
6	36479.	682992.	750643.	0.	0.
7	35622.	687134.	717632.	48903.	0.
8	35011.	702403.	686073.	13911.	0.
9	34508.	723826.	655902.	0.	0.
10	34154.	758040.	627057.	265447.	0.
11	33797.	781727.	599481.	0.	0.
12	33393.	789773.	573117.	0.	0.
13	32966.	806713.	547913.	1498384.	0.
14	32376.	815840.	523818.	0.	0.
15	31667.	819379.	500782.	895019.	0.
16	30817.	810531.	478759.	19034.	0.
17	29884.	790683.	457704.	0.	0.
18	28856.	780049.	437576.	0.	0.
19	27951.	760759.	418333.	0.	0.
20	27223.	740964.	399936.	0.	0.
21	26543.	722457.	382348.	0.	0.
22	25818.	702708.	365533.	0.	0.
23	25088.	682833.	349458.	49792.	0.
24	24275.	660721.	334090.	0.	0.
25	23501.	639640.	319398.	0.	0.
***	817834.	*****	*****	3328013.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 41a

Boiler Evaluation Parts List—Fort Gordon Bldg. 2202

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)					
1. Boiler Pressure Parts and Setting	1972	2	30 MBtu/hr		Good
2. Relief Valve(s)	1972	2	125 psig	344 temp	Good
2. Relief Valve(s)	1972	2	2.5 in.	140 psig	Good
3. Feedwater Regulator(s)	1972	2	2.5 in.	155 psig	Good
4. Boiler Burner(s)	1972	2	2 in.	125 psig	Good
5. Boiler Fan(s) (FD)	1972	2	38.97 MBtu		Good
6. Boiler Economizer	1972	2	20 Hp		Good
7. Boiler Drum Level Control	1972	2	MBtu	30 lb/hr	Good
B. Feedwater System					
8. Deserating Heater	1972	1	lb/hr		
12. Condensate Pumps	1972	1	1.5 Hp		Good
13. Condensate Receiver	1972	1	25 gal		Good
15. Make-up Pumps	1972	2	20 Hp		Good
19. Feedwater Piping System (valve)	1972		2 diam (in.)	125 psig	Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1972	2	30000 gal		Good
4. Fuel Oil Pump	1972	1	gpm	2 Hp	
5. Fuel Oil Heater	1972	1	gpm		
6. Fuel Oil Piping System (BLW)	1972		2 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1972		2.5 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	1972	1	3.5 diam (ft)	6 height (ft)	Good
E. Air Pollution Control Systems and Emissions Monitoring					
5. Stack	1972	2	2.5 diam (ft)	60 height (ft)	Good
F. Combustion Controls					
1. Plant Master	1972	1			Good
2. Boiler Master	1972	2			Good
3. Flame Safeguard System	1972	2			Good
5. Additional Boiler Instrumentation/Indicators			O2 chart		Good
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps			gal	Hp	
H. Make-up Water System					
9. Sodium Zeolite Softener	1991	1	gpm		

Table 41a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
I. Condensate Potholing					
J. Compressed Air System					
1. Air Compressor (RECTP)	1972	1	SCFM	1 Hp	Good
2. Air Dryer (REFR)	1972	1	35 SCFM		Good
3. Air Receiver	1972	1	10 gal		Good
K. Electrical System					
1. Transformer/TransPCB	—	—	KVA		
2. Switchgear -- Main Circuit Breaker	—	—	amps		
3. Motor Control Center/Starter	—	—	amps		
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1972				Good
2. Building Concrete and Building Steel	1972				Good
4. Building Lighting	1972				Good
Building Outside Dimensions		Ht (ft)	Length (ft)	Width (ft)	
Building Basement (Yes/No)					

Table 41b

**Status Quo Life Cycle Cost Analysis for
Fort Gordon Building 2202**

LIFE CYCLE COST ANALYSIS		STUDY: TDGRD4
LCCID 1.065	DATE/TIME: 05-14-92	17:03:58
PROJECT NO., FY, & TITLE: FY 1992	BUILDING 2202	
INSTALLATION & LOCATION: FORT GORDON	GEORGIA	
DESIGN FEATURE:		
ALT. ID. A;	TITLE: STATUS QUO	
NAME OF DESIGNER:		

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS)	MAY 92
MIDPOINT OF CONSTRUCTION (MPC)	JUN 92
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 93
ANALYSIS END DATE (AED)	JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S) COST INCURRED
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	24717.3	1.58	JUL93-JUL17
NATURAL GAS	444840.0	3.64	JUL93-JUL17
MAINT LABOR	167500.0	.00	JUL93-JUL17
MAINT SERV	16216.0	.00	JUL93-JUL17
MAINT SUPPLY	120000.0	.00	JUL93-JUL17
MAINT UTIL	81081.0	.00	JUL93-JUL17
STACK	29000.0	.00	JAN 12
DRUMCTL	10000.0	.00	JAN 92
ECONOMIZER	140000.0	.00	JAN 92
FW_REG	1200.0	.00	JAN 12
F_FAN	20500.0	.00	JAN 12
RELVALVE	3044.0	.00	JAN 92
RELVALVE	1545.0	.00	JAN 92
WTBOILER	1450000.0	.00	JAN 12
WTBURNER	128000.0	.00	JAN 12
BOILMASTER	10000.0	.00	JAN 02
FLAMESAFE	20000.0	.00	JAN 02
PLANTMASTER	5000.0	.00	JAN 02
AIRCOMPRECIP	20000.0	.00	JAN 92
AIRDYERREFR	12000.0	.00	JAN 87
AIRRECV	600.0	.00	JAN 02
CONDPUMP	3625.0	.00	JAN 92
CONDREC	6000.0	.00	JAN 02
DAIRHEATER	25000.0	.00	JAN 12
FWPIPINGVAL	1100.0	.00	JAN 92
MUPUMP	14000.0	.00	JAN 92
HEATER	2500.0	.00	JAN 02
NAGPIPEBELOW	16.0	.00	JAN 97
OILPIPEBELOW	25.0	.00	JAN 97

Table 41b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 17:03:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 2202
 INSTALLATION & LOCATION: PORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

PUMP	1300.0	.00	JAN 97	
TANKBELOW	84000.0	.00	JAN 02	
FLASHTANK	1775.0	.00	JAN 97	
SZSOFT	135000.0	.00	JAN 11	

=====

OTHER KEY INPUT DATA

LOCATION - GEORGIA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE: 10**6 BTUS	ELECTRIC DEMAND: 10**0 DOLLARS
ENERGY TYPE \$/MBTU AMOUNT	ELECT. DEMAND PROJECTED DATES
DIST 4.06 6088.0	JAN93-JAN18
NAT G 5.50 80880.0	JAN93-JAN18

Table 41b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 17:03:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 2202
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	425663.
NATURAL GAS	9719086.
TOTAL ENERGY COSTS	10144750.
RECURRING M&R/CUSTODIAL COSTS	5605403.
MAJOR REPAIR/REPLACEMENT COSTS	826635.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	16576790.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS

*ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 41b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 17:03:58
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 2202
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	23647.	427038.	365128.	0.	0.
2	22624.	414611.	349070.	0.	0.
3	21578.	397482.	333719.	0.	0.
4	20624.	380002.	319043.	0.	0.
5	19736.	366302.	305013.	2526.	0.
6	18986.	355472.	291599.	0.	0.
7	18540.	357628.	278776.	0.	0.
8	18222.	365575.	266516.	0.	0.
9	17960.	376725.	254795.	0.	0.
10	17777.	394532.	243590.	8293.	0.
11	17591.	406860.	232878.	0.	0.
12	17380.	411048.	222636.	0.	0.
13	17158.	419864.	212846.	0.	0.
14	16851.	424615.	203485.	0.	0.
15	16482.	426457.	194537.	0.	0.
16	16039.	421851.	185981.	0.	0.
17	15554.	411522.	177802.	0.	0.
18	15019.	405987.	169983.	0.	0.
19	14548.	395947.	162508.	58310.	0.
20	14169.	385645.	155361.	682863.	0.
21	13815.	376013.	148529.	0.	0.
22	13438.	365734.	141997.	0.	0.
23	13057.	355389.	135752.	0.	0.
24	12635.	343881.	129782.	0.	0.
25	12232.	332909.	124075.	0.	0.
***	425663.	9719086.	5605403.	826635.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 42a

Boiler Evaluation Parts List—Fort Gordon Bldg. 310

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)					
1. Boiler Pressure Parts and Setting	1972	3	18 MBtu/hr		Good
2. Relief Valve(s)	1988	3	75 psig	308 temp	Good
2. Relief Valve(s)	1988	3	1.5 in.	140 psig	Good
3. Feedwater Regulator(s)	1972	3	1.5 in.	150 psig	Good
4. Boiler Burner(s)	1972	3	2 in.	120 psig	Good
5. Boiler Fan(s) (FD)	1972	3	20 MBtu		Good
5. Boiler Fan(s) (ID)	1972	3	10 Hp		Good
6. Boiler Economizer	1982	3	10 Hp		Good
7. Boiler Drum Level Control	1987	3	MBtu		Good
B. Feedwater System					
8. Deserating Heater	1972	1	lb/hr		Good
12. Condensate Pumps	1972	2	7 Hp		Good
13. Condensate Receiver	1972	1	35 gal		Good
15. Make-up Pumps	1972	4	15 Hp		Good
18. Expansion Tank (SURGE Tank)	1972	1	4 diam (in.)	8 length (ft)	Good
19. Feedwater Piping System (valve)	1972	2	2 diam (in.)	120 psig	Good
20. Cooling Water Pumps	1972	2	100 Hp		Good
20. Cooling Water Pumps	1972	1	30 Hp		Good
20. Cooling Water Pumps	1972	1	20 Hp		Good
C. Fuel Handling System					
3. Fuel Oil Tank - Underground	1972	1	20000 gal		Good
3. Fuel Oil Tank - Underground	1972	1	30000 gal		Good
3. Fuel Oil Tank - Underground	1972	1	20000 gal		Good
4. Fuel Oil Pump	1972	2	gpm	2 Hp	Good
6. Fuel Oil Piping System (BLW)	1972		1.5 diam (in.)		Good
7. Natural Gas Piping System (BLW)	1972		4 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	1972	1	3.5 diam (ft)	6 height (ft)	Good
E. Air Pollution Control Systems and Emissions Monitoring					
5. Stack	1972	3	2.5 diam (ft)	43 height (ft)	Good

Table 42a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
F. Combustion Controls					
1. Plant Master	1987	1			Good
2. Boiler Master	1987	3			Fair
3. Flame Safeguard System	1987	3			Fair
5. Additional Boiler Instrumentation/Indicators			O2 TRIM - Disconnected		Fair
G. Chemical Feed System					
H. Make-up Water System					
9. Sodium Zeolite Softener	1987	2	_____ gpm		
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1972	2	_____ SCFM	5 Hp	Good
2. Air Dryer (REFR)	1972	1	_____ 15 SCFM		Good
3. Air Receiver	1972	1	_____ 150 gal		Good
K. Electrical System					
1. Transformer	1972	1	2000 KVA		Good
2. Switchgear -- Main Circuit Breaker	_____	_____	_____ amps		
3. Motor Control Center/Starter	_____	_____	_____ amps		
4. Emergency Generator	1972	1	3125 KVA		Good
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1972				Good
2. Building Concrete and Building Steel	1972				Good
4. Building Lighting	1972				Good
Building Outside Dimensions		Ht (ft)	_____	_____	Width (ft)
Building Basement (Yea/No)					

Table 42b

**Status Quo Life Cycle Cost Analysis for
Fort Gordon Building 310**

LIFE CYCLE COST ANALYSIS		STUDY: TDGRD2
LCCID 1.065	DATE/TIME:	05-14-92 16:57:15
PROJECT NO., FY, & TITLE:	FY 1992	BUILDING 310
INSTALLATION & LOCATION:	FORT GORDON	GEORGIA
DESIGN FEATURE:		
ALT. ID. A;	TITLE: STATUS QUO	
NAME OF DESIGNER:		

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.6%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS)	MAY 92
MIDPOINT OF CONSTRUCTION (MPC)	JUN 92
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 93
ANALYSIS END DATE (AED)	JAN 18

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE	TIME(S)
DESCRIPTION	IN DOS \$ (\$ X 10**0)	(% PER YEAR)	COST INCURRED
INVESTMENT COSTS	.0	.00	JUN 92
DISTILLATE OIL	18058.9	1.58	JUL93-JUL17
NATURAL GAS	325039.0	3.64	JUL93-JUL17
MAINT LABOR	122500.0	.00	JUL93-JUL17
MAINT SERV	12405.0	.00	JUL93-JUL17
MAINT SUPPLY	91800.0	.00	JUL93-JUL17
MAINT UTIL	62027.0	.00	JUL93-JUL17
STACK	30000.0	.00	JAN 12
DRUMCTL	15000.0	.00	JAN 07
ECONOMIZER	210000.0	.00	JAN 02
FW_REG	1800.0	.00	JAN 12
F_FAN	21000.0	.00	JAN 12
I_FAN	21000.0	.00	JAN 12
RELVALVE	3216.0	.00	JAN 08
RELVALVE	5100.0	.00	JAN 08
WTBOILER	1800000.0	.00	JAN 12
WTBURNER	150000.0	.00	JAN 12
BOILMASTER	15000.0	.00	JAN 17
FLAMESAFE	30000.0	.00	JAN 17
O2TRIM	30000.0	.00	JAN 17
PLANTMASTER	5000.0	.00	JAN 17
AIRCOMPRECIP	40000.0	.00	JAN 92
AIRDRYERREFR	12000.0	.00	JAN 87
AIRREC	850.0	.00	JAN 02
EMERGENCYGEN	210000.0	.00	JAN 02
TRANSFORMER	44000.0	.00	JAN 12
CONDPUMP	9800.0	.00	JAN 92
CONDREC	6000.0	.00	JAN 02
COOLPUMP	7000.0	.00	JAN 92
COOLPUMP	8200.0	.00	JAN 92

Table 42b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:57:15
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 310
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

COOLPUMP	22800.0	.00	JAN 92
DAIRHEATER	25000.0	.00	JAN 12
EKPTANK	10000.0	.00	JAN 12
FWPIPINGVAL	1100.0	.00	JAN 92
MUPUMP	25000.0	.00	JAN 92
NAGPIPEBELOW	23.0	.00	JAN 97
OILPIPEBELOW	25.0	.00	JAN 97
PUMP	2600.0	.00	JAN 97
TANKBELOW	26000.0	.00	JAN 02
TANKBELOW	42000.0	.00	JAN 02
TANKBELOW	57000.0	.00	JAN 02
FLASHTANK	1775.0	.00	JAN 97
SZSOFT	316666.0	.00	JAN 07

=====

OTHER KEY INPUT DATA

LOCATION - GEORGIA CENSUS REGION: 3
 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMOUNT	ELECT. DEMAND	PROJECTED DATES
DIST	4.06 4448.0		JAN93-JAN18
NAT G	5.50 59098.0		JAN93-JAN18

Table 42b (Cont'd)

LOCID 1.065 DATE/TIME: 05-14-92 16:57:15
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 310
 INSTALLATION & LOCATION: PORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	0.
ENERGY COSTS:	
DISTILLATE OIL	310997.
NATURAL GAS	7101614.
TOTAL ENERGY COSTS	7412610.
RECURRING M&R/CUSTODIAL COSTS	4206008.
MAJOR REPAIR/REPLACEMENT COSTS	1431163.
OTHER O&M COSTS & MONETARY BENEFITS	0.
DISPOSAL COSTS/RETENTION VALUE	0.
LCC OF ALL COSTS/BENEFITS (NET PW)	13049780.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 42b (Cont'd)

LCCID 1.065 DATE/TIME: 05-14-92 16:57:15
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 310
 INSTALLATION & LOCATION: FORT GORDON GEORGIA
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	NAT G	M & R	R / R	OTHER
1	17277.	312031.	273973.	0.	0.
2	16530.	302951.	261925.	0.	0.
3	15765.	290435.	250406.	0.	0.
4	15069.	277662.	239394.	0.	0.
5	14420.	267652.	228866.	3586.	0.
6	13872.	259739.	218801.	0.	0.
7	13546.	261314.	209179.	0.	0.
8	13314.	267121.	199980.	0.	0.
9	13122.	275268.	191185.	0.	0.
10	12988.	288280.	182778.	357285.	0.
11	12852.	297288.	174740.	0.	0.
12	12698.	300347.	167055.	0.	0.
13	12536.	306790.	159708.	0.	0.
14	12312.	310261.	152685.	0.	0.
15	12042.	311607.	145970.	171489.	0.
16	11719.	308242.	139551.	4111.	0.
17	11364.	300694.	133414.	0.	0.
18	10973.	296650.	127547.	0.	0.
19	10629.	289314.	121938.	0.	0.
20	10352.	281786.	116575.	868310.	0.
21	10094.	274748.	111449.	0.	0.
22	9818.	267237.	106547.	0.	0.
23	9540.	259678.	101862.	0.	0.
24	9231.	251269.	97382.	0.	0.
25	8937.	243253.	93100.	26382.	0.
***	310997.	7101614.	4206008.	1431163.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 43

CHEPCON Run Results for Fort Gordon Bldg. 25339

Technology	Boiler	\$/MBTU	\$/KWH	K\$INV.	K\$FUEL	K\$LOC	LOC/R
New Plant							
GAS	24/24/24	16.583	19.826	4498	37779	49672	100
#2 OIL	24/24/24	12.867	15.384	4498	26650	38543	78
#6 OIL	24/24/24	10.330	12.350	4498	19049	30942	62
STOKER	16/28/28/28	22.824	27.289	35846	10360	68368	138
CWS	14/28/35/35	18.869	22.559	24739	14323	59062	119
COM	17/29/29/29	18.556	22.186	21252	17932	58085	117
FBC	13/26/33/33	23.106	27.625	33669	12729	69211	139

FILE PREFIX: PGDI

PMCR: 70 L

AVE MON. LOAD: 23 M

CHP #1 2@ 35 L FUEL = NG, FS2 AGE = 1975

L = (K\$ STEAM/HR)

M = (MBTU/HR)

Table 44

CHPECON Run Results for Fort Gordon Bldg. 25910

Technology	Boiler	\$/MBTU	\$/K#STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	59/59/59	14.574	17.425	6890	96487	111986	100
#2 OIL	59/59/59	9.875	11.806	6890	60379	75877	68
#6 OIL	59/59/59	8.322	9.950	6890	48444	63942	57
STOKER	40/69/69/69	13.204	15.787	48926	24030	101461	91
CWS	35/69/88/88	12.368	14.788	39405	35329	99314	89
COM	42/72/72/72	12.071	14.432	30081	44823	96923	87
FBC	32/64/81/81	14.250	17.037	47540	31837	109495	98

FILE PREFIX: PGD2

PMCR: 176 L

AVE MON. LOAD: 59 M

CHP #2 3@ 35.9 L FUEL = NG,FS AGE = 1965

3@ 34 L FUEL = NG,FS AGE = 1967

L=(K# STEAM/HR)

M=(MBTU/HR)

Table 45

CHPECON Run Results for Fort Gordon Bldg. 2202

Technology	Boiler	\$/MBTU	\$/K#STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	20/20/20	17.082	20.424	4300	32891	44494	100
#2 OIL	20/20/20	12.383	14.805	4300	20651	32253	72
#6 OIL	20/20/20	10.829	12.948	4300	16605	28207	63
STOKER	14/24/24/24	25.071	29.975	34817	9059	65302	147
CWS	12/24/30/30	20.493	24.502	23517	12607	55780	125
COM	15/25/25/25	20.118	24.053	20307	15791	54759	123
FBC	11/22/28/28	25.192	30.119	32522	11122	65616	147

FILE PREFIX: PGD3

PMCR: 60 L

AVE MON. LOAD: 20 M

CHP #3 2@ 30 L FUEL = NG,FS2 AGE = 1972

L=(K# STEAM/HR)

M=(MBTU/HR)

Table 46

Cost Sensitivity Analysis for New Gas/Oil Fired Boiler Plant

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: PGDG Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Base and Plant Information

State: GA - Georgia

Base DOE Region: 3

PMCR: 100,000 lb/hr steam

Number of boilers: 3

Height of the plant: 40 ft

Building area: 6500 sq ft

Plant area: 1.13 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 730,093 kW-hr

1991 cost for distillate: 0.631 \$/gallon

1991 cost for residual: 0.400 \$/gallon

1991 cost for natural gas: 2.722 \$/million Btu

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 257,664 thousand lb steam

Annual Natural Gas Usage: 316 10⁶ SCF

Heating plant efficiency: 83.2% natural gas

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 1,010,599	Stack:	\$ 32,911
Building/service:	\$ 949,121	Water trtmnt:	\$ 408,948
Feedwtr pmps:	\$ 17,211	Cond xfr pmps:	\$ 14,703
Cond strg tnk:	\$ 5,489	Oil (long) storage:	\$ 183,313
Oil day strg pmp:	\$ 4,388	Oil heaters:	\$ 4,962
Oil day strg tanks:	\$ 14,929	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 4,544	Fire protection:	\$ 41,792
Cont bldn tnk:	\$ 783	Intr bldn tnk:	\$ 783
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 11,101	Site preparation:	\$ 2,951
Site improvements:	\$ 156,723	Mobile equipment:	\$ 40,748
Elec substation:	\$ 56,990	Electrical:	\$ 121,787
Piping:	\$ 690,129	Instrumentation:	\$ 255,174
Direct costs:	\$ 1,478,264		

Table 46 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: PGDG Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Facility Capital Costs, cont

Plant installed cost: \$ 5,899,197

Facility Annual O & M and Energy Costs

Operating staff: 11

Annual Labor Costs: \$ 463,732

Annual Year Non-Labor O & M Costs : \$ 564,338

1995 Natural gas costs : \$ 1,111,374

1995 Auxiliary Energy Costs : \$ 38,781

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 5,920
10 years	\$ 159,115	15 years	\$ 67,520
18 years	\$ 5,881	20 years	\$ 12,754

Facility Life Cycle Cost Summary

Analysis using natural gas as primary fuel

+ PV 'Adjusted' Investment Costs	= \$ 5,169,447
+ PV Energy + Transportation Costs	= \$ 23,950,742
+ PV Annually Recurring O&M Costs	= \$ 7,319,586
+ PV Non-Annually Recurring Repair & Replacement	= \$ 320,675
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991) = \$ 36,760,450

Levelized Cost of Service (1995 start) = 9.5966 \$/MMBtu

Levelized Cost of Service (1995 start) = 11.473 \$/1000 lb steam

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	11,703,494	25,056,955	7.820
60%	14,044,193	27,397,654	8.551

Table 46 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: PGDG Type: New plant (NP)
 Desc: FORT GORDON
 Tech: Gas / Oil Fired Boiler

Page 3
05/13/92

 Sensitivity Analysis, cont

80%	18,725,591	32,079,052	10.012
90%	21,066,290	34,419,751	10.743
100%	23,406,989	36,760,450	11.473
110%	25,747,688	39,101,149	12.204
120%	28,088,387	41,441,848	12.934
130%	30,429,086	43,782,547	13.665
140%	32,769,785	46,123,246	14.396
150%	35,110,484	48,463,945	15.126

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	16,316,909	29,670,370	9.260
-2%	18,333,295	31,686,756	9.890
-1%	20,676,900	34,030,361	10.621
0%	23,406,989	36,760,450	11.473
1%	26,593,946	39,947,408	12.468
2%	30,321,368	43,674,829	13.631
3%	34,688,529	48,041,991	14.994
4%	39,813,314	53,166,775	16.594
5%	45,835,664	59,189,125	18.474
6%	52,921,668	66,275,129	20.685

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	435,002	36,651,700	11.439
90%	489,377	36,706,075	11.456
100%	543,752	36,760,450	11.473
110%	598,127	36,814,825	11.490
120%	652,503	36,869,201	11.507

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,820,558	35,555,310	11.097
90%	5,423,128	36,157,880	11.285
100%	6,025,698	36,760,450	11.473
110%	6,628,268	37,363,020	11.661
120%	7,230,838	37,965,590	11.849

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,035,109	36,501,673	11.392
90%	1,164,498	36,631,061	11.433
100%	1,293,887	36,760,450	11.473
110%	1,423,276	36,889,839	11.514

Table 46 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: PGDG Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	256,540	36,696,315	11.453
90%	288,607	36,728,383	11.463
100%	320,675	36,760,450	11.473
110%	352,742	36,792,518	11.483
120%	384,810	36,824,585	11.493

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,135,557	35,583,743	11.106
90%	4,652,502	36,172,097	11.290
100%	5,169,447	36,760,450	11.473
110%	5,686,391	37,348,804	11.657
120%	6,203,336	37,937,157	11.840

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-149,970	36,910,421	11.520
-10%	-99,980	36,860,431	11.504
-5%	-49,990	36,810,440	11.489
0%	0	36,760,450	11.473
5%	49,990	36,710,460	11.458
10%	99,980	36,660,470	11.442
15%	149,970	36,610,479	11.426

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	70,455,438	21.990
0.5%	65,060,408	20.306
1.5%	55,793,510	17.414
2.5%	48,203,139	15.045
3.5%	41,947,628	13.092
4.5%	36,760,450	11.473
5.5%	32,432,735	10.122
6.5%	28,800,038	8.989
7.5%	25,732,296	8.031
8.5%	23,126,163	7.218

Table 46 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FGDG Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

10.5%	18,985,100	5.925
11.5%	17,330,735	5.409
12.0%	16,587,122	5.177

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	19,252,357	11.260
11 yr	20,573,828	11.164
12 yr	21,905,503	11.118
13 yr	23,222,908	11.100
14 yr	24,525,950	11.103
15 yr	25,856,367	11.142
16 yr	27,103,773	11.166
17 yr	28,310,518	11.191
18 yr	29,494,525	11.225
19 yr	30,628,265	11.256
20 yr	31,791,512	11.311
21 yr	32,862,038	11.346
22 yr	33,884,866	11.377
23 yr	34,873,673	11.408
24 yr	35,836,717	11.442
25 yr	36,760,450	11.473

Table 47

Cost Sensitivity Analysis for #6 Oil-Fired Boiler Plant

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: FGD6 Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Base and Plant Information

State: GA - Georgia

Base DOE Region: 3

PMCR: 100,000 lb/hr steam

Number of boilers: 3

Height of the plant: 40 ft

Building area: 6500 sq ft

Plant area: 1.13 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 730,093 kW-hr

1991 cost for distillate: 0.631 \$/gallon

1991 cost for residual: 0.400 \$/gallon

1991 cost for natural gas: 2.722 \$/million Btu

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 257,664 thousand lb steam

Annual #6 Fuel Oil Usage: 2,256 10³ gal

Heating plant efficiency: 87.8% #6 fuel oil

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 1,010,599	Stack:	\$ 32,911
Building/service:	\$ 949,121	Water trtmnt:	\$ 408,948
Feedwtr pmps:	\$ 17,211	Cond xfr pmps:	\$ 14,703
Cond strg tnk:	\$ 5,489	Oil (long) storage:	\$ 183,313
Oil day strg pmp:	\$ 4,388	Oil heaters:	\$ 4,962
Oil day strg tanks:	\$ 14,929	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 4,544	Fire protection:	\$ 41,792
Cont bldn tnk:	\$ 783	Intr bldn tnk:	\$ 783
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 11,101	Site preparation:	\$ 2,951
Site improvements:	\$ 156,723	Mobile equipment:	\$ 40,748
Elec substation:	\$ 56,990	Electrical:	\$ 121,787
Piping:	\$ 690,129	Instrumentation:	\$ 255,174
Direct costs:	\$ 1,478,264		

Table 47 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: PGD6 Type: New plant (NP)
 Desc: FORT GORDON
 Tech: Gas / Oil Fired Boiler

Page 2
 05/13/92

 Facility Capital Costs, cont

Plant installed cost: \$ 5,899,197

 Facility Annual O & M and Energy Costs

Operating staff: 11
 Annual Labor Costs: \$ 463,732
 Annual Year Non-Labor O & M Costs : \$ 564,338
 1995 #6 fuel oil costs : \$ 1,213,004
 1995 Auxiliary Energy Costs : \$ 38,781

 Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 5,920
10 years	\$ 159,115	15 years	\$ 67,520
18 years	\$ 5,881	20 years	\$ 12,754

 Facility Life Cycle Cost Summary

Analysis using #6 fuel oil as primary fuel

+ PV 'Adjusted' Investment Costs	= \$ 5,169,447
+ PV Energy + Transportation Costs	= \$ 24,325,649
+ PV Annually Recurring O&M Costs	= \$ 7,319,586
+ PV Non-Annually Recurring Repair & Replacement	= \$ 320,675
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0
Total Life Cycle Cost (1991)	= \$ 37,135,358
Levelized Cost of Service (1995 start)	= 9.6944 \$/MMBtu
Levelized Cost of Service (1995 start)	= 11.590 \$/1000 lb steam

 Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	11,890,948	25,244,409	7.879
60%	14,269,138	27,622,599	8.621

Table 47 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FGD6

Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

80%	19,025,517	32,378,978	10.106
90%	21,403,707	34,757,168	10.848
100%	23,781,897	37,135,358	11.590
110%	26,160,086	39,513,547	12.333
120%	28,538,276	41,891,737	13.075
130%	30,916,466	44,269,927	13.817
140%	33,294,655	46,648,117	14.559
150%	35,672,845	49,026,306	15.302

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	16,835,067	30,188,528	9.422
-2%	18,818,531	32,171,992	10.041
-1%	21,115,443	34,468,904	10.758
0%	23,781,897	37,135,358	11.590
1%	26,884,461	40,237,922	12.559
2%	30,502,138	43,855,599	13.688
3%	34,728,690	48,082,151	15.007
4%	39,675,381	53,028,842	16.551
5%	45,474,228	58,827,690	18.361
6%	52,281,834	65,635,295	20.486

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	435,002	37,026,607	11.556
90%	489,377	37,080,982	11.573
100%	543,752	37,135,358	11.590
110%	598,127	37,189,733	11.607
120%	652,503	37,244,108	11.624

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,820,558	35,930,218	11.214
90%	5,423,428	36,532,788	11.402
100%	6,025,698	37,135,358	11.590
110%	6,628,268	37,737,928	11.778
120%	7,230,838	38,340,498	11.966

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,035,109	36,876,580	11.509
90%	1,164,498	37,005,969	11.550
100%	1,293,887	37,135,358	11.590
110%	1,423,276	37,264,746	11.631

Table 47 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FGD6 Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	256,540	37,071,223	11.570
90%	288,607	37,103,290	11.580
100%	320,675	37,135,358	11.590
110%	352,742	37,167,425	11.600
120%	384,810	37,199,493	11.610

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,135,557	35,958,651	11.223
90%	4,652,502	36,547,004	11.407
100%	5,169,447	37,135,358	11.590
110%	5,686,391	37,723,711	11.774
120%	6,203,336	38,312,065	11.957

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-149,970	37,285,329	11.637
-10%	-99,980	37,235,338	11.621
-5%	-49,990	37,185,348	11.606
0%	0	37,135,358	11.590
5%	49,990	37,085,368	11.575
10%	99,980	37,035,377	11.559
15%	149,970	36,985,387	11.543

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	70,177,616	21.903
0.5%	64,909,791	20.259
1.5%	55,844,949	17.430
2.5%	48,401,080	15.106
3.5%	42,249,979	13.187
4.5%	37,135,358	11.590
5.5%	32,856,137	10.255
6.5%	29,253,815	9.130
7.5%	26,202,864	8.178
8.5%	23,603,405	7.367

Table 47 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FGD6 Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

10.5%	19,455,307	6.072
11.5%	17,790,803	5.552
12.0%	17,041,039	5.318

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	20,245,614	11.841
11 yr	21,605,160	11.723
12 yr	22,948,136	11.647
13 yr	24,241,311	11.586
14 yr	25,497,253	11.543
15 yr	26,764,610	11.534
16 yr	27,950,655	11.515
17 yr	29,097,989	11.503
18 yr	30,224,349	11.503
19 yr	31,302,163	11.503
20 yr	32,411,164	11.531
21 yr	33,429,317	11.542
22 yr	34,401,581	11.550
23 yr	35,341,472	11.561
24 yr	36,257,296	11.576
25 yr	37,135,358	11.590

Table 48

Cost Sensitivity Analysis for Coal-Fired Stoker Plant

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 1

File: FGDC Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Base and Plant Information
*****State: GA - Georgia
PMCR: 100,000 lb/hr steamBase DOE Region: 3
Number of boilers: 4

Coal code: W205320

Distance from base: 278 miles

State: KY - Kentucky

DOE Region: 3

Coal type: bituminous

(properties on a dry basis)

hhv: 12870 Btu/lb fixed carbon: 52.20% volatiles: 38.10%

ash: 9.70% sulfur: 0.50%

Coal handling equipment capacity: 50 tons/hr

Coal silo storage capacity: 374 tons

Approx. building width: 58 feet

Approx. building length: 141 feet

Height of the plant: 59 ft

Building area: 8210 sq ft

Plant area: 1.31 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)

Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)

Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)

Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual diesel/distillate fuel usage: 16,400 gallons

Annual electricity usage: 2,704,433 kW-hr

Annual lime usage: 261 tons

1991 cost for coal: 1.715 \$/MMBtu

1991 cost for distillate: 0.631 \$/gallon

1991 cost for electricity: 0.053 \$/kW-hr

Annual Facility Output: 257,664 thousand lb steam

Annual Coal Usage: 13,398 tons (dry) / 14,202 tons (wet)

Heating plant efficiency: 84%

Year of Study: 1991

Years of Operation: 1995 - 2019

Facility Installed Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 9,318,324	Coal Handling:	\$ 4,995,812
Ash Handling:	\$ 2,047,997	Mechnc'l Collector:	\$ 134,619

Table 48 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FGDC Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Installed Capital Costs, cont

Water Treatment:	\$	696,631	Pumps:	\$	172,781
Air Compressor:	\$	72,152	Waste Water Trtmnt:	\$	97,065
Piping/Stack:	\$	3,300,834	Electrical System:	\$	1,630,032
Building Costs:	\$	3,710,787	Direct costs:	\$	10,521,182

Plant installed cost: \$ 44,689,453

Facility Annual O & M and Energy Costs

Operating staff: 22

Annual Labor Costs: \$ 963,353

First Year Non-Labor O & M Costs : \$ 1,338,611

Annual Year Non-Labor O & M Costs : \$ 1,663,506

1995 Coal Costs (incl transport) : \$ 730,510

1995 Auxiliary Energy Costs : \$ 156,265

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 95,774	5 years	\$ 92,079
7 years	\$ 79,583	8 years	\$ 222,604
10 years	\$ 542,186	12 years	\$ 44,074
15 years	\$ 9,352	18 years	\$ 11,754
20 years	\$ 427,964		

Facility Life Cycle Cost Summary

+ PV 'Adjusted' Investment Costs	= \$ 39,161,216
+ PV Energy + Transportation Costs	= \$ 12,773,403
+ PV Annually Recurring O&M Costs	= \$ 21,343,004
+ PV Non-Annually Recurring Repair & Replacement	= \$ 1,728,076
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991) = \$ 75,005,701

Levelized Cost of Service (1995 start) = 19.580 \$/MMBtu

Table 48 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FGDC Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	5,269,249	69,736,451	21.766
60%	6,323,099	70,790,301	22.095
70%	7,376,949	71,844,151	22.424
80%	8,430,799	72,898,001	22.752
90%	9,484,649	73,951,851	23.081
100%	10,538,499	75,005,701	23.410
110%	11,592,349	76,059,551	23.739
120%	12,646,199	77,113,401	24.068
130%	13,700,049	78,167,251	24.397
140%	14,753,899	79,221,101	24.726
150%	15,807,749	80,274,951	25.055

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	7,637,237	72,104,439	22.505
-2%	8,469,298	72,936,500	22.765
-1%	9,428,862	73,896,064	23.064
0%	10,538,499	75,005,701	23.410
1%	11,824,979	76,292,181	23.812
2%	13,320,050	77,787,252	24.279
3%	15,061,375	79,528,577	24.822
4%	17,093,624	81,560,826	25.456
5%	19,469,776	83,936,978	26.198
6%	22,252,654	86,719,856	27.067

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,787,923	74,558,721	23.271
90%	2,011,413	74,782,211	23.341
100%	2,234,903	75,005,701	23.410
110%	2,458,394	75,229,192	23.480
120%	2,681,884	75,452,682	23.550

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	10,014,185	72,502,155	22.629
90%	11,265,959	73,753,928	23.020
100%	12,517,732	75,005,701	23.410
110%	13,769,505	76,257,475	23.801
120%	15,021,278	77,509,248	24.192

=== O&M non-labor cost variation ===

Table 48 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FGDC Type: New plant (NP)

05/13/92

Desc: FORT GORDON

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis, cont

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	7,060,217	73,240,647	22.859
90%	7,942,744	74,123,174	23.135
100%	8,825,272	75,005,701	23.410
110%	9,707,799	75,888,229	23.686
120%	10,590,326	76,770,756	23.961

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	1,382,461	74,660,086	23.302
90%	1,555,269	74,832,894	23.356
100%	1,728,076	75,005,701	23.410
110%	1,900,884	75,178,509	23.464
120%	2,073,692	75,351,317	23.518

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	31,328,973	65,531,186	20.453
90%	35,245,095	70,268,443	21.932
100%	39,161,216	75,005,701	23.410
110%	43,077,338	79,742,959	24.889
120%	46,993,460	84,480,217	26.368

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-1,076,295	76,081,997	23.746
-10%	-717,530	75,723,232	23.634
-5%	-358,765	75,364,467	23.522
0%	0	75,005,701	23.410
5%	358,765	74,646,936	23.298
10%	717,530	74,288,171	23.186
15%	1,076,295	73,929,406	23.074

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	114,883,502	35.857
0.5%	108,752,158	33.943
1.5%	98,046,923	30.602

Table 48 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FGDC Type: New plant (NP)
 Desc: FORT GORDON
 Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Page 5
 05/13/92

 Sensitivity Analysis, cont

3.5%	81,476,003	25.430
4.5%	75,005,701	23.410
5.5%	69,447,846	21.676
6.5%	64,636,946	20.174
7.5%	60,441,375	18.865
8.5%	56,755,905	17.714
9.5%	53,495,984	16.697
10.5%	50,593,320	15.791
11.5%	47,992,470	14.979
12.0%	46,790,747	14.604

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	57,634,746	33.710
11 yr	59,062,868	32.050
12 yr	60,507,693	30.711
13 yr	61,827,201	29.552
14 yr	63,132,462	28.582
15 yr	64,438,106	27.769
16 yr	65,703,522	27.068
17 yr	66,826,947	26.418
18 yr	67,949,340	25.862
19 yr	68,987,116	25.353
20 yr	70,370,575	25.037
21 yr	71,390,338	24.648
22 yr	72,311,964	24.279
23 yr	73,197,921	23.945
24 yr	74,160,051	23.678
25 yr	75,005,701	23.410

Table 49

Picatinny Arsenal Heating Plant Information

Plant	Boiler	Fuel	Reserve	Year Installed	Capacity (lb/hr)	In use	Rating	Energy Use Heat/Cool/ Process/Losses/ Internal/Pwr Gen
506	1	#6 Oil	#2 Oil	1971	50000	Y	5	H/C
506	2	#6 Oil	#2 Oil	1958	160000	Y	5	H/C
506	3	#6 Oil	#2 Oil	1958	160000	Y	5	H/C
99	1	#6 Oil	#2 Oil	1987	10000	Y	10	H
3013	1	#6 Oil	#2 Oil	1970	50000	Y	2	H
(Total)					430000			

Table 50

Picathany Arsenal Energy Use Data

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 Use	\$/MBtu	MBtu '90	MBtu '89
Dist. oil	gal	138700	0.51	297570	0	3.68	0	41273
Res. oil	gal	149690	0.45	6299916	0	3.01	0	943034
Nat. gas	Total NAG use:			0	0		0	0
Interr.	kscf	0	0.00					
Unintr.	kscf	0	0.00					
Building:		506						
Capacity (lb/hr):		410000						
SQ file:		PIC1						
Annual Costs		890000						
Labor		500000						
Utilities		100000						
Service		100000						
Supplies		100000						
Average steam production, 1989 (lb/hr):								
October		71010						
November		80830						
December		108270						
January		120960						
February		124570						
March		116600						
April		95700						
May		62780						
June		27610						
July*		25000						
August*		30000						
September*		50000						
Fuel energy, based on steam production, 1989 (MBtu)								
October		63652.3						
November		70117.6						
December		97051.7						
January		108426.8						
February		100856.7						
March		104518.6						

* = estimated

Table 50 (Cont'd)

Fuel	Units	Btu/Unit	\$/Unit	1989 Use	1990 Use	\$/MBtu	MBtu '89	MBtu '90
Fuel energy, based on steam production, 1989 (MBtu) (cont'd):								
April		83016.9						
May		56275.1						
June		23950.8						
July		22409.6						
August		26891.6						
September		43373.5						
Total (MBtu/yr)		800541.1					800541.1	
Percent of total		100.0						
Reserve fuel		#2						
Fuel use (MBtu/year):								
Natural Gas		0.0					Total	0
Dist. Oil		36024.3						36024
Res. Oil		764516.8						764517
Total \$/yr:		4020762				ERR		
\$/MBtu:								
Labor		1.11						
Utilities		0.62						
Service		0.12						
Supplies		0.12						
Fuel		3.03						
Total \$/MBtu		5.02					Average	5.02
Reported \$/MBtu:		5.28						

Table 51a

Boiler Evaluation Parts List—Picatinny Arsenal Bldg. 506

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
A. Boiler (WT)	1971	1	50 MBtu/hr		Good
1. Boiler Pressure Parts and Setting					
2. Relief Valve(s)	1971	3	450 psig	600 temp	Good
3. Feedwater Regulator(s)	1971	1	1.5 in.	600 psig	Good
4. Boiler Burner(s)	1971	1	2 in.	600 psig	Good
5. Boiler Fan(s) (FD)	1971	1	75 MBtu		Fair
7. Boiler Drum Level Control	1971	1	75 Hp		Good
A. Boiler (WT)	1958	2	180 MBtu/hr		Fair
1. Boiler Pressure Parts and Setting	(1982-25 yr life)				Good
2. Relief Valve(s)	1988	3	430 psig	600 temp	Good
2. Relief Valve(s)	1988	1	3 in.	600 psig	Good
2. Relief Valve(s)	1989	3	2.5 in.	600 psig	Good
2. Relief Valve(s)	1989	1	3 in.	600 psig	Good
3. Feedwater Regulator(s)	1954	2	2.5 in.	600 psig	Good
4. Boiler Burner(s)	1980	8	4 in.	600 psig	Fair
5. Boiler Fan(s) (FD)	1958	1	50 MBtu		Good
5. Boiler Fan(s) (ID)	1987	1	150 Hp		Fair
5. Boiler Fan(s) (FD)	1958	1	200 Hp		Good
5. Boiler Fan(s) (ID)	1987	1	100 Hp		Fair
6. Boiler Air Heater	1975	2	250 Hp		Good
7. Boiler Drum Level Control	1986	2	200 MBtu		Fair
					Good

Table 51a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
B. Feedwater System					
8. Desalting Heater	1983	1	330000 lb/hr		Good
8. Desalting Heater	1988	1	350000 lb/hr		Good
12. Condensate Pumps	1980	4	5 Hp		Good
12. Condensate Pumps	1991	1	5 Hp		Good
13. Condensate Receiver	1980	1	8600 Gal		Good
13. Condensate Receiver	1980	1	200 Gal		Fair
13. Condensate Receiver	1980	1	250 Gal		Fair
14. Boiler Feed Pumps	1990	1	150 Hp		Good
14. Boiler Feed Pumps	1986	1	131 Hp		Good
14. Boiler Feed Pumps	1981	2	250 Hp		Fair
14. Boiler Feed Pumps	1986	1	150 Hp		Fair
14. Boiler Feed Pumps	1965	1	250 Hp		Fair
14. Boiler Feed Pumps	1986	1	200 Hp		Good
15. Make-up Pumps	1986	3	50 Hp		Fair
15. Make-up Pumps	1986	1	40 Hp		Fair
15. Make-up Pumps	1990	1	50 Hp		Good
19. Feedwater Piping System (valve)	1991	10	4 diam (in.)	150 psig	Good
20. Cooling Water Pumps	1991	1	20 Hp		Fair
20. Cooling Water Pumps	1991	2	30 Hp		Fair
20. Cooling Water Pumps	1991	1	25 Hp		Fair
20. Cooling Water Pumps	Unknown	2	150 Hp	(not in use)	Fair
20. Cooling Water Pumps	Unknown	2	250 Hp	(not in use)	Fair
20. Cooling Water Pumps	Unknown	1	25 Hp	(not in use)	Fair
C. Fuel Handling System					
2. Fuel Oil Tank - Above ground	1970	2	400000 gal		Good
2. Fuel Oil Tank - Above ground	1980	2	800000 gal		Good
4. Fuel Oil Pump	1985	1	— gpm	15 Hp	Good
4. Fuel Oil Pump	1970	2	— gpm	15 Hp	Fair
5. Fuel Oil Heater	1970	3	30 gpm		Fair
6. Fuel Oil Piping System (BLW)	1970	50	4 diam (in.)		Fair
6. Fuel Oil Piping System (BLW)	1970	50	6 diam (in.)		Fair
6. Fuel Oil Piping System (ABV)	1970	500	6 diam (in.)		Fair
7. Natural Gas Piping (ABV)	1980	—	8 diam (in.)		Good
7. Natural Gas Piping (BLW)	1990	—	8 diam (in.)		Good
D. Heat Recovery System					
1. Blowdown Flash Tank	1986	1	3.5 diam (ft)	5 height (ft)	Good
1. Blowdown Flash Tank	1986	1	6 diam (ft)	8 height (ft)	Good
2. Blowdown Heat Exchanger	1977	1	18 gpm		Fair
2. Blowdown Heat Exchanger	1988	1	18 gpm		Good

Table 51a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
E. Air Pollution Control Systems and Emissions Monitoring					
4. Breeching	1974	1	16 sq ft		Good
4. Breeching	1955	2	36 sq ft		Good
5. Stack	1974	1	4 diam (ft)	65 height (ft)	Good
5. Stack	1980	2	6 diam (ft)	60 height (ft)	Good
6. Opacity Monitor	1970	3			Fair
F. Combustion Controls					
1. Plant Master	1985	1			Good
2. Boiler Master	1970	1			Fair
2. Boiler Master	1985	2			Good
3. Flame Safeguard System	1970	1			Fair
3. Flame Safeguard System	1980	1			Good
4. Furnace Draft Control (DAMPACT)	1954	2			Fair
5. Additional Boiler Instrumentation/Indicators	1991	3		FLOWMETER, 1.0 MPREC PSIG CONTROL/SENSOR	Fair
	1985	2			Fair
G. Chemical Feed System					
1. Chemical Storage Tanks and Pumps	1991	5	200 gal	0.333 Hp	Good
H. Make-up Water System					
5. Pressure Filter	1973	3	300 gpm		Fair
9. Sodium Zeolite Softener	1973	3	200 gpm		Good
I. Condensate Polishing					
J. Compressed Air System					
1. Air Compressor (RECIP)	1988	2	750 SCFM		Fair
1. Air Compressor (ROT SCRW)	1980	1	250 SCFM		Fair
1. Air Compressor (RECIP)	1983	1	50 SCFM		Fair
2. Air Dryer (REFR)	1986	1	50 SCFM		Good
3. Air Receiver	1991	1	600 gal		Good
3. Air Receiver	1981	1	600 gal		Fair
3. Air Receiver	1971	1	400 gal		Fair
K. Electrical System					
1. Transformer	1990	1	1500 KVA		Good
1. Transformer	1970	1	750 KVA		Fair
1. Transformer	1970	3	150 KVA		Fair
2. Switchgear -- Main Circuit Breaker	1954	1	2000 amps		Poor
3. Motor Control Center/Starters	1954	3	500 amps		Poor
3. Motor Control Center/Starters	1954	3	1000 amps		Poor

Table 51a (Cont'd)

Equipment	Year Installed	Units	Specification 1	Specification 2	Condition
L. Physical Plant					
1. Building Siding, Roofing, Windows, and Doors	1954	—	—		Fair
2. Building Concrete and Building Steel	1954	—	—		Fair
4. Building Lighting	1954	—	—		Fair

Status Quo Life Cycle Cost Analysis for Picatinny Arsenal Building 506

STUDY: TDPIC1

BASIC INPUT DATA SUMMARY

DISCOUNT RATE: 4.6%

DATE OF STUDY (DOS)	MAY 92
MIDPOINT OF CONSTRUCTION (MPC)	JUN 92
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 93
ANALYSIS END DATE (AED)	JAN 18

A152

Table 51b (Cont'd)

LIFE CYCLE COST ANALYSIS
 LCCID 1.065 DATE/TIME: 05-19-92 13:13:31 STUDY: TDPIC1
 PROJECT NO., FY, & TITLE: FY 1992 BUILDING 506
 INSTALLATION & LOCATION: PICATINNY ARSENAL NEW JERSEY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

BOILMASTER	10000.0	.00	JAN 15
DAMPACT	2000.0	.00	JAN 99
FLAMESAFE	10000.0	.00	JAN 00
FLAMESAFE	20000.0	.00	JAN 10
PLANTMASTER	5000.0	.00	JAN 15
PSIGCTRL	5000.0	.00	JAN 15
PSIGSENSOR	2000.0	.00	JAN 15
AIRCOMPRECIP	20000.0	.00	JAN 03
AIRCOMPRECIP	42000.0	.00	JAN 00
AIRCOMPRECIP	192000.0	.00	JAN 08
AIRDRYERREFR	12000.0	.00	JAN 01
AIRRECV	1900.0	.00	JAN 01
AIRRECV	2500.0	.00	JAN 11
MOTORCTRL	8700.0	.00	JAN 94
MOTORCTRL	16200.0	.00	JAN 94
SWITCH	25000.0	.00	JAN 94
TRANSFORMER	57000.0	.00	JAN 10
TRANSFORMER	28500.0	.00	JAN 10
CONDPUMP	18000.0	.00	JAN 00
CONDPUMP	4500.0	.00	JAN 11
CONDREC	8000.0	.00	JAN 10
CONDREC	9000.0	.00	JAN 10
CONDREC	56000.0	.00	JAN 10
COOLPUMP	7000.0	.00	JAN 11
COOLPUMP	7600.0	.00	JAN 11
COOLPUMP	7600.0	.00	JAN 11
COOLPUMP	16400.0	.00	JAN 11
COOLPUMP	22800.0	.00	JAN 11
COOLPUMP	22800.0	.00	JAN 11
FEEDPUMP	30820.0	.00	JAN 16
FEEDPUMP	35000.0	.00	JAN 16
FEEDPUMP	74000.0	.00	JAN 11
FEEDPUMP	37000.0	.00	JAN 95
FEEDPUMP	37000.0	.00	JAN 16
FWPIPINGVAL	11000.0	.00	JAN 11
MUPUMP	9933.0	.00	JAN 06
MUPUMP	34200.0	.00	JAN 06
MUPUMP	11400.0	.00	JAN 10
HEATER	15000.0	.00	JAN 00
NAGPIPEBELOW	54.0	.00	JAN 15
OILPIPEBELOW	2450.0	.00	JAN 95
OILPIPEBELOW	4300.0	.00	JAN 95
PUMP	5000.0	.00	JAN 10
PUMP	10000.0	.00	JAN 95
TANKABOVE	360000.0	.00	JAN 10
FLASHTANK	1550.0	.00	JAN 11
FLASHTANK	2000.0	.00	JAN 11
HEATEXCH	1520.0	.00	JAN 07
HEATEXCH	1520.0	.00	JAN 18

Table 51b (Cont'd)

LIFE CYCLE COST ANALYSIS

STUDY: TDPIC1

LCCID 1.065

DATE/TIME: 05-19-92 13:13:31

PROJECT NO., FY, & TITLE:

FY 1992

BUILDING 506

INSTALLATION & LOCATION: PICATINNY ARSENAL

NEW JERSEY

DESIGN FEATURE:

ALT. ID. A; TITLE: STATUS QUO

NAME OF DESIGNER:

BASIC INPUT DATA SUMMARY

1	FILTERPRESS	69000.0	.00	JAN 93
1	SZSOFT	474999.0	.00	JAN 93

11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000 1001 1002 1003 1004 1005 1006 1007 1008 1009 1010 1011 1012 1013 1014 1015 1016 1017 1018 1019 1020 1021 1022 1023 1024 1025 1026 1027 1028 1029 1030 1031 1032 1033 1034 1035 1036 1037 1038 1039 1040 1041 1042 1043 1044 10

OTHER KEY INPUT DATA

LOCATION - NEW JERSEY

CENSUS REGION: 1

RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 91

ENERGY USAGE: 10**6 BTUS

ELECTRIC DEMAND: 10**0 DOLLARS

ENERGY TYPE	\$/MBTU	AMOUNT
-------------	---------	--------

[illegible]

DIST	3.68	36024.0
------	------	---------

JAN93-JAN18

RESID	3.01	764517.0
-------	------	----------

JAN93-JAN18

Table 51b (Cont'd)

LIFE CYCLE COST ANALYSIS
 LCCID 1.065 STUDY: TDPIC1
 PROJECT NO., FY, & TITLE: DATE/TIME: 05-19-92 13:13:31
 FY 1992 BUILDING 506
 INSTALLATION & LOCATION: PICATINNY ARSENAL NEW JERSEY
 DESIGN FEATURE:
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 0.

ENERGY COSTS:

DISTILLATE OIL 2264606.
 RESIDUAL OIL 41904900.

TOTAL ENERGY COSTS 44169500.

RECURRING M&R/CUSTODIAL COSTS 23161800.

MAJOR REPAIR/REPLACEMENT COSTS 4270156.

OTHER O&M COSTS & MONETARY BENEFITS 0.

DISPOSAL COSTS/RETENTION VALUE 0.

LCC OF ALL COSTS/BENEFITS (NET PW) 71601460.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 51b (Cont'd)

LIFE CYCLE COST ANALYSIS
 LCCID 1.065 STUDY: TDPIC1
 PROJECT NO., FY, & TITLE: DATE/TIME: 05-19-92 13:13:31
 INSTALLATION & LOCATION: PICATINNY ARSENAL BUILDING 506
 DESIGN FEATURE: NEW JERSEY
 ALT. ID. A; TITLE: STATUS QUO
 NAME OF DESIGNER:

YEAR-BY-YEAR BREAKDOWN OF LIFE CYCLE COSTS*

DOLLARS IN 10**0

BENEFICIAL OCCUPANCY DATE: JAN93
 ANNUAL PAYMENTS OCCUR: JUL93 THROUGH JUL17

PAY	DIST	RESID	M & R	R / R	OTHER
1	126772.	2257201.	1508725.	527931.	0.
2	121289.	2200865.	1442376.	48338.	0.
3	115696.	2136345.	1378945.	228443.	0.
4	110589.	2047090.	1318303.	8819.	0.
5	105823.	1952730.	1260328.	0.	0.
6	101769.	1874440.	1204902.	54252.	0.
7	99260.	1830506.	1151914.	1482.	0.
8	97411.	1800943.	1101256.	116880.	0.
9	95858.	1776390.	1052826.	9413.	0.
10	94709.	1759094.	1006526.	0.	0.
11	93560.	1741913.	962262.	12379.	0.
12	92296.	1720989.	919945.	0.	0.
13	90979.	1699294.	879488.	0.	0.
14	89244.	1668088.	840811.	29277.	0.
15	87202.	1629172.	803834.	2265352.	0.
16	84796.	1581665.	768484.	99950.	0.
17	82182.	1529001.	734688.	4820.	0.
18	79323.	1475372.	702379.	250700.	0.
19	76826.	1429119.	671490.	560704.	0.
20	74827.	1391932.	641960.	0.	0.
21	72958.	1357166.	613729.	0.	0.
22	70963.	1320071.	586739.	7510.	0.
23	68956.	1282734.	560936.	7957.	0.
24	66723.	1241193.	536267.	35467.	0.
25	64594.	1201591.	512684.	0.	0.
***	2264606.	*****	*****	4270156.	0.

*NET PW EQUIVALENTS ON MAY92; IN 10**0 DOLLARS; IN CONSTANT MAY92 DOLLARS
 *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 91

Table 52

CHPECON Run Results for Picatinny Arsenal Bldg. 506

Technology	Boiler	\$/MBTU	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	124/124/124	9.340	11.167	11539	123089	145468	100
#2 OIL	124/124/124	10.513	12.570	11539	141366	163744	113
#6 OIL	124/124/124	8.052	9.627	11539	103024	125403	86
STOKER	84/144/144/144	11.206	13.397	81979	50484	174524	120
CWS	72/144/184/184	10.841	12.961	72567	71777	176779	122
COM	88/151/151/151	10.581	12.650	51153	93558	172536	119
FBC	67/134/171/171	12.342	14.756	80809	69238	192226	132
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS
Retrofit							
STOKER	45/144/144			5044	48230	-118672	-65397
CWS	37/120/120			4378	67203	-152423	-80841
M-COAL	37/120/120			6660	47303	-116390	-62426

FILE PREFIX: PAR1

PMCR: 370 L

AVE MON. LOAD: 123 M

CHP #1 2@ 160 L FUEL = FS6 AGE = 1952/1954

1@ 50 L FUEL = FS6 AGE = 1971

L=(K\$ STEAM/HR)

M=(MBTU/HR)

Table 53

CHPECON Run Results for Picatinny Arsenal Bldg. 3013

Technology	Boiler	\$/MBTU	\$/K\$STM	K\$INV.	K\$FUEL	K\$LCC	LCC/R
New Plant							
GAS	17/17/17	13.255	15.848	4406	17727	29347	100
#2 OIL	17/17/17	14.423	17.244	4406	20313	31932	109
#6 OIL	17/17/17	11.964	14.304	4406	14868	26488	90
STOKER	12/20/20/20	30.417	36.367	37350	8439	67342	229
CWS	10/20/25/25	23.729	28.371	25050	10969	54900	187
COM	12/21/21/21	23.550	28.156	22199	14234	54484	186
FBC	9/18/23/23	28.423	33.982	34038	7617	62927	214
				K\$INV	K\$COAL	K\$ HVY OIL	SAVINGS

Retrofit

STOKER

CWS

M-COAL

FILE PREFIX: PAR2

PMCR: 50 L

AVE MON. LOAD: 17 M

CHP #2 1@ 50 L FUEL = FS6 AGE = 1970

L=(K\$ STEAM/HR)

M=(MBTU/HR)

Table 54

**Cost Sensitivity Analysis for
a Gas/Oil-Fired Boiler Plant**

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FPIC Type: New plant (NP)
 Desc: PICATINNY ARSENAL
 Tech: Gas / Oil Fired Boiler

Page 1
 05/13/92

 Base and Plant Information

State: NJ - New Jersey Base DOE Region: 1
 PMCR: 250,000 lb/hr steam Number of boilers: 3

 Height of the plant: 40 ft
 Building area: 9000 sq ft
 Plant area: 1.97 acres

 Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)
 Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)
 Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)
 Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 1,635,533 kW-hr

1991 cost for distillate: 0.662 \$/gallon
 1991 cost for residual: 0.445 \$/gallon
 1991 cost for natural gas: 4.150 \$/million Btu
 1991 cost for electricity: 0.044 \$/kW-hr

Annual Facility Output: 852,120 thousand lb steam
 Annual Natural Gas Usage: 1,046 10⁶ SCF
 Heating plant efficiency: 83.2% natural gas
 Year of Study: 1991
 Years of Operation: 1995 - 2019

 Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 1,673,069	Stack:	\$ 32,911
Building/service:	\$ 1,377,326	Water trtmnt:	\$ 909,326
Feedwtr pmps:	\$ 31,154	Cond xfr pmps:	\$ 32,200
Cond strg tnk:	\$ 8,362	Oil (long) storage:	\$ 340,749
Oil day strg pmp:	\$ 5,015	Oil heaters:	\$ 8,880
Oil day strg tanks:	\$ 22,120	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 6,425	Fire protection:	\$ 52,241
Cont bldn tnk:	\$ 1,175	Intr bldn tnk:	\$ 1,175
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 22,202	Site preparation:	\$ 5,145
Site improvements:	\$ 235,085	Mobile equipment:	\$ 40,748
Elec substation:	\$ 71,237	Electrical:	\$ 197,854
Piping:	\$ 1,121,176	Instrumentation:	\$ 414,552
Direct costs:	\$ 2,458,250		

Table 54 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FPIC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Gas / Oil Fired Boiler

Facility Capital Costs, cont

Plant installed cost: \$ 10,622,206

Facility Annual O & M and Energy Costs

Operating staff: 11

Annual Labor Costs: \$ 463,732

Annual Year Non-Labor O & M Costs : \$ 714,017

1995 Natural gas costs : \$ 5,382,747

1995 Auxiliary Energy Costs : \$ 72,323

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 6,545
10 years	\$ 380,276	15 years	\$ 112,846
18 years	\$ 12,880	20 years	\$ 14,981

Facility Life Cycle Cost Summary

Analysis using natural gas as primary fuel

+ PV 'Adjusted' Investment Costs	= \$ 9,308,203
+ PV Energy + Transportation Costs	= \$ 100,259,214
+ PV Annually Recurring O&M Costs	= \$ 9,261,152
+ PV Non-Annually Recurring Repair & Replacement	= \$ 551,423
+ PV Disposal Cost of Existing System	= \$ 0
+ PV Disposal Cost of New/Retrofit Facility	= \$ 0

Total Life Cycle Cost (1991) = \$ 119,379,993

Levelized Cost of Service (1995 start) = 9.4237 \$/MMBtu

Levelized Cost of Service (1995 start) = 11.266 \$/1000 lb steam

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	49,617,335	69,762,657	6.584
60%	59,540,803	79,686,125	7.520

Table 54 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FPIC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

80%	79,387,737	99,533,059	9.393
90%	89,311,204	109,456,526	10.330
100%	99,234,671	119,379,993	11.266
110%	109,158,138	129,303,460	12.203
120%	119,081,606	139,226,928	13.140
130%	129,005,073	149,150,395	14.076
140%	138,928,540	159,073,862	15.013
150%	148,852,007	168,997,329	15.949

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	70,124,292	90,269,614	8.519
-2%	78,428,555	98,573,877	9.303
-1%	88,053,064	108,198,386	10.211
0%	99,234,671	119,379,993	11.266
1%	112,254,463	132,399,785	12.495
2%	127,446,043	147,591,365	13.929
3%	145,205,331	165,350,653	15.605
4%	166,002,156	186,147,478	17.568
5%	190,393,953	210,539,275	19.870
6%	219,041,942	239,187,264	22.574

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	819,634	119,175,085	11.247
90%	922,088	119,277,539	11.257
100%	1,024,542	119,379,993	11.266
110%	1,126,997	119,482,448	11.276
120%	1,229,451	119,584,902	11.286

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,820,558	118,174,853	11.153
90%	5,423,128	118,777,423	11.210
100%	6,025,698	119,379,993	11.266
110%	6,628,268	119,982,563	11.323
120%	7,230,838	120,585,133	11.380

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	2,588,362	118,732,903	11.205
90%	2,911,908	119,056,448	11.236
100%	3,235,453	119,379,993	11.266
110%	3,558,999	119,703,539	11.297

Table 54 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FPIC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	441,138	119,269,709	11.256
90%	496,281	119,324,851	11.261
100%	551,423	119,379,993	11.266
110%	606,565	119,435,136	11.272
120%	661,708	119,490,278	11.277

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	7,446,562	117,304,377	11.071
90%	8,377,382	118,342,185	11.169
100%	9,308,203	119,379,993	11.266
110%	10,239,023	120,417,801	11.364
120%	11,169,843	121,455,609	11.462

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-252,951	119,632,945	11.290
-10%	-168,634	119,548,628	11.282
-5%	-84,317	119,464,310	11.274
0%	0	119,379,993	11.266
5%	84,317	119,295,676	11.259
10%	168,634	119,211,359	11.251
15%	252,951	119,127,042	11.243

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	234,418,532	22.124
0.5%	215,972,753	20.383
1.5%	184,305,621	17.394
2.5%	158,389,335	14.948
3.5%	137,052,184	12.934
4.5%	119,379,993	11.266
5.5%	104,656,217	9.877
6.5%	92,316,614	8.712
7.5%	81,914,829	7.731
8.5%	73,096,135	6.898

Table 54 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FPIC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

10.5%	59,131,292	5.580
11.5%	53,575,019	5.056
12.0%	51,083,109	4.821

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	59,198,507	10.470
11 yr	63,835,860	10.474
12 yr	68,450,718	10.505
13 yr	73,032,368	10.555
14 yr	77,540,729	10.615
15 yr	82,034,653	10.689
16 yr	86,333,369	10.754
17 yr	90,490,070	10.817
18 yr	94,534,274	10.879
19 yr	98,435,401	10.938
20 yr	102,359,849	11.012
21 yr	106,014,940	11.068
22 yr	109,530,323	11.120
23 yr	112,927,419	11.170
24 yr	116,212,708	11.219
25 yr	119,379,993	11.266

Table 55

**Cost Sensitivity Analysis for
a #6 Oil-Fired Boiler Plant**

Central Heating Plant Economics Evaluation -- Sensitivity Analysis Page 1
 File: FPIC6 Type: New plant (NP) 05/13/92
 Desc: PICATINNY ARSENAL
 Tech: Gas / Oil Fired Boiler

 Base and Plant Information

State: NJ - New Jersey Base DOE Region: 1
 PMCR: 250,000 lb/hr steam Number of boilers: 3

Height of the plant: 40 ft
 Building area: 9000 sq ft
 Plant area: 1.97 acres

 Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)
 Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)
 Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)
 Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual electricity usage: 1,635,533 kW-hr

1991 cost for distillate: 0.662 \$/gallon
 1991 cost for residual: 0.445 \$/gallon
 1991 cost for natural gas: 4.150 \$/million Btu
 1991 cost for electricity: 0.044 \$/kW-hr

Annual Facility Output: 852,120 thousand lb steam
 Annual #6 Fuel Oil Usage: 7,463 10³ gal
 Heating plant efficiency: 87.8% #6 fuel oil
 Year of Study: 1991
 Years of Operation: 1995 - 2019

 Facility Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 1,673,069	Stack:	\$ 32,911
Building/service:	\$ 1,377,326	Water trtmnt:	\$ 909,326
Feedwtr pmps:	\$ 31,154	Cond xfr pmps:	\$ 32,200
Cond strg tnk:	\$ 8,362	Oil (long) storage:	\$ 340,749
Oil day strg pmp:	\$ 5,015	Oil heaters:	\$ 8,880
Oil day strg tanks:	\$ 22,120	Oil unload pumps:	\$ 13,791
Oil xfr pmps:	\$ 6,425	Fire protection:	\$ 52,241
Cont bldn tnk:	\$ 1,175	Intr bldn tnk:	\$ 1,175
Compressor:	\$ 24,453	Car puller:	\$ 20,896
Rail:	\$ 22,202	Site preparation:	\$ 5,145
Site improvements:	\$ 235,085	Mobile equipment:	\$ 40,748
Elec substation:	\$ 71,237	Electrical:	\$ 197,854
Piping:	\$ 1,121,176	Instrumentation:	\$ 414,552
Direct costs:	\$ 2,458,250		

Table 55 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FPIC6 Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Gas / Oil Fired Boiler

 Facility Capital Costs, cont

Plant installed cost: \$ 10,622,206

 Facility Annual O & M and Energy Costs

Operating staff: 11

Annual Labor Costs: \$ 463,732

Annual Year Non-Labor O & M Costs : \$ 714,017

1995 #6 fuel oil costs : \$ 4,343,856

1995 Auxiliary Energy Costs : \$ 72,323

 Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 30,000	5 years	\$ 6,545
10 years	\$ 380,276	15 years	\$ 112,846
18 years	\$ 12,880	20 years	\$ 14,981

 Facility Life Cycle Cost Summary

Analysis using #6 fuel oil as primary fuel

+ PV 'Adjusted' Investment Costs = \$ 9,308,203

+ PV Energy + Transportation Costs = \$ 83,903,376

+ PV Annually Recurring O&M Costs = \$ 9,261,152

+ PV Non-Annually Recurring Repair & Replacement = \$ 551,423

+ PV Disposal Cost of Existing System = \$ 0

+ PV Disposal Cost of New/Retrofit Facility = \$ 0

Total Life Cycle Cost (1991) = \$ 103,024,156

Levelized Cost of Service (1995 start) = 8.1325 \$/MMBtu

Levelized Cost of Service (1995 start) = 9.7233 \$/1000 lb steam

 Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	41,439,417	61,584,739	5.812
60%	49,727,300	69,872,622	6.594

Table 55 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FPIC6 Type: New plant (NP)
 Desc: PICATINNY ARSENAL
 Tech: Gas / Oil Fired Boiler

Page 3
 05/13/92

 Sensitivity Analysis, cont

80%	66,303,067	86,448,389	8.158
90%	74,590,950	94,736,272	8.941
100%	82,878,834	103,024,156	9.723
110%	91,166,717	111,312,039	10.505
120%	99,454,600	119,599,922	11.287
130%	107,742,484	127,887,806	12.069
140%	116,030,367	136,175,689	12.852
150%	124,318,251	144,463,573	13.634

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	58,798,827	78,944,149	7.450
-2%	65,677,509	85,822,831	8.099
-1%	73,639,648	93,784,970	8.851
0%	82,878,834	103,024,156	9.723
1%	93,624,768	113,770,090	10.737
2%	106,150,028	126,295,350	11.919
3%	120,778,068	140,923,390	13.300
4%	137,892,685	158,038,007	14.915
5%	157,949,203	178,094,525	16.808
6%	181,487,690	201,633,012	19.029

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	819,634	102,819,247	9.703
90%	922,088	102,921,701	9.713
100%	1,024,542	103,024,156	9.723
110%	1,126,997	103,126,610	9.732
120%	1,229,451	103,229,064	9.742

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	4,820,558	101,819,016	9.609
90%	5,423,128	102,421,586	9.666
100%	6,025,698	103,024,156	9.723
110%	6,628,268	103,626,726	9.780
120%	7,230,838	104,229,295	9.837

=== O&M non-labor cost variation ===

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	2,588,362	102,377,065	9.662
90%	2,911,908	102,700,610	9.692
100%	3,235,453	103,024,156	9.723
110%	3,558,999	103,347,701	9.753

Table 55 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FPIC6 Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Gas / Oil Fired Boiler

Sensitivity Analysis, cont

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	441,138	102,913,871	9.712
90%	496,281	102,969,013	9.718
100%	551,423	103,024,156	9.723
110%	606,565	103,079,298	9.728
120%	661,708	103,134,440	9.733

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	7,446,562	100,948,540	9.527
90%	8,377,382	101,986,348	9.625
100%	9,308,203	103,024,156	9.723
110%	10,239,023	104,061,964	9.821
120%	11,169,843	105,099,771	9.919

=== Existing salvage value variation ===

Change PV Existing Salvage Life Cycle Cost LCS, \$/1000lb steam
 Existing plant salvage values specified is 0.
 Variation of value is unnecessary. Analysis skipped.

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-252,951	103,277,107	9.747
-10%	-168,634	103,192,790	9.739
-5%	-84,317	103,108,473	9.731
0%	0	103,024,156	9.723
5%	84,317	102,939,838	9.715
10%	168,634	102,855,521	9.707
15%	252,951	102,771,204	9.699

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	199,968,565	18.872
0.5%	184,460,696	17.409
1.5%	157,811,232	14.894
2.5%	135,970,824	12.832
3.5%	117,962,622	11.133
4.5%	103,024,156	9.723
5.5%	90,557,498	8.546
6.5%	80,091,571	7.558
7.5%	71,253,500	6.724
8.5%	63,746,775	6.016

Table 55 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis
 File: FPIC6 Type: New plant (NP)
 Desc: PICATINNY ARSENAL
 Tech: Gas / Oil Fired Boiler

Page 5
 05/13/92

 Sensitivity Analysis, cont

10.5%	51,826,582	4.891
11.5%	47,069,696	4.442
12.0%	44,933,127	4.240

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	52,846,076	9.346
11 yr	56,862,494	9.330
12 yr	60,808,168	9.332
13 yr	64,644,285	9.343
14 yr	68,375,409	9.360
15 yr	72,075,701	9.392
16 yr	75,611,504	9.419
17 yr	79,035,784	9.447
18 yr	82,376,400	9.480
19 yr	85,601,633	9.512
20 yr	88,876,815	9.561
21 yr	91,909,008	9.595
22 yr	94,826,807	9.627
23 yr	97,650,242	9.659
24 yr	100,385,181	9.691
25 yr	103,024,156	9.723

Table 56

**Cost Sensitivity Analysis for
a Coal-Fired Stoker Plant**

Central Heating Plant Economics Evaluation -- Sensitivity Analysis Page 1
 File: FPICC Type: New plant (NP) 05/13/92
 Desc: PICATINNY ARSENAL
 Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

 Base and Plant Information

State: NJ - New Jersey Base DOE Region: 1
 PMCR: 250,000 lb/hr steam Number of boilers: 4

 Coal code: W190581 Distance from base: 287 miles
 State: PA - Pennsylvania DOE Region: 1
 Coal type: bituminous (properties on a dry basis)
 hhv: 11970 Btu/lb fixed carbon: 54.50% volatiles: 36.10%
 ash: 9.40% sulfur: 1.80%

Coal handling equipment capacity: 150 tons/hr
 Coal silo storage capacity: 1015 tons
 Approx. building width: 72 feet
 Approx. building length: 211 feet
 Height of the plant: 76 ft
 Building area: 15125 sq ft
 Plant area: 2.02 acres

 Facility Parameters

Capital Equipment Escalation Factor: 1.045 (4771.57/1991)
 Non-Labor Operation & Maintenance Escalation Factor: 1.106 (947.10/1991)
 Operation & Maintenance Labor Escalation Factor: 1.061 (4386.55/1991)
 Construction Labor Escalation Factor: 1.030 (272.70/1991)

Annual diesel/distillate fuel usage: 17,000 gallons
 Annual electricity usage: 5,531,268 kW-hr
 Annual lime usage: 3,352 tons

1991 cost for coal: 1.754 \$/MMBtu
 1991 cost for distillate: 0.662 \$/gallon
 1991 cost for electricity: 0.044 \$/kW-hr

Annual Facility Output: 852,120 thousand lb steam
 Annual Coal Usage: 48,059 tons (dry) / 53,730 tons (wet)
 Heating plant efficiency: 84%
 Year of Study: 1991
 Years of Operation: 1995 - 2019

 Facility Installed Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 15,459,897	Coal Handling:	\$ 6,995,254
Ash Handling:	\$ 4,931,886	Mechnc'l Collector:	\$ 201,195

Table 56 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 2

File: FPICC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Installed Capital Costs, cont

Water Treatment:	\$	1,711,718	Pumps:	\$	320,821
Air Compressor:	\$	103,275	Waste Water Trtmnt:	\$	174,671
Piping/Stack:	\$	6,440,614	Electrical System:	\$	2,115,710
Building Costs:	\$	8,586,528	Direct costs:	\$	16,053,338

Plant installed cost:	\$	74,382,847			

Facility Annual O & M and Energy Costs

Operating staff: 30

Annual Labor Costs: \$ 1,275,617

First Year Non-Labor O & M Costs : \$ 2,273,942

Annual Year Non-Labor O & M Costs : \$ 2,674,165

1995 Coal Costs (incl transport) : \$ 2,640,889

1995 Auxiliary Energy Costs : \$ 258,184

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 122,066	5 years	\$ 110,411
7 years	\$ 120,998	8 years	\$ 344,326
10 years	\$ 884,094	12 years	\$ 66,148
15 years	\$ 17,057	18 years	\$ 25,758
20 years	\$ 942,820		

Facility Life Cycle Cost Summary

+ PV 'Adjusted' Investment Costs	= \$	65,181,437
+ PV Energy + Transportation Costs	= \$	41,661,389
+ PV Annually Recurring O&M Costs	= \$	34,412,248
+ PV Non-Annually Recurring Repair & Replacement	= \$	2,634,990
+ PV Disposal Cost of Existing System	= \$	0
+ PV Disposal Cost of New/Retrofit Facility	= \$	0

Total Life Cycle Cost (1991)	= \$	143,890,065

Levelized Cost of Service (1995 start) = 11.358 \$/MMBtu

Table 56 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 3

File: FPICC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis

=== Primary fuel initial cost variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
50%	18,980,482	124,909,582	11.788
60%	22,776,579	128,705,679	12.147
70%	26,572,676	132,501,775	12.505
80%	30,368,772	136,297,872	12.863
90%	34,164,869	140,093,969	13.221
100%	37,960,965	143,890,065	13.580
110%	41,757,062	147,686,162	13.938
120%	45,553,159	151,482,258	14.296
130%	49,349,255	155,278,355	14.655
140%	53,145,352	159,074,452	15.013
150%	56,941,448	162,870,548	15.371

=== Primary fuel escalation rate variation ===

Change	PV Primary Fuel	Life Cycle Cost	LCS, \$/1000lb steam
-3%	27,518,797	133,447,897	12.594
-2%	30,513,820	136,442,920	12.877
-1%	33,967,490	139,896,589	13.203
0%	37,960,965	143,890,065	13.580
1%	42,590,495	148,519,595	14.017
2%	47,970,235	153,899,335	14.524
3%	54,235,592	160,164,691	15.116
4%	61,547,168	167,476,268	15.806
5%	70,095,436	176,024,536	16.613
6%	80,106,247	186,035,347	17.557

=== Auxiliary energy cost variation ===

Change	PV Auxiliary Energy	Life Cycle Cost	LCS, \$/1000lb steam
80%	2,960,338	143,149,981	13.510
90%	3,330,381	143,520,023	13.545
100%	3,700,423	143,890,065	13.580
110%	4,070,465	144,260,108	13.615
120%	4,440,508	144,630,150	13.650

=== O&M labor cost variation ===

Change	PV O&M Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	13,260,202	140,575,015	13.267
90%	14,917,728	142,232,540	13.423
100%	16,575,253	143,890,065	13.580
110%	18,232,778	145,547,591	13.736
120%	19,890,304	147,205,116	13.893

=== O&M non-labor cost variation ===

Table 56 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 4

File: FPICC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis, cont

Change	PV O&M Non-Labor	Life Cycle Cost	LCS, \$/1000lb steam
80%	14,269,596	140,322,666	13.243
90%	16,053,295	142,106,366	13.411
100%	17,836,995	143,890,065	13.580
110%	19,620,694	145,673,765	13.748
120%	21,404,394	147,457,464	13.916

=== Repair/replace cost variation ===

Change	PV Repair/Replace	Life Cycle Cost	LCS, \$/1000lb steam
80%	2,107,992	143,363,067	13.530
90%	2,371,491	143,626,566	13.555
100%	2,634,990	143,890,065	13.580
110%	2,898,489	144,153,564	13.605
120%	3,161,989	144,417,063	13.629

=== Initial cost variation ===

Change	PV Initial Cost	Life Cycle Cost	LCS, \$/1000lb steam
80%	52,145,149	128,695,841	12.146
90%	58,663,293	136,292,953	12.863
100%	65,181,437	143,890,065	13.580
110%	71,699,580	151,487,178	14.297
120%	78,217,724	159,084,290	15.014

=== Existing salvage value variation ===

Change	PV Existing Salvage	Life Cycle Cost	LCS, \$/1000lb steam
Existing plant salvage values specified is 0.			
Variation of value is unnecessary. Analysis skipped.			

=== New salvage value variation ===

Change	PV New Salvage	Life Cycle Cost	LCS, \$/1000lb steam
-15%	-1,640,928	145,530,994	13.735
-10%	-1,093,952	144,984,018	13.683
-5%	-546,976	144,437,041	13.631
0%	0	143,890,065	13.580
5%	546,976	143,343,089	13.528
10%	1,093,952	142,796,113	13.476
15%	1,640,928	142,249,137	13.425

=== Discount rate variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
0.0%	228,790,331	21.593
0.5%	215,623,821	20.350
1.5%	192,714,944	18.188

Table 56 (Cont'd)

Central Heating Plant Economics Evaluation -- Sensitivity Analysis

Page 5

File: FPICC Type: New plant (NP)

05/13/92

Desc: PICATINNY ARSENAL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Sensitivity Analysis, cont

3.5%	157,516,619	14.866
4.5%	143,890,065	13.580
5.5%	132,254,362	12.482
6.5%	122,244,376	11.537
7.5%	113,569,996	10.718
8.5%	105,999,566	10.004
9.5%	99,347,178	9.376
10.5%	93,462,882	8.820
11.5%	88,225,121	8.326
12.0%	85,816,994	8.099

=== Plant life variation ===

Change	Life Cycle Cost	LCS, \$/1000lb steam
10 yr	105,456,941	18.651
11 yr	108,625,896	17.823
12 yr	111,773,064	17.154
13 yr	114,710,661	16.579
14 yr	117,593,683	16.098
15 yr	120,424,534	15.692
16 yr	123,191,953	15.346
17 yr	125,714,265	15.027
18 yr	128,202,981	14.754
19 yr	130,544,299	14.507
20 yr	133,504,147	14.363
21 yr	135,762,379	14.173
22 yr	137,857,000	13.996
23 yr	139,875,524	13.836
24 yr	141,983,064	13.707
25 yr	143,890,065	13.580

Table 57

Summary of Coal Conversion Potential for the Four Bases Studied

Parameters	Values for:			
	Fort Gordon	Fort Campbell	Picatinny	Fort Bragg
New plant PMCR (1000 LBS/HR)	100	188	250	379
Base location				
DOE FY91 price	DOE REG.3	DOE REG.3	DOE REG.1	DOE REG.3
Elec. (\$/MBtu)	15.35	15.35	13.12	15.35
Gas (\$/MBtu)	2.69	2.69	4.11	2.69
#6 Oil (\$/MBtu)	2.62	2.62	2.93	2.62
Coal (\$/MBtu)	1.71	1.53	1.75	1.72
Coal Source	DOE REG.3	DOE REG.2	DOE REG.1	DOE REG.3
Breakeven price				
Gas (\$/MBtu)	7.2	5.2	5.15	3.7
#6 Oil (\$/MBtu)	8.1	5.8	5.18	4.1
Price paid by base				
Gas (\$/MBtu)	5.5	3	3.38	4.5
#6 Oil (\$/MBtu)	4.41	3.54	3.45	4.41
Price increase needed to use coal as fuel	31% (GAS) 84% (OIL)	73%(GAS) 64%(OIL)	52%(GAS) 50%(OIL)	0%(GAS) 8%(OIL)

APPENDIX B:

Figures




Figure 1. Effect of Primary Fuel Price on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Campbell.




Figure 2. Effect of Primary Fuel Cost Escalation Rate on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Campbell.




Figure 3. Effect of Auxiliary Energy Costs, O&M Labor, O&M Non-labor, Repair/Replacement and Initial Cost on the LCC of a Gas/#2 Oil-fired Boiler Plant, Fort Campbell.




Figure 4. Effect of Salvage Value on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Campbell.




Figure 5. Effect of Discount Rate on the LCC of a Gas/#2 Oil-Fired Plant, Fort Campbell.




Figure 6. Effect of Plant Life on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Campbell.




Figure 7. Effect of Primary Fuel Price on the LCC of a #6 Oil-Fired Boiler Plant, Fort Campbell.




Figure 8. Effect of Primary Fuel Escalation Rate on the LCC of a #6 Oil-Fired Boiler Plant, Fort Campbell.




Figure 9. Effect of Auxiliary Energy Costs, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Cost on the LCC of a #6 Oil-Fired Boiler Plant, Fort Campbell.




Figure 10. Effect of Salvage Value on the LCC of a #6 Oil-Fired Boiler Plant, Fort Campbell.




Figure 11. Effect of Discount Rate on the LCC of a #6 Oil-Fired Boiler Plant, Fort Campbell.




Figure 12. Effect of Plant Life on the LCC of a #6 Oil-Fired Boiler Plant, Fort Campbell.




Figure 13. Effect of Primary Fuel Price on the LCC of a Coal-Fired Stoker Plant, Fort Campbell.




Figure 14. Effect of Escalation Rate on the LCC of a Coal-Fired Stoker Plant, Fort Campbell.




Figure 15. Effect of Auxiliary Energy Cost, O&M Labor, O&M Non-labor, Repair/Replace and Initial Cost on the LCC of a Coal-Fired Stoker Plant, Fort Campbell .




Figure 16. Effect of Salvage Value on the LCC of a Coal-Fired Stoker Plant, Fort Campbell.




Figure 17. Effect of Discount Rate on the LCC of a Coal-Fired Stoker Plant, Fort Campbell.




Figure 18. Effect of Plant Life on the LCC of a Coal-Fired Stoker Plant, Fort Campbell.




Figure 19. Levelized Cost of Service vs. Fuel Price; Fort Campbell.




Figure 20. Effect of Primary Fuel Cost on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Bragg.




Figure 21. Effect of Primary Fuel Escalation on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Bragg.




Figure 22. Effect of Auxiliary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Costs on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Bragg.




Figure 23. Effect of Salvage Value on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Bragg.




Figure 24. Effect of Discount Rate on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Bragg.




Figure 25. Effect of Plant Life on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Bragg.




Figure 26. Effect of Primary Fuel Cost on the LCC of a #6 Oil-Fired Boiler Plant, Fort Bragg.




Figure 27. Effect of Primary Fuel Cost Escalation on the LCC of a #6 Oil-Fired Boiler Plant, Fort Bragg.




Figure 28. Effect of Auxillary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Costs of the LCC of a #6 Oil-Fired Boiler Plant, Fort Bragg.




Figure 29. Effect of Salvage Value on the LCC of a #6 Oil-Fired Boiler Plant, Fort Bragg.




Figure 30. Effect of Discount Rate on the LCC of a #6 Oil-Fired Boiler Plant, Fort Bragg.




Figure 31. Effect of Plant Life on the LCC of a #6 Oil-Fired Boiler Plant, Fort Bragg.




Figure 32. Effect of Primary Fuel Cost on the LCC of a Coal-Fired Stoker Plant, Fort Bragg.




Figure 33. Effect of Primary Fuel Escalation on the LCC of a Coal-Fired Stoker Plant, Fort Bragg.




Figure 34. Effect of Auxiliary Energy, O&M Labor, O&M Non-labor, Repair/Replacement and Initial Costs on a Coal-Fired Stoker Plant, Fort Bragg.




Figure 35. Effect of Salvage Value on the LCC of a Coal-Fired Stoker Plant, Fort Bragg.




Figure 36. Effect of Discount Rate on the LCC of a Coal-Fired Stoker Plant, Fort Bragg.




Figure 37. Effect of Plant Life on the LCC of a Coal-Fired Stoker Plant, Fort Bragg.




Figure 38. Levelized Cost of Service vs. Fuel Price; Fort Bragg.




Figure 39. Effect of Primary Fuel Cost on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Gordon.




Figure 40. Effect of Primary Fuel Escalation on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Gordon.




Figure 41. Effect of Auxiliary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Costs on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Gordon.




Figure 42. Effect of Salvage Value on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Gordon.




Figure 43. Effect of Discount Rate on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Gordon.




Figure 44. Effect of Plant Life on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Fort Gordon.




Figure 45. Effect of Primary Fuel Cost on the LCC of a #6 Oil-Fired Boiler Plant, Fort Gordon.




Figure 46. Effect of Primary Fuel Escalation on the LCC of a #6 Oil-Fired Boiler Plant, Fort Gordon.




Figure 47. Effect of Auxiliary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement, Initial Costs on the LCC of a #6 Oil-Fired Boiler Plant, Fort Gordon .




Figure 48. Effect of Salvage Value on the LCC on a #6 Oil-Fired Boiler Plant, Fort Gordon.




Figure 49. Effect of Discount Rate on the LCC of a #6 Oil-Fired Boiler Plant, Fort Gordon.




Figure 50. Effect of Plant Life on the LCC of a #6 Oil-Fired Boiler Plant, Fort Gordon.




Figure 51. Effect of Primary Fuel Cost on the LCC of a Coal-Fired Stoker Plant, Fort Gordon.




Figure 52. Effect of Primary Fuel Escalation on the LCC of a Coal-Fired Stoker Plant, Fort Gordon.





Figure 53. Effect of Auxiliary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Costs on the LCC of a Coal-Fired Stoker Plant, Fort Gordon.




Figure 54. Effect of Salvage Value on the LCC of a Coal-Fired Stoker Plant, Fort Gordon.




Figure 55. Effect of Discount Rate on the LCC of a Coal-Fired Stoker Plant, Fort Gordon.




Figure 56. Effect of Plant Life on the LCC of a Coal-Fired Stoker Plant, Fort Gordon.




Figure 57. Levelized Cost of Service vs. Fuel Price; Fort Gordon.




Figure 58. Effect of Primary Fuel Cost on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 59. Effect of Primary Fuel Escalation on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 60. Effect of Auxiliary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Costs on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 61. Effect of Salvage Value on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 62. Effect of Discount Rate on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 63. Effect of Plant Life on the LCC of a Gas/#2 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 64. Effect of Primary Fuel Cost on the LCC of a #6 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 65. Effect of Primary Fuel Escalation Cost on the LCC of an #6 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 66. Effect of Auxiliary Energy, O&M Labor, O&M Non-Labor, Repair/Replacement and Initial Costs of a #6 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 67. Effect of Salvage Value on the LCC of a #6 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 68. Effect of Discount Rate on the LCC of a #6 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 69. Effect of Plant Life on the LCC of a #6 Oil-Fired Boiler Plant, Picatinny Arsenal.




Figure 70. Effect of Primary Fuel Cost on the LCC of a Coal-Fired Stoker Plant, Picatinny Arsenal.




Figure 71. Effect of Primary Fuel Cost Escalation on the LCC of a Coal-Fired Stoker Plant, Picatinny Arsenal.




Figure 72. Effect of Auxiliary Energy, O&M Labor, O&M Labor, Repair/Replacement and Initial Costs of a Coal-Fired Stoker Plant, Picatinny Arsenal.




Figure 73. Effect of Salvage Value on the LCC of a Coal-Fired Stoker Plant, Picatinny Arsenal.




Figure 74. Effect of Discount Rate on the LCC of a Coal-Fired Stoker Plant, Picatinny Arsenal.




Figure 75. Effect of Plant Life on the LCC of a Coal-Fired Stoker Plant, Picatinny Arsenal.




Figure 76. Levelized Cost of Service vs. Fuel Price; Picatinny Arsenal.

APPENDIX C: 1989 Installation Energy Consumption Report

ADDS REPORT: RANKING
 COVERS : FROM JAN89 THRU DEC89
 INCLUDES : ALL MACOMS
 INSTALLATION RANKING BY CONSUMPTION - TOTAL FACILITY

RANK		MBTUS
----		-----
1	VII CORPS STUTTGART	9,475,618
2	V CORPS, FRANKFURT	8,261,431
3	FORT RICHARDSON	5,220,795
4	RADFORD ARMY AMMO PLANT	3,960,608
5	HOLSTON ARMY AMMO PLANT	3,801,610
6	21ST SUPCOM	3,760,975
7	FORT BRAGG	3,117,543
8	FORT HOOD	2,873,759
9	FORT KNOX	2,718,746
10	FORT BENNING	2,717,107
11	Aberdeen PG	2,541,672
12	FORT LEWIS	2,515,574
13	FORT CAMPBELL	2,425,919
14	REDSTONE ARSENAL	2,195,256
15	FORT RILEY	1,937,176
16	FORT ORD	1,874,942
17	FORT DIX	1,793,491
18	FORT GEORGE MEADE	1,719,846
19	FORT CARSON	1,706,884
20	FORT BLISS	1,655,909
21	FORT SILL	1,649,784
22	FORT LEONARD WOOD	1,646,571
23	SUNFLOWER ARMY AMMO PLANT	1,613,163
24	FORT STEWART	1,601,289
25	FORT DRUM	1,536,908
26	FORT BELVOIR	1,351,474
27	FORT JACKSON	1,342,532
28	ROCK ISLAND ARSENAL	1,296,026
29	WEST POINT	1,289,720
30	WALTER REED ARMY MEDICAL CENTE	1,254,489
31	FORT DEVENS	1,240,232
32	PICATINNY ARSENAL	1,229,515
33	FORT GORDON	1,224,015
34	7TH ATC, GRAFENWOHR	1,211,465
35	FORT POLK	1,177,156
36	FORT SAM HOUSTON	1,090,090
37	PRESIDIO OF SAN FRANCISCO	966,007
38	FORT RUCKER	952,015
39	FORT MONMOUTH	934,401
40	PINE BLUFF ARSENAL	930,685
41	FORT MCCLELLAN	914,909
42	FORT EUSTIS	907,831
43	DETROIT ARSENAL	891,238
44	LAKE CITY ARMY AMMO PLANT	881,996
45	FORT LEAVENWORTH	868,345
46	RED RIVER ARMY AMMO DEPOT	867,540
47	FORT BENJAMIN HARRISON	842,345
48	FORT HUACHUCA	821,486
49	STRATFORD ARMY ENGINE PLANT	774,041
50	CAMP CASEY, KOREA	756,734
51	LONE STAR ARMY AMMO PLANT	747,764
52	IOWA ARMY AMMO PLANT	745,734
53	FORT LEE	725,970
54	Anniston Army Depot	700,806
55	26TH SPTGRP, HEIDELBERG	668,308
56	WHITE SANDS MISSILE RANGE	666,540

57	MISSISSIPPI ARMY AMMO PLANT	665,458
58	WATERVLIET ARSENAL	661,868
59	TOBYHANNA ARMY DEPOT	646,374
60	FORT MCCOY	646,369
61	USAB (BERLIN)	645,700
62	FORT DIETRICK	630,684
63	FORT SHERIDAN	609,520
64	TOOELE ARMY DEPOT	601,416
65	FORT CLAYTON	586,557
66	FITZSIMONS ARMY MEDICAL CENTER	569,836
67	FORT SHAFTER	567,595
68	CAMP ZAMA JAPAN	556,025
69	LONGHORN ARMY AMMO PLANT	543,813
70	LIMA ARMY TANK PLANT	527,248
71	LETTERKENNY ARMY DEPOT	509,376
72	FORT MCPHERSON	484,372
73	LOUISIANA ARMY AMMO PLANT	478,393
74	SETAF/5TH SUPCOM, VICENZA	450,879
75	NEW CUMBERLAND ARMY DEPOT	432,960
76	FORT HAMILTON	414,203
77	FORT IRWIN	409,088
78	SCRANTON ARMY AMMO PLANT	403,900
79	FORT MYER	400,128
80	Charleston	345,633
81	CORPUS CHRISTI ARMY DEPOT	341,924
82	MTMC MOT BAYONNE	336,471
83	FORT RITCHIE	336,323
84	DUGWAY PROVING GROUND	315,211
85	MCALISTER ARMY AMMO PLANT	303,012
86	USA FDSK	289,543
87	JOLIET ARMY AMMO PLANT	279,146
88	Norfolk	264,526
89	LEXINGTON BLUEGRASS ARMY DEPOT	261,240
90	RIVERBANK ARMY AMMO PLANT	260,607
91	TWIN CITIES ARMY AMMO PLANT	259,886
92	New Orleans	253,040
93	KANSAS ARMY AMMO PLANT	252,916
94	HARRY DIAMOND LAB	250,856
95	Memphis	241,621
96	SACRAMENTO ARMY DEPOT	237,383
97	FORT CHAFFEE	231,468
98	CARLISLE BARRACKS	230,078
99	PUEBLO DEPOT ACTIVITY	228,781
100	Baltimore	227,760
101	HAWTHORNE AAP	218,533
102	FORT MONROE	202,581
103	MILAN ARMY AMMO PLANT	199,012
104	Vicksburg	190,291
105	INDIANA AAP	182,625
106	ROCKY MOUNTAIN ARSENAL	180,873
107	CAMERON STATION	180,853
108	MICHIGAN ARNG	179,729
109	SENECA ARMY DEPOT	175,371
110	ST LOUIS AREA SUPPORT CENTER	171,058
111	St. Louis	165,891
112	USA NATICK RD & E CENTER	156,968
113	VINT HILL FARMS STATION	150,481
114	WES	145,831
115	Mobile	139,117
116	MATERIALS TECHNOLOGY LAB	131,041
117	YUMA PROVING GROUND	128,895
118	SAVANNAH DEPOT ACTIVITY	128,584
119	ARKANSAS ARNG	128,538
120	CALIFORNIA ARNG	125,851
121	SIERRA ARMY DEPOT	118,299
122	MTMC WESTERN AREA	111,840

123	SHARPE ARMY DEPOT	109,986
124	MISSISSIPPI ARNG	103,051
125	Philadelphia	101,658
126	PORT BUCHANAN	99,093
127	INDIANA ARNG	93,468
128	PORT MCNAIR	85,073
129	ARLINGTON HALL STATION	80,319
130	NEWPORT ARMY AMMO PLANT	79,686
131	NEW YORK ARNG	77,991
132	Rock Island	76,629
133	MINNESOTA ARNG	73,709
134	PENNSYLVANIA ARNG	71,281
135	RAVENNA ARMY AMMO PLANT	71,167
136	HEC	69,205
137	NEW JERSEY ARNG	63,078
138	ALABAMA ARNG	62,884
	JEFFERSON PROVING GROUND	62,884
139	IDAHO ARNG	62,454
140	Wilmington	60,550
141	MASSACHUSETTS ARNG	59,886
142	Detroit	58,148
143	Little Rock	57,759
144	OKLAHOMA ARNG	57,185
145	ALASKA ARNG	57,014
146	USAGO MAKIMINATO RYUKYU I	53,117
147	UTAH ARNG	52,925
148	TENNESSEE ARNG	52,815
149	FIELD STATION KUNIA WHEEL	51,558
150	IOWA ARNG	51,369
151	Omaha	50,544
152	Huntington	48,294
153	GEORGIA ARNG	46,796
154	CONNECTICUT ARNG	46,358
155	CRREL	44,255
156	NORTH DAKOTA ARNG	43,787
157	BADGER AAP	43,072
158	OREGON ARNG	42,999
159	WISCONSIN ARNG	42,548
160	ILLINIOS ARNG	41,813
161	125TH ARCOM	40,591
162	Pittsburgh	38,517
163	OHIO ARNG	37,413
164	Kansas City	37,304
165	UMATILLA DEPOT ACTIVITY	36,955
166	LOUISIANA ARNG	36,596
167	FLORIDA ARNG	34,938
168	MISSOURI ARNG	33,548
169	VERMONT ARNG	32,363
170	KANSAS ARNG	31,854
171	Louisville	31,074
172	MONTANA ARNG	30,961
173	TULSA	30,707
174	New York	30,636
175	WASHINGTON ARNG	29,659
176	TEXAS ARNG	29,253
177	KENTUCKY ARNG	28,860
178	RHODE ISLAND ARNG	27,740
179	PUERTO RICO ARNG	27,525
180	USA CERL	26,930
181	ARIZONA ARNG	26,168
182	MAINE ARNG	25,857
183	NEW MEXICO ARNG	25,855
184	COLORADO ARNG	25,332
185	VIRGINIA ARNG	25,031
186	MARYLAND ARNG	24,876
187	Walla Walla	24,845

188	WYOMING ARNG	23,131
189	NORTH CAROLINA ARNG	23,023
190	WEST VIRGINIA ARNG	22,840
191	SOUTH CAROLINA ARNG	22,242
192	FORT WINGATE DEPOT ACTIVITY	21,617
193	NEBRASKA ARNG	21,509
194	ST. LOUIS AAP	21,281
195	SOUTH DAKOTA ARNG	21,061
196	NEVADA ARNG	20,401
197	Buffalo	19,326
198	DELAWARE ARNG	18,689
199	Fort Worth	17,531
200	Sacramento	17,208
201	81ST ARCOM	15,591
202	MOT SUNNY POINT	15,101
203	89TH ARCOM	15,078
204	CORNHUSKER AAP	14,355
205	NED	13,949
206	Seattle	12,352
207	VOLUNTEER ARMY AMMO PLANT	12,342
208	Nashville	12,183
209	NEW HAMPSHIRE ARNG	9,710
210	San Francisco	9,248
211	St. Paul	8,416
212	USAMED	7,422
213	ALBUQUERQUE	7,051
214	DISTRICT OF COLUMBIA ARNG	5,637
215	Jacksonville	3,720
216	GUAM ARNG MARIANAS ISLANDS	3,239
217	PONTIAC STORAGE FACILITY	3,238
218	LOS ANGELES	2,672
219	HAWAII ARNG	2,644
220	Galveston	2,367
221	VIRGIN ISLANDS ARNG	2,034
222	Alaska	1,011
223	Chicago	78
224	RESERVES	0
	FORT A.P. HILL	0

=====

130,082,527

APPENDIX 5:

CHPEÇON Input

FROM SCREENING MODELS

NEW PLANT SCREENING OPTION

Select State, Base, Emission regulation region
Type of boiler system (steam/HTHW)
Process load (MBtu/hr)
Average monthly steam flow (MBtu/hr)
Internal boiler house leak percentage (0-5)
Blowdown percentage (0-10)
Condensate return percentage (0-100)
Condensate return temperature (degrees F)
Makeup water temperature (degrees F)
Boiler technology (Choose one)
Number of boilers (3, 4, 5)
Coalfield-distance search, choose field
Days of long term coal storage (60-100)
Days of short term coal storage (1-3)
Coal pile arrangement (single/multiple)
Rail car thawing shed needed (yes/no/maybe)
Rail transport available for coal/limestone (y/n/m)
Highway transport available for coal/lime (y/n/m)
Are there available sites for ash disposal (A) No landfill is on or near base; B) Landfill is near base; C) Landfill is on base, not adjacent to site; D) Landfill is on base, adjacent to site)
Local sewage disposal of boiler water discharge (y/n/m)
Transport of coal/ash through community/base feasible (y/n/m)
Local resistance to new boiler plant (y/n/m)
Sufficient city water for makeup (y/n/m)
New electrical substation required (y/n/m)
Lime available (y/n/m)
How accessible is steam distribution system (A) Routing is very long and/or difficult to access; B) Routing is fairly accessible and medium length; C) Routing is short and accessible)
Condition of steam distribution system (Poor, Fair, Good)
Does base have its own supply of natural gas (y/n/m)
Does a local utility supply natural gas (y/n/m)
Is natural gas supply interruptible (y/n/m)
Can a firm delivery contract be established (y/n/m)
Natural gas pipeline have sufficient capacity (y/n/m)
Price of natural gas less than price of #2 fuel oil on an equivalent energy basis (y/n/m)
Is low sulfur fuel oil (#2 or #6) available (y/n/m)
Price of #2/#6 fuel oil less than price of natural gas on an equivalent energy basis (y/n/m)

NEW PLANT WITH COGENERATION SCREENING OPTION

Average and peak electricity loads for each month (kW)
Cogenerated electricity generation efficiency (%)
How many hours per year will plant be operated (A) <4000 hours, B) 4000-6000 hours, C) >6000 hours)

Can/does existing electrical system use a single point supply and metering station near the proposed cogeneration site so cogenerated power can displace purchased power (y/n/m)
Will base see reduction of thermal or electric load in near future (y/n/m)
Will utility supply service to maintain and repair interconnection facilities (y/n/m)
Local utility cooperative in setting interconnections and standby power cost (y/n/m)
Local utility use coal (y/n/m)
Present electric rate (\$/kWh)
Anticipated cost of fuel (\$/MBtu)
Facilities electric load: a.<25 MW, b.25-50 MW, c.>50 MW

Facilities load factor: a.<30%, b.30-40%, c.>40%
Base annual electric power to steam power ratio: a.<35 kWh/MBtu, b. 35 - 75 kWh/MBtu, c.>75 kWh/MBtu
Base average ratio of hourly electric to steam power ratio:
a.<35 kWh/MBtu, b.35-75 kWh/MBtu, c.>75 kWh/MBtu

THIRD PARTY COGENERATION OPTION

Process load (MBtu/hr)
Cogeneration electricity-generation efficiency (%)
What is the cost of thermal energy provided by the base (\$/MBtu)
What is the expected cost of thermal energy provided to base by a third party cogenerator (\$/MBtu)
What is the current thermal demand of the base (A) $\geq 500,000$ lb/hr; B) $500,000 \geq x \geq 200,000$ lb/hr; C) $\leq 200,000$ lb/hr)
How many hours per year is third party cogeneration facility expected to be operated (A) ≤ 4000 ; B) 4000 to 5999; C) 6000 to 8760)
Will significant electric generation capacity be consistently available between 8 AM and 6 PM (y/n/m)
Will significant electric generation capacity be consistently available from July 1 to September 15 (y/n/m)
What is the expected cost of electricity that will be produced by the third party cogeneration facility, given today's fuel prices (cents/kWh)
What is the current rate of electricity experienced by the base (cents/kWh)
If the cogeneration facility will supply the base with electricity as well as thermal energy, what is the most likely rate that the cogenerator will offer the base (cents/kWh)
Is the local utility capacity-constrained (y/n/m)
Is wheeling of cogenerated electricity to other demand centers a realistic alternative to local buy-backs (y/n/m)
Does the existing CHP require retrofit/repair/expansion (y/n/m)
Will the thermal output of the facility be at least 5% of the total energy output (y/n/m)
Will electric power output + 0.5 of the useful thermal energy output be at least 42.5% of the fuel heat input if the useful thermal energy is at least 15% of the total, and at least 45% otherwise (y/n/m)

CONSOLIDATION OPTION

Does the base have a relatively flat thermal load profile during the typical day (y/n/m)
Enter the area to be served by the proposed distribution system (acres)
Can you convince the base commander and existing building operators of the advantages of a CHP (y/n/m)
Do the existing buildings utilize steam or HTW for heating (y/n/m)
Does the base have a process steam load which requires steam greater than 200 psi (y/n/m)

RETROFIT SCREENING OPTION

Boiler sizes (lb. steam/hour)
Are feedwater pumps, deaerator, condensate system, and raw water treatment adequate and in a good state of repair (y/n/m)
Does the facility have adequate electric substation to support the modification technology (y/n/m)
Is there room to install ash handling system (y/n/m)
Is there room to install air pollution control equipment (y/n/m)
Is there room to install new combustion control system (y/n/m)
Is there room to install fuel burning equipment (y/n/m)
Can the boiler be retrofitted without major boiler/equipment modifications (y/n/m)
Does the boiler house allow boiler(s) retrofit without major structural change (y/n/m)
Is the stack suitable for use (y/n/m)
Is the auxiliary fuel system adequate to support retrofit technology (y/n/m)
Does the facility/boiler require major repairs or replacement not related to retrofit (y/n/m)
Does the boiler house have a basement (y/n/m)
Is the soot blowing system in proper working order (y/n/m)

Is existing ash handling equipment available (a/b/c)
Is existing coal handling equipment available (a/b/c)

FROM COSTING MODELS

NEW PLANT COSTING

Years plant is to be operated (maximum of 25)
Current discount rate (%)
Net salvage value of current system (\$)
What % of Adjusted Investment Cost is the net salvage value of the new or retrofit system
What is the year of the study
What year will the facility start operation
Escalation factors (choices given)
Coal transport cost (cents/ton-mile)
Coal transport cost escalation rate (%)
Apply 10% investment cost exclusion (y/n)
Water cost (\$/1000 gallons)
Non-potable water cost (\$/1000 gallons)
Sewer cost (\$/1000 gallons)
Ash waste disposal (\$/ton)
Lime cost (\$/ton)
Cost of coal; distillate oil; residual oil; electricity; natural gas; (defaults given)
Is a desuperheater required (y/n/m)
Coal transport by truck, rail, both (t/r/b)
Should a stock/reclaim system be included (y/n/m)
Include a coal silo (y/n/m)
Storage time for silo (1-7 days)
Dry scrubber and lime: days of storage required (3-28 days)
Include a mixed-bed for condensate polishing (y/n/m)
Include a dealkalizer unit (y/n/m)
Required storage for condensate storage tank (1-4 hours)
Amount of water in ash waste (1-50%)

NEW PLANT WITH COGENERATION COSTING

Steam load: (1) to meet electricity load; 2) to follow heat/process load)
Should non-potable water be used for cooling tower and ash conditioning (y/n/m)

THIRD PARTY COGENERATION COSTING

See New Plant Costing

CONSOLIDATION COSTING

Select the type of steam system design (A) Tunnel construction; B) Direct Burial; C) Shallow trench/walkway construction; D) Above ground single stanchion construction)
Enter dimensions of steam distribution system (ft x ft; # of connections)

APPENDIX E:

CHPECON Screening Model Report

```

*****
** Central Heating Plant Economics Evaluation Program          Page 1  **
** File: F1              Type: New plant (NP)                09/21/92  **
** Desc: FORT CAMPBELL                                         **
** Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection  **
*****

```

State : KY - Kentucky
 Location : 36d 7m - 86d 41m
 County :
 Emission regulation region
 # 0 - State and federal only

Annual heating degree days: 4166

***** Boiler Characteristics *****

Type of heating system : Steam

Average Monthly Steam Flows (million Btu/hr)

Jan	Feb	Mar	Apr	May	Jun
79	98	72	60	39	40
Jul	Aug	Sep	Oct	Nov	Dec
40	36	33	50	65	82

Calculated PMCR: 188 thousand lb/hr steam *** manual entry

Boiler technology: Dump Grate Spreader Stoker, w/ fly ash reinjection

Boiler sizes (thousand lb steam/hr) :

1: 43 2: 73 3: 73 4: 73

***** Coalfield Properties *****

Coalfield state : IN - Indiana
 Coal code: W193122 desc: MS NO 2 PIT
 Distance from base: 140 miles
 Located at 38d 05m 34s - 87d 15m 44s
 Cmnt:

Proximate Analysis

Ultimate Analysis

Rank	: Bituminous	Carbon	: 71.40 %
Moisture	: 8.60 %	Hydrogen	: 5.00 %
Volatiles	: 37.60 % dry	Sulfur	: 2.80 %
Fixed Carbon	: 52.10 % dry	Oxygen	: 9.10 %
Ash	: 10.30 % dry	Nitrogen	: 1.40 %
		Ash	: 10.30 %

Hrdgrv Grind : 0.0
 Free Swell : 4.0
 Hemisph Temp : 2327 deg F
 Heating Value (dry) : 12830 Btu/lb

```

*****
**   Coal Fired Boiler Evaluation Program                               Page 2   **
**   File: F1                      Type: New plant (NP)                09/21/92   **
**   Desc: FORT CAMPBELL                                              **
**   Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection        **
*****

```

***** Boiler Performance @ PMCR *****

```

Heat input : 253 million Btu/hr
Coal input : 9.9 tons/hr (dry)
              10.8 tons/hr (incl moisture)
Blowdown   : 5 %

Temperature out of stack : 220 deg F
Gas flow from stack      : 88017 cubic feet/min
Steam pressure           : 150 psig
Steam temperature        : 367 deg F      enthalpy : 1195.6 Btu/lb
Condensate return temp   : 150 deg F      enthalpy : 118.8 Btu/lb
Makeup water temperature : 50 deg F       enthalpy : 18.1 Btu/lb
Inlet water temperature  : 97 deg F       enthalpy : 65.2 Btu/lb

```

***** Boiler Emissions @ PMCR *****

```

147.97 lb/hr, NOx emissions (out stack)
110.36 lb/hr, SOx emissions (out stack)
2032.10 lb/hr, particulate emissions (from boiler)
1625.68 lb/hr, particulate emissions (after settling chamber)
243.85 lb/hr, particulate emissions (after mechanical collector)
36.58 lb/hr, particulate emissions (after dry scrubber)
0.18 lb/hr, particulate emissions (after baghouse - out stack)

```

Ash collected by emis equip @ pmcr: 24.4 tons/day

Total ash output @ pmcr: 24.4 tons/day

***** Area and Water Requirements @ PMCR *****

```

Building size : 12267 sq ft      Condensate Return      : 50 %
Plant area    : 1.73 acres       Boiler house leakage   : 2 %
Plant height  : 69 ft           Water requirements     : 250 gpm (est)
Stack height  : 173 ft          Railway track length   : 672 ft
Sewer dischrq : 50 gpm (est)    Lime needed            : 2145 lb/hr

```

Multiple coal piles for storage

```

Long term : 90 days long term storage, on 3.06 acres
Short term : 3 days short term storage, on 0.21 acres

```

Total storage area (long + short + others) : 4.27 acres

Pond size : 0.37 acres

Car thawing shed required: No

```

*****
**   Coal Fired Boiler Evaluation Program                               Page 3   **
**   File: F1                      Type: New plant (NP)                09/21/92   **
**   Desc: FORT CAMPBELL                                              **
**   Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection        **
*****

```

***** Emission Regulation Evaluation @ PMCR *****

This plant passed all emission regulations

NOx:	147.97	151.87	Regulation of: US
			emissions [lb/hr] = 0.6 * input [10 ⁶ Btu/hr]
Part:	0.18	12.66	Regulation of: US
			emissions [lb/hr] = 0.05 * input [10 ⁶ Btu/hr]
SOx:	110.36	303.75	Regulation of: US
			emissions [lb/hr] = 1.2 * input [10 ⁶ Btu/hr]
SOx:	90.01	90.00	Regulation of: US
			reduction = 90 %
NOx:	147.97	177.19	Regulation of: KY
			emissions [lb/hr] = 0.7 * input [10 ⁶ Btu/hr]
Part:	0.18	25.31	Regulation of: KY
			emissions [lb/hr] = 0.1 * input [10 ⁶ Btu/hr]


```

*****
**   Coal Fired Boiler Evaluation Program                               Page 4   **
**   File: F1                      Type: New plant (NP)                09/21/92  **
**   Desc: FORT CAMPBELL                                              **
**   Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection        **
*****

```

***** General Site Considerations *****

Rail transport available: Yes
 Highway transport available: Yes
 No problems with transportation.
 Score: 10

Location of ash disposal site: landfill near base
 Ash disposal can be a problem. Further investigation should verify
 ash disposal possibilities.
 Score: 5

Local sewer system available: Maybe
 Local sewage facilities may not be available. Therefore, it
 may be difficult to dispose of boiler water.
 Score: 5

Coal/ash transport feasible: Maybe
 Transportation of coal and/or ash might impose problems.
 Score: 5

Local community resistant to plant: Maybe
 The impact of community resistance might impose problems.
 Score: 5

City water available: Maybe
 Additional efforts and costs may be required to establish a water
 supply which are not considered in the detailed evaluation
 section of this program.
 Score: 5

New electrical substation required: Maybe
 Additional effort and expense may be required to construct
 a new substation.
 Score: 2

Lime available: Maybe
 Lime is required in the dry scrubbers for the stokers. Therefore, a more
 thorough investigation on the availability of a lime supply should be
 performed before considering a detailed plant evaluation or another
 combustion technology or fuel type should be considered.
 Score: 5

Steam distribution system routing is medium
 It may be difficult to incorporate the existing distribution system
 into the new plant. Additional costs may be required heavily modify
 the existing distribution system. These costs are not considered in
 the new plant detailed evaluation section of this program.
 Score: 2

```

*****
**   Central Heating Plant Economics Evaluation Program           Page 5   **
**   File: F1               Type: New plant (NP)                 09/21/92  **
**   Desc: FORT CAMPBELL                                           **
**   Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection    **
*****

```

Condition of system is fair
 Additional costs may be required to install a new distribution system.
 These costs are not considered in the detailed evaluation program.
 Score: 3

Boiler technology rating: 10

Feasibility score: 57/95 = 60%

APPENDIX F:

**CHPECON Costing Model Report
(Long Form)**

File: F1 Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Base Information

State: KY - Kentucky

Base DOE Region: 3

PMCR: 188,000 lb/hr steam

Number of boilers: 4

Steam Properties: 150 psi (1195.6 Btu/lb)

Inlet water temp: 97 deg F enthalpy: 65.2 Btu/lb

Coalfield:

Coal code: W193122

desc: MS NO 2 PIT

State: IN - Indiana

Distance from base: 140 miles

Coal type: bituminous

(properties on a dry basis)

hhv: 12830 Btu/lb fixed carbon: 52.10% volatiles: 37.60%

ash: 10.30% sulfur: 2.80%

Coalfield DOE Region: 2

Boiler Design Parameters

A desuperheater IS required

A stock/reclaim system SHOULD BE included

A coal silo IS needed

Storage required for coal silo: 3 days

Selected method for coal transport is by BOTH RAIL AND TRUCK

Ash silo diameter: 20 feet

Number of ash silos: 1

Required lime storage: 14 days

A mixed bed for condensate polishing IS REQUIRED

A dealkalizer unit IS INCLUDED

Storage required for the condensate storage tank: 1 hours

Fraction of water in the ash waste generated: 10 %

File: F1 Type: New plant (NP)
Desc: FORT CAMPBELL
Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

09/21/92

Plant Design Parameters --- Space Requirements

Approx. building width: 66 feet
Approx. building length: 185 feet
Air compressor flow rate: 219 cfm
Diesel generator capacity: 500 kW
Fuel storage area: 4.27 acres
Coal pile runoff pond area: 0.37 acres
Height of the plant: 69 ft
Building area: 12267 sq ft
Plant area: 1.73 acres

Plant Design Parameters --- Material Handling Specifications

Coal handling equipment capacity: 100 tons/hr
Coal silo storage capacity: 713 tons
Fly ash pipe size: 4 inches
Bottom ash pipe size: 6 inches
Total ash collected: 58 tons/day
Total gas flow: 294263 lbs/hr
Fly ash intake: 2 tons/day
Bottom ash intake: 2 lbs/hr
Ash silo capacity: 231 tons
Lime silo storage capacity: 397 tons
Number of facility fuel oil tanks: 1
Acid and caustic storage tank volume: 13537 gallons

Plant Design Parameters --- Water & Water Treatment Specifications

Number of deaerators: 2
Number of resin vessels / train: 1
Number of mixed beds / train: 1
Condensate storage tank size: 11285 gallons
Water storage tank size: 189580 gallons
Number of water treatment trains: 2
Boiler 1: 1 motor-driven feedwater pump -- 83 gpm
Boiler 1: 1 turbine-driven feedwater pump -- 83 gpm
Boiler 2: 1 motor-driven feedwater pump -- 141 gpm
Boiler 2: 1 turbine-driven feedwater pump -- 141 gpm
Boiler 3: 1 motor-driven feedwater pump -- 141 gpm
Boiler 3: 1 turbine-driven feedwater pump -- 141 gpm
Boiler 4: 1 motor-driven feedwater pump -- 141 gpm
Boiler 4: 1 turbine-driven feedwater pump -- 141 gpm
Annual dry scrubber water use: 1,771,215 gallons
Annual personnel water use: 236,250 gallons

File: F1 Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Capital Costs

Boiler capital costs: \$ 10,335,163

Boiler #1 (43 k-lb stm/hr) cost: \$ 2,118,713

Boiler #2 (73 k-lb stm/hr) cost: \$ 2,735,878

Boiler #3 (73 k-lb stm/hr) cost: \$ 2,735,878

Boiler #4 (73 k-lb stm/hr) cost: \$ 2,735,878

Desuperheater cost: \$ 8,815

Coal Handling Capital Costs: \$ 4,746,004

Rail/truck receiving cost: \$ 2,192,748

Car dumper installed cost: \$ 2,487,083

Coal pond cost: \$ 21,311

Coal silo cost: \$ 44,860

Ash handling system capital costs: \$ 527,457

Ash piping system cost: \$ 87,583

Air operated branch line gate cost: \$ 12,125

Air operated fly ash intake cost: \$ 74,046

Mechanical exhauster cost: \$ 111,506

Manual bottom ash intake cost: \$ 4,407

Receiver cost: \$ 44,073

Mixer and unloader cost: \$ 155,151

Control cost: \$ 38,563

Mechanical Collector Capital Costs: \$ 142,214

cost of collector #1 : \$ 30,910

cost of collector #2 : \$ 37,101

cost of collector #3 : \$ 37,101

cost of collector #4 : \$ 37,101

Dry scrubber and lime system capital costs: \$ 1,960,918

cost of dry scrb/lime sys #1 : \$ 339,770

cost of dry scrb/lime sys #2 : \$ 339,770

cost of dry scrb/lime sys #3 : \$ 339,770

cost of dry scrb/lime sys #4 : \$ 339,770

Lime silo equipment cost: \$ 262,068

Baghouse and ID fan capital costs: \$ 1,804,867

Cost of baghouse #1 : \$ 366,276

Cost of ID fan #1 : \$ 22,936

Cost of baghouse #2 : \$ 445,003

Cost of ID fan #2 : \$ 26,880

Cost of baghouse #3 : \$ 445,003

Cost of ID fan #3: \$ 26,880

Cost of baghouse #4 : \$ 445,003

Cost of ID fan #4 : \$ 26,880

Boiler Water Treatment System Capital Costs: \$ 707,707

Cost of zeolite softeners: \$ 48,963

Cost of dealkalizers: \$ 319,551

File: F1 Type: New plant (NP)
Desc: FORT CAMPBELL
Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

09/21/92

Facility Capital Costs, cont

Cost of mixed bed for condensate polishing: \$ 226,253
Cost of chemical injection skid: \$ 22,037
Cost of water lab: \$ 22,037
Cost of 2 deaerators: \$ 68,863

Tank Capital Costs: \$ 445,201

Pump Capital Costs: \$ 171,721

Air compressor capital costs: \$ 60,277

Waste Water Treatment System Capital Costs: \$ 70,911

Sanitary system cost: \$ 37,243
Pond neutralization cost: \$ 9,923
Storm sewer system cost: \$ 23,743

Piping and Stack System Capital Costs: \$ 2,512,048

Water/steam piping cost: \$ 1,035,770
Facility stack cost: \$ 1,476,277

Instrumentation Capital Costs: \$ 881,507

Cost of heating/cogen control system: \$ 220,376
Cost of emission monitors: \$ 661,130

Electrical System Capital Cost: \$ 1,045,298

Cost of backup diesel generation system: \$ 56,802
Cost of substations: \$ 929,328

Spare Parts, Tools and Mobile Equipment Capital Costs: \$ 1,357,713
spare parts basis = equipment cost (unescaled): \$ 23,061,686

Building and service capital costs: \$ 5,273,923

Building costs: \$ 4,430,133
Elevator costs: \$ 165,282
Miscellaneous building costs: \$ 343,683
Site development / improvement costs: \$ 231,312
Cost of fuel storage area development: \$ 103,510

File: F1 Type: New plant (NP)
Desc: FORT CAMPBELL
Tech: Dump Grate Spreader Stoker, w/ fly ash reir_ection

09/21/92

Facility Installation Costs

Boiler Installation costs: \$ 2,721,259

Direct labor cost: \$ 727,889

Indirect cost: \$ 545,917

Freight cost: \$ 206,703

Bulk material cost: \$ 1,240,748

Coal Handling Installation Costs: \$ 1,373,625

Direct labor cost \$ 323,888

Indirect cost \$ 242,916

Freight cost \$ 94,920

Bulk material cost \$ 711,900

Ash Handling Installation Costs: \$ 2,602,879

Direct labor cost: \$ 1,345,699

Indirect cost: \$ 1,009,274

Freight cost: \$ 10,549

Bulk material cost: \$ 237,356

Mechanical Collector Installation Costs: \$ 30,858

Direct labor cost: \$ 11,945

Indirect cost: \$ 8,958

Freight cost: \$ 2844

Bulk material cost: \$ 7,110

Dry Scrubber and Lime System Installation Costs: \$1,514,550

Direct labor cost: \$ 427,783

Indirect cost: \$ 320,837

Freight cost: \$ 39,218

Bulk material cost: \$ 726,712

Baghouse and ID Fan Installation Costs: \$ 985,474

Direct labor cost: \$ 259,641

Indirect cost: \$ 194,730

Freight cost: \$ 36,097

Bulk material cost: \$ 495,004

Boiler Water Treatment System Installation Costs: \$ 434,554

Direct labor cost: \$ 116,378

Indirect cost: \$ 87,283

Freight cost: \$ 14,154

Bulk material cost: \$ 216,738

Tank Installation Costs: \$ 287,801

Direct labor cost: \$ 113,164

Indirect cost: \$ 84,873

Freight cost: \$ 8,904

Bulk material cost: \$ 80,858

Pump installation costs: \$ 82,902

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Installation Costs, cont

Direct labor cost: \$ 24,471
Indirect cost: \$ 18,353
Freight cost: \$ 3,434
Bulk material cost: \$ 36,643

Air Compressor Installation Costs: \$ 31,273

Direct labor cost: \$ 5,126
Indirect cost: \$ 3,844
Freight cost: \$ 1,205
Bulk material cost: \$ 21,097

Waste Water Treatment System Installation Costs: \$ 60,089

Direct labor cost: \$ 25,655
Indirect cost: \$ 19,241
Freight cost: \$ 1,418
Bulk material cost: \$ 13,773

Piping and Stack System Installation Costs: \$ 2,225,710

Direct labor cost: \$ 879,704
Indirect cost: \$ 659,778
Freight cost: \$ 50,240
Bulk material cost: \$ 635,987

Instrumentation Installation Costs: \$ 613,291

Direct labor cost: \$ 101,111
Indirect cost: \$ 75,833
Freight cost: \$ 17,630
Bulk material cost: \$ 418,715

Electrical System Installation Costs: \$ 800,435

Direct labor cost: \$ 254,377
Indirect cost: \$ 190,782
Freight cost: \$ 20,905
Bulk material cost: \$ 334,369

Spare Parts, Tools, Mobile Equipment Installation Costs: \$ 27,154

Freight cost: \$ 27,154

Building Costs: \$ 1,287,398

Direct labor cost: \$ 106,810
Indirect cost: \$ 80,107
Freight cost: \$ 103,408
Bulk material cost: \$ 997,072

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Direct Costs

Direct costs: \$ 14,328,324

Permit development cost: \$ 807,736

Engineering cost: \$ 3,845,152

Construction management cost: \$ 2,243,005

Construction contingency cost: \$ 4,806,440

Owners management cost: \$ 2,336,329

Startup cost: \$ 289,660

Installed Capital Equipment Cost Summary

Total Capital Costs: \$ 32,042,935

Total Direct labor cost: \$ 4,723,647

Total Indirect cost: \$ 3,542,735

Total Freight cost: \$ 638,788

Total Bulk material cost: \$ 6,174,089

Total Direct costs: \$ 14,328,324

Plant installed cost: \$ 61,450,519

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Operating Labor Requirements

Operation personnel requirements

plant manager: 1
plant engineer: 1
plant technician: 1
plant clerk: 1
plant secretary: 1
plant janitor: 1
operations operator: 6
operations assistant operator: 3
operations laborer: 2
fuel storage operator equipment: 1
fuel storage assistant operator: 1
fuel storage laborer: 2
maintenance a mechanic: 3
maintenance a electrician: 2
maintenance laborer: 1

Operating staff: 27

Annual Labor Costs: \$ 1,185,309

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Yearly O & M Costs Summary

Annual boiler maintenance costs: \$ 87,848
Annual spare parts costs (first year): \$ 84,101
Annual spare parts costs (after first year): \$ 476,573
Annual mobile equipment maintenance costs: \$ 31,469
Annual facility consumables costs: \$ 39,247
Annual O & M (materials/supplies) costs: \$ 526,167
Annual diesel/distillate fuel usage: 16,752 gallons
Annual electricity usage: 3,722,308 kW-hr
Annual lime cost: \$ 230,257
Annual condensate make-up water cost: \$ 90,663
Annual blowdown make-up water cost: \$ 9,066
Annual dry scrubber water cost: \$ 5,313
Annual ash conditioning water cost: \$ 217
Annual facility washdown water cost: \$ 2,340
Annual condensate polisher water cost: \$ 3,812
Annual zeolite softener water cost: \$ 2,897
Annual personnel water cost: \$ 708
Annual chemicals cost: \$ 2,997
Annual sanitary sewer cost: \$ 3,790
Annual ash disposal cost: \$ 151,577
Annual miscellaneous maintenance costs: \$ 22,523
Annual lime usage: 2,878 tons
Study year lime cost: \$80.00/ton
Study year water cost: \$3.00/1000 gallon
Study year ash disposal cost: \$50.00/ton
Study year coal transportation cost: 2.18 cents/ton-mile
Study year cost transportation cost escalation rate: \$0.00 %
(escalation above general inflation)
1993 cost for coal: 1.530 \$/MMBtu
1993 cost for distillate: 0.633 \$/gallon
1993 cost for electricity: 0.047 \$/kW-hr

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Periodic Maintenance Costs Summary

Major boiler maintenance costs (every 8 years): \$ 310,054
Coal handling system maintenance costs (every 10 years): \$ 474,600
Major ash handling system maintenance costs (every 7 years): \$ 116,040
Major scrubber-lime system maintenance costs (every 5 years): \$ 101,931
Lime conveyor system maintenance costs (every 5 years): \$ 6,115
Major baghouse maintenance costs (every 3 years): \$ 85,064
Major baghouse maintenance costs (every 12 years): \$ 119,090
Major I.D. fan maintenance costs (every 20 years): \$ 39,360
Major water treatment system maintenance costs (every 10 years): \$ 267,645
Major deaerator maintenance costs (every 20 years): \$ 17,215
Motor-driven feedwater pumps maint costs (every 15 years): \$ 14,652
Turbine-driven feedwater pumps maint costs (every 12 years): \$ 25,919
Centrifugal pump maint costs (every 18 years): \$ 21,153
Sump pump maintenance costs (every 20 years): \$ 13,652
Major stack maintenance costs (every 20 years): \$ 14,762
Major building maintenance costs (every 20 years): \$ 664,520
Periodic EPA permit testing/renewal costs (every 3 years): \$ 30,000

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Economic Data Summary

Capital Equipment Escalation Factor: 1.102

based on Engineering News Record, Construction Cost Index: 5032.16

Non-Labor Operation & Maintenance Escalation Factor: 1.092

based on Chemical Engineering, M & S Index, Steam Power Comp: 935.60

Operation & Maintenance Labor Escalation Factor: 1.119

based on Engineering News Record, Skilled Labor Index: 4626.82

Construction Labor Escalation Factor: 1.024

based on Chemical Engineering, Construction Labor Index: 271.10

Annual Facility Output: 504,528 thousand lb steam

Steam enthalpy: 1195.6 Btu/lb

Inlet enthalpy: 65.1 Btu/lb

Annual Coal Usage: 26,568 tons (dry)

28,853 tons (wet)

Heating plant efficiency: 84%

Discount Rate: 4.0 %

Coal Transportation Cost: 2.18 cents/ton-mile

Coal Transportation Cost Escalation: 0.00 %

Year of Study: 1993

Years of Operation: 1997 - 2021

10% Investment Cost Exclusion IS NOT applied

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Cash Flow Summary
*****-----
1996 adjusted investment: 61,450,519 existing plant salvage: 0

Year	Boiler Fuel & Tran	Auxiliary Energy	Non-Energy O&M	Repair and Replacement
1997	1,257,844	191,084	1,954,143	0
1998	1,272,650	192,961	2,346,616	0
1999	1,280,058	195,140	2,346,616	115,064
2000	1,302,271	199,739	2,346,616	0
2001	1,317,076	202,592	2,346,616	108,047
2002	1,331,881	205,272	2,346,616	115,064
2003	1,339,289	207,779	2,346,616	116,041
2004	1,361,491	210,113	2,346,616	310,055
2005	1,383,704	213,212	2,346,616	115,064
2006	1,413,315	214,226	2,346,616	850,293
2007	1,442,936	216,004	2,346,616	0
2008	1,479,955	217,274	2,346,616	175,010
2009	1,502,168	218,692	2,346,616	0
2010	1,524,370	220,531	2,346,616	116,041
2011	1,545,916	222,073	2,346,616	237,764
2012	1,567,790	223,629	2,346,616	310,055
2013	1,589,981	225,200	2,346,616	0
2014	1,612,511	226,784	2,346,616	136,217
2015	1,635,383	228,385	2,346,616	0
2016	1,658,593	229,999	2,346,616	1,599,804
2017	1,682,143	231,628	2,346,616	231,105
2018	1,706,056	233,130	2,346,616	0
2019	1,730,330	234,647	2,346,616	0
2020	1,754,968	236,180	2,346,616	485,065
2021	1,779,968	237,731	2,346,616	108,047

2022 new plant salvage: 0

File: F1

Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Life Cycle Cost Summary

+ PV 'Adjusted' Investment Costs	= \$	54,629,288
+ PV Energy + Transportation Costs	= \$	23,154,192
+ PV Annually Recurring O&M Costs	= \$	32,254,253
+ PV Non-Annually Recurring Repair & Replacement	= \$	2,537,619
+ PV Disposal Cost of Existing System	= \$	0
+ PV Disposal Cost of New/Retrofit Facility	= \$	0

Total Life Cycle Cost (1993)	= \$	112,575,353
------------------------------	------	-------------

Levelized Cost of Service (1997 start)

= 13.975 \$/MMBtu

Levelized Cost of Service (1997 start)

= 16.709 \$/1000 lb steam

APPENDIX G:

**CHPECON Costing Model Report
(Short Form)**

File: F1 Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Base and Plant Information

State: KY - Kentucky

Base DOE Region: 3

PMCR: 188,000 lb/hr steam

Number of boilers: 4

Coal code: W193122

Distance from base: 140 miles

State: IN - Indiana

DOE Region: 2

Coal type: bituminous

(properties on a dry basis)

hvh: 12830 Btu/lb fixed carbon: 52.10% volatiles: 37.60%

ash: 10.30% sulfur: 2.80%

Coal handling equipment capacity: 100 tons/hr

Coal silo storage capacity: 713 tons

Approx. building width: 66 feet

Approx. building length: 185 feet

Height of the plant: 69 ft

Building area: 12267 sq ft

Plant area: 1.73 acres

Facility Parameters

Capital Equipment Escalation Factor: 1.102 (5032.16/1993)

Non-Labor Operation & Maintenance Escalation Factor: 1.092 (935.60/1993)

Operation & Maintenance Labor Escalation Factor: 1.119 (4626.82/1993)

Construction Labor Escalation Factor: 1.024 (271.10/1993)

Annual diesel/distillate fuel usage: 16,752 gallons

Annual electricity usage: 3,722,308 kW-hr

Annual lime usage: 2,878 tons

1993 cost for coal: 1.530 \$/MMBtu

1993 cost for distillate: 0.633 \$/gallon

1993 cost for electricity: 0.047 \$/kW-hr

Annual Facility Output: 504,528 thousand lb steam

Annual Coal Usage: 26,568 tons (dry) / 28,853 tons (wet)

Heating plant efficiency: 84%

Year of Study: 1993

Years of Operation: 1997 - 2021

Facility Installed Capital Costs

Equipment	Cost	Equipment	Cost
Boiler:	\$ 13,056,422	Coal Handling:	\$ 6,119,630
Ash Handling:	\$ 3,130,337	Mechnc'l Collector:	\$ 173,073
Dry Scrubber/Lime:	\$ 3,475,468	Baghouse/ID Fan:	\$ 2,790,341

File: F1 Type: New plant (NP)

09/21/92

Desc: FORT CAMPBELL

Tech: Dump Grate Spreader Stoker, w/ fly ash reinjection

Facility Installed Capital Costs, cont

Water Treatment:	\$	1,142,261	Pumps:	\$	254,623
Air Compressor:	\$	91,551	Waste Water Trtmnt:	\$	131,000
Piping/Stack:	\$	4,737,758	Electrical System:	\$	1,845,734
Building Costs:	\$	6,561,322	Direct costs:	\$	14,328,324

Plant installed cost: \$ 61,450,519

Facility Annual O & M and Energy Costs

Operating staff: 27

Annual Labor Costs: \$ 1,185,309

First Year Non-Labor O & M Costs : \$ 1,954,143

Annual Year Non-Labor O & M Costs : \$ 2,346,616

1997 Coal Costs (incl transport) : \$ 1,257,844

1997 Auxiliary Energy Costs : \$ 191,084

Periodic Major Maintenance Cost Summary

Time Interval	Cost	Time Interval	Cost
3 years	\$ 115,064	5 years	\$ 108,047
7 years	\$ 116,041	8 years	\$ 310,055
10 years	\$ 742,246	12 years	\$ 59,946
15 years	\$ 14,653	18 years	\$ 21,153
20 years	\$ 749,511		

Facility Life Cycle Cost Summary

+ PV 'Adjusted' Investment Costs	= \$	54,629,288
+ PV Energy + Transportation Costs	= \$	23,154,192
+ PV Annually Recurring O&M Costs	= \$	32,254,253
+ PV Non-Annually Recurring Repair & Replacement	= \$	2,537,619
+ PV Disposal Cost of Existing System	= \$	0
+ PV Disposal Cost of New/Retrofit Facility	= \$	0

Total Life Cycle Cost (1993) = \$ 112,575,353

Levelized Cost of Service (1997 start) = 13.975 \$/MMBtu

Levelized Cost of Service (1997 start) = 16.709 \$/1000 lb steam

USACERL DISTRIBUTION

Chief of Engineers

ATTN: CEHEC-IM-LH (2)
ATTN: CEHEC-IM-LP (2)
ATTN: CERD-L

CECPW 22060

ATTN: CECPW-FU-M
ATTN: Library

US Army Engr District

ATTN: Library (40)

US Army Engr Division

ATTN: Library (13)

US Army Europe

ATTN: AEAEN-ODCS 09014

US Army Materiel Command (AMC)

Alexandria, VA 22333-0001
ATTN: AMCEN-F

FORSCOM

Forts Gillem & McPherson 30330
ATTN: FCEN

Fort Belvoir 22060

ATTN: CECC-R

TRADOC

Fort Monroe 23651
ATTN: ATBO-G

USARPAC 96858

ATTN: DPW
ATTN: APEN-A

CEWES 39180

ATTN: Library

CECRL 03755

ATTN: Library

USA AMCOM 61299

ATTN: AMSMC-IR
ATTN: AMSMC-IS

Naval Facilities Engr Command

ATTN: Code 1652B 22332-2300

Naval Facilities Engr Service Center 93043

ATTN: Code 241

US Army HSC

Fort Sam Houston 78234
ATTN: HSLO-F

Fitzsimons Army Medical Ctr

ATTN: HSHG-DPW 80045
Walter Reed Army Medical Ctr 20307

National Guard Bureau 20310

ATTN: Installations Div

Tyndall AFB 32403

ATTN: HQAFCEA Program Ofc

Defense Tech Info Center 22304

ATTN: DTIC-FAB (2)

Defense Fuel Supply Center

ATTN: DFSC-PR 22314

80

11/93